Project Manual

DATE: March 27, 2025



DARKE COUNTY WAGNER AVENUE INTERIOR RENOVATON

631 Wagner Ave. Greenville, Ohio 45331



615 Woodside Drive, Englewood, Ohio 45322 T 937.836.8898 F 937.832.3696

www.app-arch.com

PROJECT NUMBER: 3961.05



SECTION 00 0100 TABLE OF CONTENTS

PROCUREMENT AND CONTRACTING REQUIREMENTS

1.01 DIVISION 00 -- PROCUREMENT AND CONTRACTING REQUIREMENTS

00 0100 - Table of Contents	00	0100	- Table	of (Contents
-----------------------------	----	------	---------	------	----------

- 00 0103 Project Directory
- 00 0115 List of Drawing Sheets
- 00 1000 Legal Notice
- 00 2113 Instructions to Bidders
- 00 4100 Bid Form
- 00 4336 Subcontractors List
- 00 5200 Agreement Form
- 00 6000 Project Forms
- 00 7200 General Conditions
- 00 7300 Supplementary Conditions
- 00 8300 Wage Rates

SPECIFICATIONS

2.01 DIVISION 01 -- GENERAL REQUIREMENTS

- 01 1000 Summary
- 01 2000 Price and Payment Procedures
- 01 2100 Allowances
- 01 2200 Unit Prices
- 01 2500 Substitution Procedures
- 01 3000 Administrative Requirements
- 01 5000 Temporary Facilities and Controls
- 01 6000 Product Requirements
- 01 7000 Execution and Closeout Requirements
- 01 7800 Closeout Submittals

2.02 DIVISION 02 -- EXISTING CONDITIONS

02 4100 - Demolition

2.03 DIVISION 03 CONCRETE	SEE DRAWINGS
---------------------------	--------------

2.04 DIVISON 05 -- METALS SEE DRAWINGS

2.05 DIVISION 06 -- WOOD, PLASTICS, AND COMPOSITES SEE DRAWINGS

2.06 DIVISION 07 -- THERMAL AND MOISTURE PROTECTION SEE DRAWINGS

2.07 DIVISION 08 -- OPENINGS SEE DRAWINGS FOR BALANCE OF SECTIONS

08 0671 - Door Hardware Schedule

2.08 DIVISION 09 -- FINISHES SEE DRAWINGS

2.09 DIVISION 21 -- FIRE SUPPRESSION SEE DRAWINGS

2.10 DIVISION 23 -- HEATING, VENTILATING, AND AIR-CONDITIONING (HVAC)

23 0000 General Requirements for HVAC Systems

- 23 0001 Basic HVAC Requirements
- 23 0002 HVAC Work in Existing Buildings
- 23 0500 Common Work Results for HVAC
 - 23 0529 Pipe Hangers and Supports
 - 23 0553 Identification for HVAC Systems
- 23 0700 HVAC Insulation
 - 23 0713 Duct Insulation
 - 23 0719 Pipe Insulation
- 23 0900 Instrumentation and Control for HVAC
 - 23 0913 Instruments and Control Devices
 - 23 0914 Control Wiring and Cabling
 - 23 0923 Direct Digital Control System
- 23 2000 HVAC Piping and Pumps
 - 23 2113 Hydronic Piping
- 23 3000 HVAC Air Distribution
 - 23 3113 Ductwork
 - 23 3300 Air Duct Accessories
 - 23 3600 Air Terminal Units
 - 23 3713 Diffusers, Registers and Grilles

2.11 DIVISION 26 -- ELECTRICAL

- 26 0000 General Requirements for Electrical Systems
 - 26 0001 Basic Electrical Requirements
- 26 0500 Common Work Results for Electrical
 - 26 0519 Low-Voltage Electrical Power Conductors and Cables
 - 26 0529 Hangers and Supports for Electrical Systems
 - 26 0533 Raceway and Boxes for Electrical Systems
 - 26 0537 J-Hook Pathways for Electrical Systems
 - 26 0553 Identification for Electrical Systems
- 26 0900 Instrumentation and Control for Electrical
 - 26 0923 Lighting Control Devices
- 26 2000 Low-Voltage Electrical Distribution
 - 26 2416 Panelboards
 - 26 2726 Wiring Devices
- 26 5000 Lighting
 - 26 5113 Interior Lighting Fixtures
- 26 7000 Voice and Data Communications
 - 26 7561 Voice and Data Communications Horizontal Cabling

SECTION 00 0103 PROJECT DIRECTORY

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Identification of project team members and their contact information.

1.02 CONTRACTING AUTHORITY / OWNER:

- A. Name: Darke County Board of Commissioners
 - 1. Address Line 1: 520 S. Broadway St
 - City: Greenville
 Zip Code: 45331
- B. Owner's Representative:
 - 1. Title: Facility & Safety Manager
 - 2. Name: Dale Musser
 - 3. Email: dmusser@co.darke.oh.us

1.03 CONSULTANTS:

- A. Architect: Design Professional of Record. All correspondence from the Contractor regarding construction documents authored by Architect's consultants will be through this party, unless alternate arrangements are mutually agreed upon at preconstruction meeting.
 - 1. Company Name: App Architecture.
 - a. Address: 615 Woodside Dr
 - b. City: Englewoodc. State: Ohio
 - d. Zip Code: 45322
 - e. Telephone: (937) 836-8898
 - 2. Primary Contact:
 - a. Title: Project Architect
 - b. Name: Maria E. Schertler, AIA
 - c. Email: maria.schertler@app-arch.com
- B. MEP Engineering Consultant
 - 1. Company Name: Nauman & Zelinski
 - a. Address: 204 S. Ludlow Street
 - b. City: Dayton
 - c. State: Ohio
 - d. Zip Code: 45402
 - e. Telephone: (937) 223-3821
 - 2. Primary Contact:
 - a. Title: Principal
 - b. Name: Jeff Zelinski
 - c. Email: jzelinski@nzengineering.com

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED



SECTION 00 0115 LIST OF DRAWING SHEETS

GENERAL

G0.1 COVER SHEET

G0.2 LIFE SAFETY PLAN & SITE PLAN

ARCHITECTURAL

A0.1	ABBREVIATIONS AND SYMBOLS
A0.2	ARCHITECTURAL SPECIFICATIONS
A0.3	SCHEDULES AND DETAILS
A1.1	DEMOLITION PLAN
A1.2	REFERENCE PLAN
A2.1	DEMOLITION REFLECTED CEILING PLAN
A2.2	REFLECTED CEILING PLAN
A7.1	INTERIOR ELEVATIONS
A8.1	CASEWORK DETAILS
A8.2	CASEWORK DETAILS

FIRE PROTECTION

LEGEND, SCHEDULES & FLOOR PLAN

MECHANICAL

H0.1	LEGENDS AND SCHEDULES
H1.1	DEMOLITION PLAN
H2.1	NEW WORK PLAN
H3.1	DETAILS
H4.1	CONTROLS

ELECTRICAL	
E0.1	LEGENDS AND SCHEDULES
E0.2	PANEL SCHEDULES
E1.1	DEMOLITION
E2.1	NEW LIGHTING PLAN
E3.1	NEW POWER PLAN
E4.1	NEW SYSTEMS PLAN



SEE ATTACHED DOCUMENT

DOCUMENT 00020 - NOTICE TO BIDDERS

The Darke County Commissioners will receive bids for the Darke County Wagner Avenue Interior Renovation project.

Bids will be received at the office of the Darke County Commissioners located at 520 South Broadway, Greenville, Ohio 45331, until 1:00 PM (local time) on April 10, 2025, then opened and read publicly that same day at 1:30 PM. Bids received after 1:00 PM on April 10, will be returned unopened.

Bids will be received on a lump sum basis as outlined in the bid documents.

The proposed work consists of the interior renovation of the offices for Darke County Job and Family Services. This is a two phased project with general trades, fire protection, mechanical and electrical work.

Bids must be signed and submitted on the separate bidding forms included in the Bidding Documents, sealed in the provided envelope, and shall be accompanied by either a Bid Guaranty Bond in the amount of 100% of the Bid amount or by a certified check, cashier's check, or letter of credit on a solvent bank in the amount of not less than 10% of the amount of the Bid, subject to conditions provided in the Instructions to Bidders. Bid security, furnished in Bond form, shall be issued by a Surety Company or Corporation licensed in the State of Ohio to provide said surety. The successful Bidder will be required to furnish a satisfactory Performance Bond in the amount of 100% of the Bid.

All contractors and sub-contractors involved with the project will, to the extent practicable, use Ohio products, materials, services, and labor in the implementation of their project. Additionally, contractor compliance with the equal employment opportunity requirements of Ohio Administrative Code Chapter 123, the Governor's Executive Order of 1972, and Governor's Executive Order 84-9 shall be required.

Attention of bidders is called to all of the requirements contained in this bid packet, particularly to the State of Ohio prevailing wage rates, various insurance requirements, and various equal employment opportunity provisions.

The Bidding Documents, which include Drawings, Specifications and blank forms, will be available to download from App Architecture's ShareFile site. Email your request to bids@app-arch.com and a link will be sent with downloading instructions. BIDS WILL ONLY BE ACCEPTED FROM BIDDERS LISTED ON THE ARCHITECT'S OFFICIAL LIST OF PLAN HOLDERS.

The Owner reserves the right to reject each and every bid and to waive informalities, irregularities and errors in the bidding to the extent permitted by law.

No bidder may withdraw his bid within 60 days after the actual date of the opening thereof.

PLEASE PUBLISH IN THE LEGAL SECTION ON WEDNESDAY, MARCH 26, 2025 & MARCH 30,2025, IN THE EARLY BIRD/DAILY ADVOCATE.

Send the bill to the Darke County Commissioner's Office, Customer ID 40018824 and please provide a tear sheet with the invoice.

Approved by:

Matthew W. Aultman Z

Marshall Combs _

Aaron Flatter

Advertise: 3/26/25 and 3/30/25

SECTION 00 2113 INSTRUCTIONS TO BIDDERS

RECEIPT AND OPENING OF BIDS

The Darke County Board of Commissioners, acting as the "Contracting Authority", (herein called the "Board"), invites bids on the forms attached hereto, all blanks of which must be appropriately filled in. Bids will be received by the Board at the Office of the Darke County Board of Commissioners until 1:00 PM on Thursday, April 10, 2025, and then at said office publicly opened and read aloud at 1:30 pm on the same day. The envelopes containing bids must be sealed and addressed to the Darke County Board of Commissioners, 520 S. Broadway, Greenville, Ohio, 45331, and designated as a bid for:

Wagner Avenue Interior Renovation 631 Wagner Ave. Greenville, OH 45331

The Board may consider informal any bid not prepared and submitted in accordance with the provisions hereof and may waive any informalities or reject any and all bids. Any bid may be withdrawn prior to the above scheduled time for the opening of bids or authorized postponement thereof. Any bid received after the time and date specified shall not be considered. No bidder may withdraw a bid within sixty (60) days after the actual date of the opening thereof.

CONTRACTOR QUESTIONS

All questions are to be submitted to Maria Schertler, App Architecture at <u>maria.schertler@app-arch.com</u>. Questions will be reviewed, and all necessary clarifications will be made by Addendum. The last day for written questions will be April 6, 2025, no later than 5:00 pm.

PREPARATION OF BIDS

All Bidders must complete the following forms and certifications in triplicate in their entirety.

Each bid must be submitted on the prescribed form and accompanied by Certification by Bidder regarding Equal Employment Opportunity, Form HUD—950.1, Certification by Bidder (Contractor) concerning Labor Standards and Prevailing Wage Requirements, Form HUD-1421, and Certification of Bidder regarding Section 3 and Segregated Facilities. All blank spaces for bid prices must be filled in, in ink or typewritten, in both words and figures, and the foregoing Certifications must be fully completed and executed when submitted.

The bid proposals must be submitted in a sealed envelope bearing on the outside the name of the bidder, his/her (hereinafter referred to as "his") address, and the name of the project for which the bid is submitted. If forwarded by mail, the sealed envelope containing the bid must be enclosed in another envelope, clearly marked as containing a sealed bid, and addressed as specified in the bid form.

The project is tax exempt.

Bidders must comply with prevailing wage rates for Building Construction Projects in Darke County as determined by the Ohio Department of Commerce, Bureau of Wage & Hour Administration.

METHODS OF BIDDING

The Board invites the following bid(s):

Wagner Avenue Interior Renovation, 631 Wagner Ave., Greenville, OH 45331

The Darke County Board of Commissioners will act as the Contracting Authority for this project. The Darke County Commissioners will administer the project. The Tenant for this project is the Darke County Department of Job & Family Services.

QUALIFICATION OF BIDDER

The Board may make such investigations as he/she (hereinafter referred to as "he") deems necessary to determine the ability of the bidder to perform the work and the bidder shall furnish to the Board all such information and data for this purpose as the Board may request. The Board reserves the right to reject any bid if the evidence submitted by, or investigation of such bidder fails to satisfy the Board that such bidder is properly qualified to carry out the obligations of the contract and to complete the work contemplated therein. Conditional bids will not be accepted.

BID SECURITY

Each bid must be accompanied by either a Bid Guaranty Bond in the amount of 100% of the Bid amount or by a certified check, cashier's check, or letter of credit on a solvent bank in the amount of not less than 10% of the amount of the Bid, subject to conditions provided in the Instructions to Bidders. Bid security, furnished in Bond form, shall be issued by a Surety Company or Corporation licensed in the State of Ohio to provide said surety. The successful Bidder will be required to furnish a satisfactory Performance Bond in the amount of 100% of the Bid.

TIME OF COMPLETION & LIQUIDATED DAMAGES

The Bidder must agree to commence work on or before a date to be specified in a written "Notice to Proceed" of the Board and the project is scheduled to be **completed by September 30, 2025.**

CONDITIONS OF THE WORK

A Pre Bid walkthrough will be conducted on April 1, 2025 @ 1:30 PM at the Department of Job & Family Services located at 631 Wagner Ave, Greenville, OH 45331. Bidders and interested subcontractors are encouraged to attend. Currently no additional walkthroughs are scheduled.

Each bidder must inform himself fully of the conditions relating to the construction of the project and the employment of labor thereon. Failure to do so will not relieve a successful bidder of his obligation to furnish all material and labor necessary to carry out the provisions of the contract. Insofar as possible the contractor in carrying out the work must employ such methods or means as will not cause any interruption of or interference with the work of any other contractor.

ADDENDA & INTERPRETATIONS

No interpretation of the meaning of the plans, specifications or other pre-bid documents will be made to any bidder orally.

Every Request for Information (RFI) should be submitted to Maria Schertler, App Architecture at maria.schertler@app-arch.com, and to be given consideration, must be received at least four (4) days prior to the date fixed for the opening of bids. Any and all such interpretations and any supplemental instructions will be in the form of written addenda to the specifications which, if issued, will be mailed,

faxed, or delivered to all prospective bidders (at the respective addresses furnished for such purpose), not later than three (3) days prior to the date fixed for the opening of bids. Failure of any bidder to receive any such addendum or interpretation shall not relieve such bidder from any obligation under his bid as submitted. All addenda so issued shall become part of the contract documents.

SECURITY FOR FAITHFUL PERFORMANCE

Simultaneously with his delivery of the executed contract, the Contractor shall furnish a surety bond or bonds as security for faithful performance of this contract and for the payment of all persons performing labor on the project under this contract and furnishing materials in connection with this contract, as specified in the General Conditions included herein. The surety on such bond or bonds shall be a duly authorized surety company satisfactory to the Board.

OBLIGATION OF BIDDER

At the time of the opening of bids each bidder will be presumed to have inspected the site and to have read and to be thoroughly familiar with the plans and contract documents (including all addenda). The failure or omission of any bidder to examine any form, instrument or document shall in no way relieve any bidder from any obligation in respect to his bid.

PERMITS

The General Contractor will be responsible for obtaining all applicable permits pertaining to this project.

OHIO WORKER'S COMPENSATION COVERAGE (§ 4123.01 of the O.R.C.)

The Contractor must secure and maintain valid Ohio workers' compensation coverage until the project has been finally accepted by the local contracting authority. A certificate of coverage evidencing valid workers' compensation coverage must be submitted to the local contracting authority before the contract is executed.

The Contractor must immediately notify the local contracting authority, in writing, if it or any subcontractor fails or refuses to renew their workers' compensation coverage. Furthermore, the Contractor must notify the local contracting authority, in writing, if its or any of its subcontractor's workers' compensation policies are canceled, terminated or lapse.

The failure to maintain valid workers' compensation coverage shall be considered a breach of contract which may result in the Contractor or subcontractor being removed from the project, withholding of pay estimates and/or termination of the contract.

DRUG-FREE WORKPLACE PROGRAM

In accordance with Ohio Revised Code §153.03 and during the life of this project, the Contractor and all its Subcontractors that provide labor on the Project site must be enrolled in and remain in good standing in the Ohio Bureau of Worker's Compensation ("OBWC") Drug-Free Workplace Program ("DFWP") or a comparable program approved by the OBWC.

Every bidder shall complete, sign and notarize the Drug-Free Workplace Program Affidavit hereinafter included in these specifications. Said Affidavit shall be included with the Bid Proposal.



BID FORM

THE PROJECT AND THE PARTIES
TO:
Contracting Authority / Owner:
Darke County Board of Commissioners 520 S. Broadway St. Greenville, Ohio 45331
FOR:
Project: Darke County - Wagner Avenue Interior Renovation
Project Address: 631 Wagner Avenue, Greenville, Ohio 45331
DATE: (Bidder to enter date)
SUBMITTED BY: (Bidder to enter name and address)
Bidder's Full Name
Address
and the Bid Documents prepared by App Architecture, Inc. for the above-mentioned project, we, the undersigned, hereby offer to enter into a Contract to perform the Work for the Sum of:
UNIT PRICES: ACOUSTICAL PANEL CEILINGS Cost shall include labor & material for Acoustical Panel Ceiling Work. Work is inclusive of demolition of existing ACP ceilings and installation of new ACP ceilings, products as specified.
CARPET TILE Cost shall include labor & material for Carpet Tile flooring Work. Work is inclusive of demolition of existing carpet flooring and installation of new Carpet Tile, products as specified.
We have included the required security Bid Bond as required by the Instruction to Bidders and as per ORC 153.54.
We have included the required performance assurance bonds in the Bid Amount as required by the Instructions to Bidders.

The cost of the required performance assurance bonds is _	dollars (\$), in
lawful money of the United States of America.		

All applicable federal taxes are excluded, and State of Ohio taxes are excluded from the Bid Sum.

We acknowledge the requirements for compliance with the Davis Bacon Act (40 United States Code (U.S.C) 3141 to 3148) and agree to comply with these requirements and all other applicable federal and state regulations.

ACCEPTANCE

CONTRACT TIME

This offer shall be open to acceptance and is irrevocable for sixty days from the bid closing date. If this bid is accepted by Owner within the time period stated above, we will:

- Execute the Agreement within seven days of receipt of Notice of Award.
- Furnish the required bonds within seven days of receipt of Notice of Award.
- Commence work within 30 days after written Notice to Proceed of this bid.

If this bid is accepted within the time stated, and we fail to commence the Work or we fail to provide the required Bond(s), the security deposit shall be forfeited as damages to Owner by reason of our failure, limited in amount to the lesser of the 10% security deposit or the difference between this bid and the bid upon which a Contract is signed

COMITME TIME	
If this Bid is accepted	, we will:
Complete the Work b	y
ADDENDA	
_	da have been received. The modifications to the Bid Documents noted below have all costs are included in the Bid Sum.
Addendum #	Dated
Addendum #	Dated
Addendum #	Dated

BID FORM SUPPLEMENTS

The following Supplements are attached to this Bid Form and are considered an integral part of this Bid Form:

Subcontractor List (Spec Section 00 4336)

Addendum # ______ Dated ______.

- Ohio Bureau of Workers' Compensation Certificate
- Ohio Department of Administrative Services Certificate of Compliance Certification Equal Opportunity Division
- State of Ohio Drug-Free Workplace Compliance Affidavit Form

It is understood and agreed by the undersigned that the Contracting Authority / Owner reserves the right to reject any and all bids, or award to the lowest and best bidder. The Contracting Authority / Owner reserves the right to waive irregularities and to reject any or all bids.

BID FORM SIGNATURE(S) Firm Name: By: Title:

Official Address:

DRUG-FREE WORKPLACE COMPLIANCE AFFIDAVIT FORM (O.R.C. - 153.03 - 153.031)

I,, the _	of
On behalf of said corporation/compan	y and in accordance with O,R.C 153.01 - 153.031, hereby
	is enrolled and in good standing with the
Ohio Bureau of Workers' Compensation	n Drug-Free Workplace Program, or in a comparable program,
called	, which has been approved by the
Bureau of Workers' Compensation.	
I further certify and acknowledge	e that understands
	orporated into and become a part of the contract between the
-	as contractor if the said
corporation/company is the successful	bidder on theProject.
contractually responsible to the public necessary to ensure that it's subcontrated in good standing with the Ohio Program, or with a comparable Bureau	nally certifies, agrees and acknowledged that it is hereby contracting authority for taking whatever measures are legally ctors, and any subsequent tier of contractors, are also enrolled a Bureau of Workers' Compensation Drug-Free workplace approved program, prior to provision of any labor on the Project by any subcontractor of any tier.
Further Affiant Sayeth Naught.	
	(signature of Affiant)
	(printed or typed name of Affiant)
Fo	r: (name of corporation/company/contractor)
Its	(title of Affiant)
STATE OF)	
COUNTY OF)	SS:
, on the da	me, a Notary Public in and for the State of y ofby s his/her voluntary act and deed.
(Affiant)	Simonia. I Siminary was also assess
	Notary Public

DOCUMENT 00 4336 - SUBCONTRACTOR LIST

Bidders shall list below the Major Subcontractors used in the completion of this bid. Where the Contractor will complete branches of work with his own forces, Contractor's name shall be listed. If a subcontractor is not planned for a particular area listed below, mark that space "N.A."

1.	General Construction Work:
	Subcontractor
2.	Fire Protection Work:
	Subcontractor
3.	Plumbing Work:
	Subcontractor
4.	Heating, Ventilating and Air Conditioning Work:
	Subcontractor
5.	Electrical Work:
	Subcontractor
6.	Flooring:
	Subcontractor
7.	Painting:
	Subcontractor

NOTE: If the Bidder can show just cause at the time of awarding the Contract that a specific Subcontractor has withdrawn his bid, or raised his bid, the Bidder may substitute a Subcontractor upon approval of the Owner and at no additional cost to Owner.

END OF DOCUMENT 00 4336



SECTION 00 5200 AGREEMENT FORM

PART 1 GENERAL

- 1.01 FORM OF AGREEMENT
- 1.02 THE AGREEMENT TO BE EXECUTED IS ATTACHED FOLLOWING THIS PAGE.
- 1.03 RELATED REQUIREMENTS
 - A. Section 00 7200 General Conditions.
 - B. Section 00 7300 Supplementary Conditions.

PART 2 PRODUCTS (NOT USED)

PART 3 EXECUTION (NOT USED)



Standard Form of Agreement Between Owner and Contractor where the basis of payment is a Stipulated Sum

AGREEMENT made as of the day of in the year (In words, indicate day, month and year.)

BETWEEN the Owner:

(Name, legal status, address and other information)

Sample

and the Contractor:

(Name, legal status, address and other information)

for the following Project: (Name, location and detailed description)

The Architect:

(Name, legal status, address and other information)

The Owner and Contractor agree as follows.

ADDITIONS AND DELETIONS:

The author of this document has added information needed for its completion. The author may also have revised the text of the original AIA standard form. An Additions and Deletions Report that notes added information as well as revisions to the standard form text is available from the author and should be reviewed. A vertical line in the left margin of this document indicates where the author has added necessary information and where the author has added to or deleted from the original AIA text.

This document has important legal consequences. Consultation with an attorney is encouraged with respect to its completion or modification.

The parties should complete A101™–2017, Exhibit A, Insurance and Bonds, contemporaneously with this Agreement. AIA Document A201™–2017, General Conditions of the Contract for Construction, is adopted in this document by reference. Do not use with other general conditions unless this document is modified.

User Notes:

TABLE OF ARTICLES

- 1 THE CONTRACT DOCUMENTS
- 2 THE WORK OF THIS CONTRACT
- 3 DATE OF COMMENCEMENT AND SUBSTANTIAL COMPLETION
- 4 CONTRACT SUM
- 5 PAYMENTS
- 6 DISPUTE RESOLUTION
- 7 TERMINATION OR SUSPENSION
- 8 MISCELLANEOUS PROVISIONS
- 9 ENUMERATION OF CONTRACT DOCUMENTS

EXHIBIT A INSURANCE AND BONDS

ARTICLE 1 THE CONTRACT DOCUMENTS

The Contract Documents consist of this Agreement, Conditions of the Contract (General, Supplementary, and other Conditions), Drawings, Specifications, Addenda issued prior to execution of this Agreement, other documents listed in this Agreement, and Modifications issued after execution of this Agreement, all of which form the Contract, and are as fully a part of the Contract as if attached to this Agreement or repeated herein. The Contract represents the entire and integrated agreement between the parties hereto and supersedes prior negotiations, representations, or agreements, either written or oral. An enumeration of the Contract Documents, other than a Modification, appears in Article 9.

ARTICLE 2 THE WORK OF THIS CONTRACT

The Contractor shall fully execute the Work described in the Contract Documents, except as specifically indicated in the Contract Documents to be the responsibility of others.

ARTICLE 3 DATE OF COMMENCEMENT AND SUBSTANTIAL COMPLETION

§ 3.1 The date of commencement of the Work shall be:

(Check one of the following boxes.)

]]	The date of this Agreement.
[]	A date set forth in a notice to proceed issued by the Owner.
]]	Established as follows: (Insert a date or a means to determine the date of commencement of the Work.)

If a date of commencement of the Work is not selected, then the date of commencement shall be the date of this Agreement.

§ 3.2 The Contract Time shall be measured from the date of commencement of the Work.

§ 3.3 Substantial Completion

§ 3.3.1 Subject to adjustments of the Contract Time as provided in the Contract Documents, the Contractor shall achieve Substantial Completion of the entire Work:

(Check one of the following boxes and complete the necessary information.)

User Notes:

(1212232538)

[] Not later than	() calendar days from the date of commencement of	of the Work.
[] By the following	ing date:	
	s of the Contract Time as provided in the Contract Docustantial Completion of the entire Work, the Contractor sby the following dates:	
Portion of Work	Substantial Completion Date	
§ 3.3.3 If the Contractor fails tany, shall be assessed as set f	to achieve Substantial Completion as provided in this S forth in Section 4.5.	section 3.3, liquidated damages, if
	e Contractor the Contract Sum in current funds for the shall be (\$), subject to additions and deductions as	
§ 4.2 Alternates § 4.2.1 Alternates, if any, incl	uded in the Contract Sum:	
Item	Price	
execution of this Agreement.	ons noted below, the following alternates may be accept Upon acceptance, the Owner shall issue a Modification and the conditions that must be met for the Owner to accept the Owner the Owner to accept the Owner the Owner to accept the Owner to accept the Owner the Ow	n to this Agreement.
Item	Price	Conditions for Acceptance
§ 4.3 Allowances, if any, includentify each allowance.)	uded in the Contract Sum:	
Item	Price	
§ 4.4 Unit prices, if any: (Identify the item and state th	ne unit price and quantity limitations, if any, to which th	he unit price will be applicable.)
Item	Units and Limitations	Price per Unit (\$0.00)
§ 4.5 Liquidated damages, if a (Insert terms and conditions)	any: for liquidated damages, if any.)	
§ 4.6 Other: (Insert provisions for homes of	or other incentives, if any, that might result in a change	e to the Contract Sum)

(1212232538)

ARTICLE 5 PAYMENTS

§ 5.1 Progress Payments

§ 5.1.1 Based upon Applications for Payment submitted to the Architect by the Contractor and Certificates for Payment issued by the Architect, the Owner shall make progress payments on account of the Contract Sum to the Contractor as provided below and elsewhere in the Contract Documents.

§ 5.1.2 The period covered by each Application for Payment shall be one calendar month ending on the last day of the month, or as follows:

§ 5.1.3 Provided that an Application for Payment is received by the Architect not later than the day of a month, the Owner shall make payment of the amount certified to the Contractor not later than the day of the month. If an Application for Payment is received by the Architect after the application date fixed above, payment of the amount certified shall be made by the Owner not later than () days after the Architect receives the Application for Payment.

(Federal, state or local laws may require payment within a certain period of time.)

- § 5.1.4 Each Application for Payment shall be based on the most recent schedule of values submitted by the Contractor in accordance with the Contract Documents. The schedule of values shall allocate the entire Contract Sum among the various portions of the Work. The schedule of values shall be prepared in such form, and supported by such data to substantiate its accuracy, as the Architect may require. This schedule of values shall be used as a basis for reviewing the Contractor's Applications for Payment.
- § 5.1.5 Applications for Payment shall show the percentage of completion of each portion of the Work as of the end of the period covered by the Application for Payment.
- § 5.1.6 In accordance with AIA Document A201TM—2017, General Conditions of the Contract for Construction, and subject to other provisions of the Contract Documents, the amount of each progress payment shall be computed as follows:
- § 5.1.6.1 The amount of each progress payment shall first include:
 - .1 That portion of the Contract Sum properly allocable to completed Work;
 - .2 That portion of the Contract Sum properly allocable to materials and equipment delivered and suitably stored at the site for subsequent incorporation in the completed construction, or, if approved in advance by the Owner, suitably stored off the site at a location agreed upon in writing; and
 - .3 That portion of Construction Change Directives that the Architect determines, in the Architect's professional judgment, to be reasonably justified.
- § 5.1.6.2 The amount of each progress payment shall then be reduced by:
 - .1 The aggregate of any amounts previously paid by the Owner;
 - .2 The amount, if any, for Work that remains uncorrected and for which the Architect has previously withheld a Certificate for Payment as provided in Article 9 of AIA Document A201–2017;
 - .3 Any amount for which the Contractor does not intend to pay a Subcontractor or material supplier, unless the Work has been performed by others the Contractor intends to pay;
 - .4 For Work performed or defects discovered since the last payment application, any amount for which the Architect may withhold payment, or nullify a Certificate of Payment in whole or in part, as provided in Article 9 of AIA Document A201–2017; and
 - **.5** Retainage withheld pursuant to Section 5.1.7.

§ 5.1.7 Retainage

User Notes:

§ 5.1.7.1 For each progress payment made prior to Substantial Completion of the Work, the Owner may withhold the following amount, as retainage, from the payment otherwise due:

(Insert a percentage or amount to be withheld as retainage from each Application for Payment. The amount of retainage may be limited by governing law.)

§ 5.1.7.1.1 The following items are not subject to retainage:

(Insert any items not subject to the withholding of retainage, such as general conditions, insurance, etc.)

§ 5.1.7.2 Reduction or limitation of retainage, if any, shall be as follows:

(If the retainage established in Section 5.1.7.1 is to be modified prior to Substantial Completion of the entire Work, including modifications for Substantial Completion of portions of the Work as provided in Section 3.3.2, insert provisions for such modifications.)

§ 5.1.7.3 Except as set forth in this Section 5.1.7.3, upon Substantial Completion of the Work, the Contractor may submit an Application for Payment that includes the retainage withheld from prior Applications for Payment pursuant to this Section 5.1.7. The Application for Payment submitted at Substantial Completion shall not include retainage as follows:

(Insert any other conditions for release of retainage upon Substantial Completion.)

§ 5.1.8 If final completion of the Work is materially delayed through no fault of the Contractor, the Owner shall pay the Contractor any additional amounts in accordance with Article 9 of AIA Document A201–2017.

§ 5.1.9 Except with the Owner's prior approval, the Contractor shall not make advance payments to suppliers for materials or equipment which have not been delivered and stored at the site.

§ 5.2 Final Payment

§ 5.2.1 Final payment, constituting the entire unpaid balance of the Contract Sum, shall be made by the Owner to the Contractor when

- .1 the Contractor has fully performed the Contract except for the Contractor's responsibility to correct Work as provided in Article 12 of AIA Document A201–2017, and to satisfy other requirements, if any, which extend beyond final payment; and
- .2 a final Certificate for Payment has been issued by the Architect.

§ 5.2.2 The Owner's final payment to the Contractor shall be made no later than 30 days after the issuance of the Architect's final Certificate for Payment, or as follows:

§ 5.3 Interest

Payments due and unpaid under the Contract shall bear interest from the date payment is due at the rate stated below, or in the absence thereof, at the legal rate prevailing from time to time at the place where the Project is located. (Insert rate of interest agreed upon, if any.)

%

ARTICLE 6 DISPUTE RESOLUTION

§ 6.1 Initial Decision Maker

The Architect will serve as the Initial Decision Maker pursuant to Article 15 of AIA Document A201–2017, unless the parties appoint below another individual, not a party to this Agreement, to serve as the Initial Decision Maker. (If the parties mutually agree, insert the name, address and other contact information of the Initial Decision Maker, if other than the Architect.)

§ 6.2 Binding Dispute Re	solution	ution
--------------------------	----------	-------

For any Claim subject to, but not resolved by, mediation pursuant to Article 15 of AIA Document A201-2017, the
method of binding dispute resolution shall be as follows:
(Check the appropriate box.)
1 1 Arbitration purguent to Section 15 A of AIA Document A 201 2017

[]	Arbitration pursuant to Section 15.4 of AIA Document A201–2017
[]	Litigation in a court of competent jurisdiction
[]	Other (Specify)

If the Owner and Contractor do not select a method of binding dispute resolution, or do not subsequently agree in writing to a binding dispute resolution method other than litigation, Claims will be resolved by litigation in a court of competent jurisdiction.

ARTICLE 7 TERMINATION OR SUSPENSION

§ 7.1 The Contract may be terminated by the Owner or the Contractor as provided in Article 14 of AIA Document A201–2017.

§ 7.1.1 If the Contract is terminated for the Owner's convenience in accordance with Article 14 of AIA Document A201–2017, then the Owner shall pay the Contractor a termination fee as follows:

(Insert the amount of or method for determining the fee, if any payable to the Contractor following a termination to

(Insert the amount of, or method for determining, the fee, if any, payable to the Contractor following a termination for the Owner's convenience.)

§ 7.2 The Work may be suspended by the Owner as provided in Article 14 of AIA Document A201–2017.

ARTICLE 8 MISCELLANEOUS PROVISIONS

§ 8.1 Where reference is made in this Agreement to a provision of AIA Document A201–2017 or another Contract Document, the reference refers to that provision as amended or supplemented by other provisions of the Contract Documents.

§ 8.2 The Owner's representative:

(Name, address, email address, and other information)

§ 8.3 The Contractor's representative:

(Name, address, email address, and other information)

(1212232538)

User Notes:

§ 8.4 Neither the Owner's nor the Contractor's representative shall be changed without ten days' prior notice to the other party.

§ 8.5 Insurance and Bonds

§ 8.5.1 The Owner and the Contractor shall purchase and maintain insurance as set forth in AIA Document A101TM-2017, Standard Form of Agreement Between Owner and Contractor where the basis of payment is a Stipulated Sum, Exhibit A, Insurance and Bonds, and elsewhere in the Contract Documents.

§ 8.5.2 The Contractor shall provide bonds as set forth in AIA Document A101TM—2017 Exhibit A, and elsewhere in the Contract Documents.

§ 8.6 Notice in electronic format, pursuant to Article 1 of AIA Document A201–2017, may be given in accordance with AIA Document E203TM_2013, Building Information Modeling and Digital Data Exhibit, if completed, or as otherwise set forth below:

(If other than in accordance with AIA Document E203–2013, insert requirements for delivering notice in electronic format such as name, title, and email address of the recipient and whether and how the system will be required to generate a read receipt for the transmission.)

§ 8.7 Other provisions:

ARTICLE 9 ENUMERATION OF CONTRACT DOCUMENTS

§ 9.1 This Agreement is comprised of the following documents:

- AIA Document A101TM–2017, Standard Form of Agreement Between Owner and Contractor
- .2 AIA Document A101TM–2017, Exhibit A, Insurance and Bonds
- .3 AIA Document A201TM–2017, General Conditions of the Contract for Construction
- AIA Document E203TM–2013, Building Information Modeling and Digital Data Exhibit, dated as indicated below:

(Insert the date of the E203-2013 incorporated into this Agreement.)

.5	Drawings			
	Number	Title	Date	
.6	Specifications			
	Section	Title	Date	Pages
.7	Addenda, if any:			
	Number	Date	Pages	

Portions of Addenda relating to bidding or proposal requirements are not part of the Contract Documents unless the bidding or proposal requirements are also enumerated in this Article 9.

.8 Other Exhibits: (Check all boxes that apply and include appropriate information identifying the exhibit where required.)

		ment E204 TM —2017, Sustainable Project date of the E204-2017 incorporated int		cated below:
	[] The Sustain	nability Plan:		
	Title	Date	Pages	
	[] Supplement	ntary and other Conditions of the Contra	act:	
	Document	Title	Date	Pages
.9 This Agree	Document A201 TM sample forms, the C requirements, and c proposals, are not p documents should b	tional documents that are intended to for contractor's bid or proposal, portions of other information furnished by the Owner of the Contract Documents unless end listed here only if intended to be part the day and year first written above.	r invitation to bid, Instra f Addenda relating to bi er in anticipation of reco cnumerated in this Agree	uctions to Bidders, idding or proposal eiving bids or ement. Any such
OWNER (S	Signature)	CONTRACTO	OR (Signature)	
(Printed n	ame and title)	(Printed nan	me and title)	

User Notes:

Insurance and Bonds

This Insurance and Bonds Exhibit is part of the Agreement, between the Owner and the Contractor, dated the day of in the year (In words, indicate day, month and year.)

for the following **PROJECT**:

(Name and location or address)

Sample

THE OWNER:

(Name, legal status and address)

THE CONTRACTOR:

(Name, legal status and address)

TABLE OF ARTICLES

- **A.1 GENERAL**
- A.2 **OWNER'S INSURANCE**
- **A.3 CONTRACTOR'S INSURANCE AND BONDS**
- SPECIAL TERMS AND CONDITIONS **A.4**

ARTICLE A.1 GENERAL

The Owner and Contractor shall purchase and maintain insurance, and provide bonds, as set forth in this Exhibit. As used in this Exhibit, the term General Conditions refers to AIA Document A201TM–2017, General Conditions of the Contract for Construction.

ARTICLE A.2 OWNER'S INSURANCE § A.2.1 General

Prior to commencement of the Work, the Owner shall secure the insurance, and provide evidence of the coverage, required under this Article A.2 and, upon the Contractor's request, provide a copy of the property insurance policy or policies required by Section A.2.3. The copy of the policy or policies provided shall contain all applicable conditions, definitions, exclusions, and endorsements.

§ A.2.2 Liability Insurance

The Owner shall be responsible for purchasing and maintaining the Owner's usual general liability insurance.

ADDITIONS AND DELETIONS:

The author of this document has added information needed for its completion. The author may also have revised the text of the original AIA standard form. An Additions and Deletions Report that notes added information as well as revisions to the standard form text is available from the author and should be reviewed. A vertical line in the left margin of this document indicates where the author has added necessary information and where the author has added to or deleted from the original AIA text.

This document has important legal consequences. Consultation with an attorney is encouraged with respect to its completion or modification.

This document is intended to be used in conjunction with AIA Document A201™-2017, General Conditions of the Contract for Construction. Article 11 of A201™-2017 contains additional insurance provisions.

§ A.2.3 Required Property Insurance

§ A.2.3.1 Unless this obligation is placed on the Contractor pursuant to Section A.3.3.2.1, the Owner shall purchase and maintain, from an insurance company or insurance companies lawfully authorized to issue insurance in the jurisdiction where the Project is located, property insurance written on a builder's risk "all-risks" completed value or equivalent policy form and sufficient to cover the total value of the entire Project on a replacement cost basis. The Owner's property insurance coverage shall be no less than the amount of the initial Contract Sum, plus the value of subsequent Modifications and labor performed and materials or equipment supplied by others. The property insurance shall be maintained until Substantial Completion and thereafter as provided in Section A.2.3.1.3, unless otherwise provided in the Contract Documents or otherwise agreed in writing by the parties to this Agreement. This insurance shall include the interests of the Owner, Contractor, Subcontractors, and Sub-subcontractors in the Project as insureds. This insurance shall include the interests of mortgagees as loss payees.

§ A.2.3.1.1 Causes of Loss. The insurance required by this Section A.2.3.1 shall provide coverage for direct physical loss or damage, and shall not exclude the risks of fire, explosion, theft, vandalism, malicious mischief, collapse, earthquake, flood, or windstorm. The insurance shall also provide coverage for ensuing loss or resulting damage from error, omission, or deficiency in construction methods, design, specifications, workmanship, or materials. Sub-limits, if any, are as follows:

(Indicate below the cause of loss and any applicable sub-limit.)

Causes of Loss

Sub-Limit

§ A.2.3.1.2 Specific Required Coverages. The insurance required by this Section A.2.3.1 shall provide coverage for loss or damage to falsework and other temporary structures, and to building systems from testing and startup. The insurance shall also cover debris removal, including demolition occasioned by enforcement of any applicable legal requirements, and reasonable compensation for the Architect's and Contractor's services and expenses required as a result of such insured loss, including claim preparation expenses. Sub-limits, if any, are as follows: (Indicate below type of coverage and any applicable sub-limit for specific required coverages.)

Coverage Sub-Limit

§ A.2.3.1.3 Unless the parties agree otherwise, upon Substantial Completion, the Owner shall continue the insurance required by Section A.2.3.1 or, if necessary, replace the insurance policy required under Section A.2.3.1 with property insurance written for the total value of the Project that shall remain in effect until expiration of the period for correction of the Work set forth in Section 12.2.2 of the General Conditions.

§ A.2.3.1.4 Deductibles and Self-Insured Retentions. If the insurance required by this Section A.2.3 is subject to deductibles or self-insured retentions, the Owner shall be responsible for all loss not covered because of such deductibles or retentions.

§ A.2.3.2 Occupancy or Use Prior to Substantial Completion. The Owner's occupancy or use of any completed or partially completed portion of the Work prior to Substantial Completion shall not commence until the insurance company or companies providing the insurance under Section A.2.3.1 have consented in writing to the continuance of coverage. The Owner and the Contractor shall take no action with respect to partial occupancy or use that would cause cancellation, lapse, or reduction of insurance, unless they agree otherwise in writing.

§ A.2.3.3 Insurance for Existing Structures

If the Work involves remodeling an existing structure or constructing an addition to an existing structure, the Owner shall purchase and maintain, until the expiration of the period for correction of Work as set forth in Section 12.2.2 of the General Conditions, "all-risks" property insurance, on a replacement cost basis, protecting the existing structure against direct physical loss or damage from the causes of loss identified in Section A.2.3.1, notwithstanding the undertaking of the Work. The Owner shall be responsible for all co-insurance penalties.

§ A.2.4 Optional Extended Property Insurance.

The Owner shall purchase and maintain the insurance selected and described below.

the description(s) of selected insurance. For each type of insurance selected, indicate applicable limits of coverage or other conditions in the fill point below the selected item.) § A.2.4.1 Loss of Use, Business Interruption, and Delay in Completion Insurance, to reimburse the Owner for loss of use of the Owner's property, or the inability to conduct normal operations due to a covered cause of loss. § A.2.4.2 Ordinance or Law Insurance, for the reasonable and necessary costs to satisfy the minimum [] requirements of the enforcement of any law or ordinance regulating the demolition, construction, repair, replacement or use of the Project. [] § A.2.4.3 Expediting Cost Insurance, for the reasonable and necessary costs for the temporary repair of damage to insured property, and to expedite the permanent repair or replacement of the damaged property. § A.2.4.4 Extra Expense Insurance, to provide reimbursement of the reasonable and necessary excess costs incurred during the period of restoration or repair of the damaged property that are over and above the total costs that would normally have been incurred during the same period of time had no loss or damage occurred. [] § A.2.4.5 Civil Authority Insurance, for losses or costs arising from an order of a civil authority prohibiting access to the Project, provided such order is the direct result of physical damage covered under the required property insurance. § A.2.4.6 Ingress/Egress Insurance, for loss due to the necessary interruption of the insured's business due to physical prevention of ingress to, or egress from, the Project as a direct result of physical damage. § A.2.4.7 Soft Costs Insurance, to reimburse the Owner for costs due to the delay of completion of the Work, arising out of physical loss or damage covered by the required property insurance: including construction loan fees; leasing and marketing expenses; additional fees, including those of architects, engineers, consultants, attorneys and accountants, needed for the completion of the construction, repairs, or reconstruction; and carrying costs such as property taxes, building permits, additional interest on loans, realty taxes, and insurance premiums over and above normal expenses. § A.2.5 Other Optional Insurance. The Owner shall purchase and maintain the insurance selected below. (Select the types of insurance the Owner is required to purchase and maintain by placing an X in the box(es) next to *the description(s) of selected insurance.)* § A.2.5.1 Cyber Security Insurance for loss to the Owner due to data security and privacy breach,

(Select the types of insurance the Owner is required to purchase and maintain by placing an X in the box(es) next to

including costs of investigating a potential or actual breach of confidential or private information. (Indicate applicable limits of coverage or other conditions in the fill point below.)

§ A.2.5.2 Other Insurance

(List below any other insurance coverage to be provided by the Owner and any applicable limits.)

Coverage	Limits

ARTICLE A.3 CONTRACTOR'S INSURANCE AND BONDS

§ A.3.1 General

§ A.3.1.1 Certificates of Insurance. The Contractor shall provide certificates of insurance acceptable to the Owner evidencing compliance with the requirements in this Article A.3 at the following times: (1) prior to commencement of the Work; (2) upon renewal or replacement of each required policy of insurance; and (3) upon the Owner's written request. An additional certificate evidencing continuation of commercial liability coverage, including coverage for completed operations, shall be submitted with the final Application for Payment and thereafter upon renewal or replacement of such coverage until the expiration of the periods required by Section A.3.2.1 and Section A.3.3.1. The certificates will show the Owner as an additional insured on the Contractor's Commercial General Liability and excess or umbrella liability policy or policies.

§ A.3.1.2 Deductibles and Self-Insured Retentions. The Contractor shall disclose to the Owner any deductible or selfinsured retentions applicable to any insurance required to be provided by the Contractor.

§ A.3.1.3 Additional Insured Obligations. To the fullest extent permitted by law, the Contractor shall cause the commercial general liability coverage to include (1) the Owner, the Architect, and the Architect's consultants as additional insureds for claims caused in whole or in part by the Contractor's negligent acts or omissions during the Contractor's operations; and (2) the Owner as an additional insured for claims caused in whole or in part by the Contractor's negligent acts or omissions for which loss occurs during completed operations. The additional insured coverage shall be primary and non-contributory to any of the Owner's general liability insurance policies and shall apply to both ongoing and completed operations. To the extent commercially available, the additional insured coverage shall be no less than that provided by Insurance Services Office, Inc. (ISO) forms CG 20 10 07 04, CG 20 37 07 04, and, with respect to the Architect and the Architect's consultants, CG 20 32 07 04.

§ A.3.2 Contractor's Required Insurance Coverage

§ A.3.2.1 The Contractor shall purchase and maintain the following types and limits of insurance from an insurance company or insurance companies lawfully authorized to issue insurance in the jurisdiction where the Project is located. The Contractor shall maintain the required insurance until the expiration of the period for correction of Work as set forth in Section 12.2.2 of the General Conditions, unless a different duration is stated below: (If the Contractor is required to maintain insurance for a duration other than the expiration of the period for correction of Work, state the duration.)

§ A.3.2.2 Commercial General Liability

§ A.3.2.2.1 Commercial General Liability insurance for the Project written on an occurrence form with policy limits of not less than (\$) each occurrence, (\$) general aggregate, and (\$) aggregate for products-completed operations hazard, providing coverage for claims including

- .1 damages because of bodily injury, sickness or disease, including occupational sickness or disease, and death of any person;
- .2 personal injury and advertising injury;
- damages because of physical damage to or destruction of tangible property, including the loss of use of
- bodily injury or property damage arising out of completed operations; and
- .5 the Contractor's indemnity obligations under Section 3.18 of the General Conditions.

- § A.3.2.2 The Contractor's Commercial General Liability policy under this Section A.3.2.2 shall not contain an exclusion or restriction of coverage for the following:
 - .1 Claims by one insured against another insured, if the exclusion or restriction is based solely on the fact that the claimant is an insured, and there would otherwise be coverage for the claim.
 - .2 Claims for property damage to the Contractor's Work arising out of the products-completed operations hazard where the damaged Work or the Work out of which the damage arises was performed by a Subcontractor.
 - .3 Claims for bodily injury other than to employees of the insured.
 - .4 Claims for indemnity under Section 3.18 of the General Conditions arising out of injury to employees of the insured.
 - .5 Claims or loss excluded under a prior work endorsement or other similar exclusionary language.
 - .6 Claims or loss due to physical damage under a prior injury endorsement or similar exclusionary language.
 - .7 Claims related to residential, multi-family, or other habitational projects, if the Work is to be performed on such a project.
 - .8 Claims related to roofing, if the Work involves roofing.
 - .9 Claims related to exterior insulation finish systems (EIFS), synthetic stucco or similar exterior coatings or surfaces, if the Work involves such coatings or surfaces.
 - .10 Claims related to earth subsidence or movement, where the Work involves such hazards.
 - .11 Claims related to explosion, collapse and underground hazards, where the Work involves such hazards.
- § A.3.2.3 Automobile Liability covering vehicles owned, and non-owned vehicles used, by the Contractor, with policy limits of not less than (\$) per accident, for bodily injury, death of any person, and property damage arising out of the ownership, maintenance and use of those motor vehicles along with any other statutorily required automobile coverage.
- § A.3.2.4 The Contractor may achieve the required limits and coverage for Commercial General Liability and Automobile Liability through a combination of primary and excess or umbrella liability insurance, provided such primary and excess or umbrella insurance policies result in the same or greater coverage as the coverages required under Section A.3.2.2 and A.3.2.3, and in no event shall any excess or umbrella liability insurance provide narrower coverage than the primary policy. The excess policy shall not require the exhaustion of the underlying limits only through the actual payment by the underlying insurers.
- § A.3.2.5 Workers' Compensation at statutory limits.
- § A.3.2.6 Employers' Liability with policy limits not less than (\$) each accident, (\$) each employee, and (\$) policy limit.
- **§ A.3.2.7** Jones Act, and the Longshore & Harbor Workers' Compensation Act, as required, if the Work involves hazards arising from work on or near navigable waterways, including vessels and docks
- § A.3.2.8 If the Contractor is required to furnish professional services as part of the Work, the Contractor shall procure Professional Liability insurance covering performance of the professional services, with policy limits of not less than (\$) per claim and (\$) in the aggregate.
- § A.3.2.9 If the Work involves the transport, dissemination, use, or release of pollutants, the Contractor shall procure Pollution Liability insurance, with policy limits of not less than (\$) per claim and (\$) in the aggregate.
- § A.3.2.10 Coverage under Sections A.3.2.8 and A.3.2.9 may be procured through a Combined Professional Liability and Pollution Liability insurance policy, with combined policy limits of not less than (\$) per claim and (\$) in the aggregate.
- § A.3.2.11 Insurance for maritime liability risks associated with the operation of a vessel, if the Work requires such activities, with policy limits of not less than (\$) per claim and (\$) in the aggregate.

§ A.3.2.12 Insurance for the use or operation of manned or unmanned aircraft, if the Work requires such activities, with policy limits of not less than (\$) per claim and (\$) in the aggregate.

§ A.3.3 Contractor's Other Insurance Coverage

§ A.3.3.1 Insurance selected and described in this Section A.3.3 shall be purchased from an insurance company or insurance companies lawfully authorized to issue insurance in the jurisdiction where the Project is located. The Contractor shall maintain the required insurance until the expiration of the period for correction of Work as set forth in Section 12.2.2 of the General Conditions, unless a different duration is stated below:

(If the Contractor is required to maintain any of the types of insurance selected below for a duration other than the expiration of the period for correction of Work, state the duration.)

§ A.3.3.2 The Contractor shall purchase and maintain the following types and limits of insurance in accordance with Section A.3.3.1.

(Select the types of insurance the Contractor is required to purchase and maintain by placing an X in the box(es) next to the description(s) of selected insurance. Where policy limits are provided, include the policy limit in the appropriate fill point.)

- § A.3.3.2.1 Property insurance of the same type and scope satisfying the requirements identified in [] Section A.2.3, which, if selected in this section A.3.3.2.1, relieves the Owner of the responsibility to purchase and maintain such insurance except insurance required by Section A.2.3.1.3 and Section A.2.3.3. The Contractor shall comply with all obligations of the Owner under Section A.2.3 except to the extent provided below. The Contractor shall disclose to the Owner the amount of any deductible, and the Owner shall be responsible for losses within the deductible. Upon request, the Contractor shall provide the Owner with a copy of the property insurance policy or policies required. The Owner shall adjust and settle the loss with the insurer and be the trustee of the proceeds of the property insurance in accordance with Article 11 of the General Conditions unless otherwise set forth below: (Where the Contractor's obligation to provide property insurance differs from the Owner's obligations as described under Section A.2.3, indicate such differences in the space below. Additionally, if a party other than the Owner will be responsible for adjusting and settling a loss with the insurer and acting as the trustee of the proceeds of property insurance in accordance with Article 11 of the General Conditions, indicate the responsible party below.)
- § A.3.3.2.2 Railroad Protective Liability Insurance, with policy limits of not less than (\$) per claim [] and (\$) in the aggregate, for Work within fifty (50) feet of railroad property.
- § A.3.3.2.3 Asbestos Abatement Liability Insurance, with policy limits of not less than (\$) per claim and (\$) in the aggregate, for liability arising from the encapsulation, removal, handling, storage, transportation, and disposal of asbestos-containing materials.
- [] § A.3.3.2.4 Insurance for physical damage to property while it is in storage and in transit to the construction site on an "all-risks" completed value form.
- § A.3.3.2.5 Property insurance on an "all-risks" completed value form, covering property owned by the [] Contractor and used on the Project, including scaffolding and other equipment.
- § A.3.3.2.6 Other Insurance [] (List below any other insurance coverage to be provided by the Contractor and any applicable limits.)

Coverage	Limits

§ A.3.4 Performance Bond and Payment Bond

The Contractor shall provide surety bonds, from a company or companies lawfully authorized to issue surety bonds in the jurisdiction where the Project is located, as follows:

(Specify type and penal sum of bonds.)

Type Penal Sum (\$0.00)

Payment Bond Performance Bond

Payment and Performance Bonds shall be AIA Document A312TM, Payment Bond and Performance Bond, or contain provisions identical to AIA Document A312TM, current as of the date of this Agreement.

ARTICLE A.4 SPECIAL TERMS AND CONDITIONS

Special terms and conditions that modify this Insurance and Bonds Exhibit, if any, are as follows:



SECTION 00 6000 PROJECT FORMS

FORMS INCLUDED HERE:

1.01 AIA A310-2010 PERFORMANCE BOND IS ATTACHED FOLLOWING THIS PAGE.
1.02 AIA A312-2010 PERFORMANCE BOND IS ATTACHED FOLLOWING THIS PAGE.
END OF SECTION



Bid Bond

CONTRACTOR:

(Name, legal status and address)

SURETY:

(Name, legal status and principal place of business)

OWNER:

(Name, legal status and address)

BOND AMOUNT: \$

PROJECT:

(Name, location or address, and Project number, if any)

The Contractor and Surety are bound to the Owner in the amount set forth above, for the payment of which the Contractor and Surety bind themselves, their heirs, executors, administrators, successors and assigns, jointly and severally, as provided herein. The conditions of this Bond are such that if the Owner accepts the bid of the Contractor within the time specified in the bid documents, or within such time period as may be agreed to by the Owner and Contractor, and the Contractor either (1) enters into a contract with the Owner in accordance with the terms of such bid, and gives such bond or bonds as may be specified in the bidding or Contract Documents, with a surety admitted in the jurisdiction of the Project and otherwise acceptable to the Owner, for the faithful performance of such Contract and for the prompt payment of labor and material furnished in the prosecution thereof; or (2) pays to the Owner the difference, not to exceed the amount of this Bond. between the amount specified in said bid and such larger amount for which the Owner may in good faith contract with another party to perform the work covered by said bid, then this obligation shall be null and void, otherwise to remain in full force and effect. The Surety hereby waives any notice of an agreement between the Owner and Contractor to extend the time in which the Owner may accept the bid. Waiver of notice by the Surety shall not apply to any extension exceeding sixty (60) days in the aggregate beyond the time for acceptance of bids specified in the bid documents, and the Owner and Contractor shall obtain the Surety's consent for an extension beyond sixty (60) days.

If this Bond is issued in connection with a subcontractor's bid to a Contractor, the term Contractor in this Bond shall be deemed to be Subcontractor and the term Owner shall be deemed to be Contractor.

When this Bond has been furnished to comply with a statutory or other legal requirement in the location of the Project, any provision in this Bond conflicting with said statutory or legal requirement shall be deemed deleted herefrom and provisions conforming to such statutory or other legal requirement shall be deemed incorporated herein. When so furnished, the intent is that this Bond shall be construed as a statutory bond and not as a common law bond.

ADDITIONS AND DELETIONS:

The author of this document has added information needed for its completion. The author may also have revised the text of the original AIA standard form. An Additions and Deletions Report that notes added information as well as revisions to the standard form text is available from the author and should be reviewed. A vertical line in the left margin of this document indicates where the author has added necessary information and where the author has added to or deleted from the original AIA text.

This document has important legal consequences. Consultation with an attorney is encouraged with respect to its completion or modification.

Any singular reference to Contractor, Surety, Owner or other party shall be considered plural where applicable.

| (Contractor as Principal) (Seal) | (Witness) | (Title) | (Surety) (Seal) | (Title) |

Performance Bond

CONTRACTOR: (Name, legal status and address)	SURETY: (Name, legal status and principal place of business)		
	of business)		
OWNER: (Name, legal status and address)			
CONSTRUCTION CONTRACT Date:			
Amount: \$			
Description:			
(Name and location)			
BOND Date:			
(Not earlier than Construction Con	tract Date)		
Amount: \$			
Modifications to this Bond:	None See Section 16		
CONTRACTOR AS PRINCIPAL	SURETY		
Company: (Corporate Seal)	Company: (Corporate Seal)		
Signature:	Signature:		
Name and	Name and		
Title:	Title:		
(Any additional signatures appear on the last page of this Performance Bond.)			
(FOR INFORMATION ONLY — Name, address and telephone)			
AGENT or BROKER:	OWNER'S REPRESENTATIVE:		
	(Architect, Engineer or other party:)		

ADDITIONS AND DELETIONS:

The author of this document has added information needed for its completion. The author may also have revised the text of the original AIA standard form. An *Additions and Deletions Report* that notes added information as well as revisions to the standard form text is available from the author and should be reviewed. A vertical line in the left margin of this document indicates where the author has added necessary information and where the author has added to or deleted from the original AIA text.

This document has important legal consequences. Consultation with an attorney is encouraged with respect to its completion or modification.

Any singular reference to Contractor, Surety, Owner or other party shall be considered plural where applicable.

- § 1 The Contractor and Surety, jointly and severally, bind themselves, their heirs, executors, administrators, successors and assigns to the Owner for the performance of the Construction Contract, which is incorporated herein by reference.
- § 2 If the Contractor performs the Construction Contract, the Surety and the Contractor shall have no obligation under this Bond, except when applicable to participate in a conference as provided in Section 3.
- § 3 If there is no Owner Default under the Construction Contract, the Surety's obligation under this Bond shall arise after
 - the Owner first provides notice to the Contractor and the Surety that the Owner is considering declaring a Contractor Default. Such notice shall indicate whether the Owner is requesting a conference among the Owner, Contractor and Surety to discuss the Contractor's performance. If the Owner does not request a conference, the Surety may, within five (5) business days after receipt of the Owner's notice, request such a conference. If the Surety timely requests a conference, the Owner shall attend. Unless the Owner agrees otherwise, any conference requested under this Section 3.1 shall be held within ten (10) business days of the Surety's receipt of the Owner's notice. If the Owner, the Contractor and the Surety agree, the Contractor shall be allowed a reasonable time to perform the Construction Contract, but such an agreement shall not waive the Owner's right, if any, subsequently to declare a Contractor
 - .2 the Owner declares a Contractor Default, terminates the Construction Contract and notifies the Surety;
 - .3 the Owner has agreed to pay the Balance of the Contract Price in accordance with the terms of the Construction Contract to the Surety or to a contractor selected to perform the Construction Contract.
- § 4 Failure on the part of the Owner to comply with the notice requirement in Section 3.1 shall not constitute a failure to comply with a condition precedent to the Surety's obligations, or release the Surety from its obligations, except to the extent the Surety demonstrates actual prejudice.
- § 5 When the Owner has satisfied the conditions of Section 3, the Surety shall promptly and at the Surety's expense take one of the following actions:
- § 5.1 Arrange for the Contractor, with the consent of the Owner, to perform and complete the Construction Contract;
- § 5.2 Undertake to perform and complete the Construction Contract itself, through its agents or independent contractors:
- § 5.3 Obtain bids or negotiated proposals from qualified contractors acceptable to the Owner for a contract for performance and completion of the Construction Contract, arrange for a contract to be prepared for execution by the Owner and a contractor selected with the Owner's concurrence, to be secured with performance and payment bonds executed by a qualified surety equivalent to the bonds issued on the Construction Contract, and pay to the Owner the amount of damages as described in Section 7 in excess of the Balance of the Contract Price incurred by the Owner as a result of the Contractor Default; or
- § 5.4 Waive its right to perform and complete, arrange for completion, or obtain a new contractor and with reasonable promptness under the circumstances:
 - After investigation, determine the amount for which it may be liable to the Owner and, as soon as practicable after the amount is determined, make payment to the Owner; or
 - .2 Deny liability in whole or in part and notify the Owner, citing the reasons for denial.
- § 6 If the Surety does not proceed as provided in Section 5 with reasonable promptness, the Surety shall be deemed to be in default on this Bond seven days after receipt of an additional written notice from the Owner to the Surety demanding that the Surety perform its obligations under this Bond, and the Owner shall be entitled to enforce any remedy available to the Owner. If the Surety proceeds as provided in Section 5.4, and the Owner refuses the payment or the Surety has denied liability, in whole or in part, without further notice the Owner shall be entitled to enforce any remedy available to the Owner.

- § 7 If the Surety elects to act under Section 5.1, 5.2 or 5.3, then the responsibilities of the Surety to the Owner shall not be greater than those of the Contractor under the Construction Contract, and the responsibilities of the Owner to the Surety shall not be greater than those of the Owner under the Construction Contract. Subject to the commitment by the Owner to pay the Balance of the Contract Price, the Surety is obligated, without duplication, for
 - .1 the responsibilities of the Contractor for correction of defective work and completion of the Construction Contract;
 - .2 additional legal, design professional and delay costs resulting from the Contractor's Default, and resulting from the actions or failure to act of the Surety under Section 5; and
 - .3 liquidated damages, or if no liquidated damages are specified in the Construction Contract, actual damages caused by delayed performance or non-performance of the Contractor.
- § 8 If the Surety elects to act under Section 5.1, 5.3 or 5.4, the Surety's liability is limited to the amount of this Bond.
- § 9 The Surety shall not be liable to the Owner or others for obligations of the Contractor that are unrelated to the Construction Contract, and the Balance of the Contract Price shall not be reduced or set off on account of any such unrelated obligations. No right of action shall accrue on this Bond to any person or entity other than the Owner or its heirs, executors, administrators, successors and assigns.
- § 10 The Surety hereby waives notice of any change, including changes of time, to the Construction Contract or to related subcontracts, purchase orders and other obligations.
- § 11 Any proceeding, legal or equitable, under this Bond may be instituted in any court of competent jurisdiction in the location in which the work or part of the work is located and shall be instituted within two years after a declaration of Contractor Default or within two years after the Contractor ceased working or within two years after the Surety refuses or fails to perform its obligations under this Bond, whichever occurs first. If the provisions of this Paragraph are void or prohibited by law, the minimum period of limitation available to sureties as a defense in the jurisdiction of the suit shall be applicable.
- § 12 Notice to the Surety, the Owner or the Contractor shall be mailed or delivered to the address shown on the page on which their signature appears.
- § 13 When this Bond has been furnished to comply with a statutory or other legal requirement in the location where the construction was to be performed, any provision in this Bond conflicting with said statutory or legal requirement shall be deemed deleted herefrom and provisions conforming to such statutory or other legal requirement shall be deemed incorporated herein. When so furnished, the intent is that this Bond shall be construed as a statutory bond and not as a common law bond.

§ 14 Definitions

- § 14.1 Balance of the Contract Price. The total amount payable by the Owner to the Contractor under the Construction Contract after all proper adjustments have been made, including allowance to the Contractor of any amounts received or to be received by the Owner in settlement of insurance or other claims for damages to which the Contractor is entitled, reduced by all valid and proper payments made to or on behalf of the Contractor under the Construction Contract.
- § 14.2 Construction Contract. The agreement between the Owner and Contractor identified on the cover page, including all Contract Documents and changes made to the agreement and the Contract Documents.
- § 14.3 Contractor Default. Failure of the Contractor, which has not been remedied or waived, to perform or otherwise to comply with a material term of the Construction Contract.
- § 14.4 Owner Default. Failure of the Owner, which has not been remedied or waived, to pay the Contractor as required under the Construction Contract or to perform and complete or comply with the other material terms of the Construction Contract.
- § 14.5 Contract Documents. All the documents that comprise the agreement between the Owner and Contractor.

§ 15 If this Bond is issued for an agreement between a Contractor and subcontractor, the term Contractor in this Bond shall be deemed to be Subcontractor and the term Owner shall be deemed to be Contractor.

§ 16 Modifications to this bond are as follows:

(Space is provided below for add CONTRACTOR AS PRINCIPAL	litional signatures of ad	lded parties, other than those appearing on the cover page. SURETY		
Company:	(Corporate Seal)	Company:	(Corporate Seal)	
Signature:		Signature:		
Name and Title: Address:		Name and Title: Address:		

SECTION 00 7200 GENERAL CONDITIONS

FORM OF GENERAL CONDITIONS

1.01 THE GENERAL CONDITIONS APPLICABLE TO THIS CONTRACT IS ATTACHED FOLLOWING THIS PAGE.

RELATED REQUIREMENTS

2.01 SECTION 00 7300 - SUPPLEMENTARY CONDITIONS.

END OF SECTION



General Conditions of the Contract for Construction

for the following PROJECT:

(Name and location or address)

Darke County Wagner Avenue Interior Renovation 631 Wagner Avenue Greenville, Ohio 45331

THE OWNER:

(Name, legal status and address)

Darke County Board of Commissioners 520 S. Broadway Street Greenville, Ohio 45331

THE ARCHITECT:

(Name, legal status and address)

App Architecture, Inc. 615 Woodside Drive Englewood, Ohio 45322

TABLE OF ARTICLES

- **GENERAL PROVISIONS**
- OWNER
- 3 CONTRACTOR
- ARCHITECT
- **SUBCONTRACTORS** 5
- 6 CONSTRUCTION BY OWNER OR BY SEPARATE CONTRACTORS
- 7 **CHANGES IN THE WORK**
- 8 TIME
- 9 PAYMENTS AND COMPLETION
- 10 PROTECTION OF PERSONS AND PROPERTY
- 11 **INSURANCE AND BONDS**
- **UNCOVERING AND CORRECTION OF WORK** 12

MISCELLANEOUS PROVISIONS

ADDITIONS AND DELETIONS:

The author of this document may have revised the text of the original AIA standard form. An Additions and Deletions Report that notes revisions to the standard form text is available from the author and should be reviewed. A vertical line in the left margin of this document indicates where the author has added to or deleted from the original AIA text.

This document has important legal consequences. Consultation with an attorney is encouraged with respect to its completion or modification.

For guidance in modifying this document to include supplementary conditions, see AIA Document A503™-2017, Guide for Supplementary Conditions.

- 14 **TERMINATION OR SUSPENSION OF THE CONTRACT**
- 15 **CLAIMS AND DISPUTES**

INDEX Architect's Authority to Reject Work (Topics and numbers in bold are Section headings.) 3.5, 4.2.6, 12.1.2, 12.2.1 Architect's Copyright 1.1.7, 1.5 Acceptance of Nonconforming Work Architect's Decisions 9.6.6, 9.9.3, 12.3 3.7.4, 4.2.6, 4.2.7, 4.2.11, 4.2.12, 4.2.13, 4.2.14, 6.3, 7.3.4, 7.3.9, 8.1.3, 8.3.1, 9.2, 9.4.1, 9.5, 9.8.4, 9.9.1, Acceptance of Work 9.6.6, 9.8.2, 9.9.3, 9.10.1, 9.10.3, 12.3 13.4.2, 15.2 Access to Work Architect's Inspections 3.7.4, 4.2.2, 4.2.9, 9.4.2, 9.8.3, 9.9.2, 9.10.1, 13.4 **3.16**, 6.2.1, 12.1 **Accident Prevention** Architect's Instructions 3.2.4, 3.3.1, 4.2.6, 4.2.7, 13.4.2 Acts and Omissions Architect's Interpretations 3.2, 3.3.2, 3.12.8, 3.18, 4.2.3, 8.3.1, 9.5.1, 10.2.5, 4.2.11, 4.2.12 10.2.8, 13.3.2, 14.1, 15.1.2, 15.2 Architect's Project Representative Addenda 4.2.10 1.1.1 Architect's Relationship with Contractor Additional Costs, Claims for 1.1.2, 1.5, 2.3.3, 3.1.3, 3.2.2, 3.2.3, 3.2.4, 3.3.1, 3.4.2, 3.7.4, 3.7.5, 10.3.2, 15.1.5 3.5, 3.7.4, 3.7.5, 3.9.2, 3.9.3, 3.10, 3.11, 3.12, 3.16, **Additional Inspections and Testing** 3.18, 4.1.2, 4.2, 5.2, 6.2.2, 7, 8.3.1, 9.2, 9.3, 9.4, 9.5, 9.4.2, 9.8.3, 12.2.1, **13.4** 9.7, 9.8, 9.9, 10.2.6, 10.3, 11.3, 12, 13.3.2, 13.4, 15.2 Additional Time, Claims for Architect's Relationship with Subcontractors 3.2.4, 3.7.4, 3.7.5, 3.10.2, 8.3.2, 15.1.6 1.1.2, 4.2.3, 4.2.4, 4.2.6, 9.6.3, 9.6.4, 11.3 **Administration of the Contract** Architect's Representations 3.1.3, **4.2**, 9.4, 9.5 9.4.2, 9.5.1, 9.10.1 Advertisement or Invitation to Bid Architect's Site Visits 1.1.1 3.7.4, 4.2.2, 4.2.9, 9.4.2, 9.5.1, 9.9.2, 9.10.1, 13.4 Aesthetic Effect 4.2.13 10.3.1 **Allowances** Attorneys' Fees 3.18.1, 9.6.8, 9.10.2, 10.3.3 **Applications for Payment** Award of Separate Contracts 4.2.5, 7.3.9, 9.2, **9.3**, 9.4, 9.5.1, 9.5.4, 9.6.3, 9.7, 9.10 6.1.1, 6.1.2 Award of Subcontracts and Other Contracts for 2.1.1, 2.3.1, 2.5, 3.1.3, 3.10.2, 3.12.8, 3.12.9, **Portions of the Work** 3.12.10.1, 4.2.7, 9.3.2, 13.4.1 5.2 **Basic Definitions** Arbitration 8.3.1, 15.3.2, **15.4** 1.1 ARCHITECT Bidding Requirements 1.1.1 Architect, Definition of Binding Dispute Resolution 4.1.1 8.3.1, 9.7, 11.5, 13.1, 15.1.2, 15.1.3, 15.2.1, 15.2.5, Architect, Extent of Authority 15.2.6.1, 15.3.1, 15.3.2, 15.3.3, 15.4.1 2.5, 3.12.7, 4.1.2, 4.2, 5.2, 6.3, 7.1.2, 7.3.4, 7.4, 9.2, Bonds, Lien 9.3.1, 9.4, 9.5, 9.6.3, 9.8, 9.10.1, 9.10.3, 12.1, 12.2.1, 7.3.4.4, 9.6.8, 9.10.2, 9.10.3 13.4.1, 13.4.2, 14.2.2, 14.2.4, 15.1.4, 15.2.1 Bonds, Performance, and Payment Architect, Limitations of Authority and Responsibility 7.3.4.4, 9.6.7, 9.10.3, **11.1.2**, 11.1.3, **11.5** 2.1.1, 3.12.4, 3.12.8, 3.12.10, 4.1.2, 4.2.1, 4.2.2, 4.2.3, **Building Information Models Use and Reliance** 4.2.6, 4.2.7, 4.2.10, 4.2.12, 4.2.13, 5.2.1, 7.4, 9.4.2, 1.8 **Building Permit** 9.5.4, 9.6.4, 15.1.4, 15.2 Architect's Additional Services and Expenses 3.7.1 2.5, 12.2.1, 13.4.2, 13.4.3, 14.2.4 Capitalization Architect's Administration of the Contract 3.1.3, 3.7.4, 15.2, 9.4.1, 9.5 Certificate of Substantial Completion Architect's Approvals 9.8.3, 9.8.4, 9.8.5

Init.

2.5, 3.1.3, 3.5, 3.10.2, 4.2.7

User Notes:

Certificates for Payment

4.2.1, 4.2.5, 4.2.9, 9.3.3, **9.4**, 9.5, 9.6.1, 9.6.6, 9.7, 9.10.1, 9.10.3, 14.1.1.3, 14.2.4, 15.1.4

Certificates of Inspection, Testing or Approval 13.4.4

Certificates of Insurance 9.10.2

Change Orders

1.1.1, 3.4.2, 3.7.4, 3.8.2.3, 3.11, 3.12.8, 4.2.8, 5.2.3, 7.1.2, 7.1.3, **7.2**, 7.3.2, 7.3.7, 7.3.9, 7.3.10, 8.3.1, 9.3.1.1, 9.10.3, 10.3.2, 11.2, 11.5, 12.1.2

Change Orders, Definition of

7.2.1

CHANGES IN THE WORK

2.2.2, 3.11, 4.2.8, **7**, 7.2.1, 7.3.1, 7.4, 8.3.1, 9.3.1.1, 11.5

Claims, Definition of

15.1.1

Claims, Notice of

1.6.2, 15.1.3

CLAIMS AND DISPUTES

3.2.4, 6.1.1, 6.3, 7.3.9, 9.3.3, 9.10.4, 10.3.3, **15**, 15.4 Claims and Timely Assertion of Claims

Claims for Additional Cost

3.2.4, 3.3.1, 3.7.4, 7.3.9, 9.5.2, 10.2.5, 10.3.2, **15.1.5**

Claims for Additional Time

3.2.4, 3.3.1, 3.7.4, 6.1.1, 8.3.2, 9.5.2, 10.3.2, **15.1.6**

Concealed or Unknown Conditions, Claims for 3.7.4

Claims for Damages

3.2.4, 3.18, 8.3.3, 9.5.1, 9.6.7, 10.2.5, 10.3.3, 11.3, 11.3.2, 14.2.4, 15.1.7

Claims Subject to Arbitration

15.4.1

Cleaning Up

3.15, 6.3

Commencement of the Work, Conditions Relating to 2.2.1, 3.2.2, 3.4.1, 3.7.1, 3.10.1, 3.12.6, 5.2.1, 5.2.3, 6.2.2, 8.1.2, 8.2.2, 8.3.1, 11.1, 11.2, **15.1.5**

Commencement of the Work, Definition of 8.1.2

Communications

3.9.1, 4.2.4

User Notes:

Completion, Conditions Relating to

3.4.1, 3.11, 3.15, 4.2.2, 4.2.9, 8.2, 9.4.2, 9.8, 9.9.1,

9.10, 12.2, 14.1.2, 15.1.2

COMPLETION, PAYMENTS AND

9

Completion, Substantial

3.10.1, 4.2.9, 8.1.1, 8.1.3, 8.2.3, 9.4.2, 9.8, 9.9.1, 9.10.3, 12.2, 15.1.2

Compliance with Laws

2.3.2, 3.2.3, 3.6, 3.7, 3.12.10, 3.13, 9.6.4, 10.2.2, 13.1, 13.3, 13.4.1, 13.4.2, 13.5, 14.1.1, 14.2.1.3, 15.2.8, 15.4.2, 15.4.3

Concealed or Unknown Conditions

3.7.4, 4.2.8, 8.3.1, 10.3

Conditions of the Contract

1.1.1, 6.1.1, 6.1.4

Consent, Written

3.4.2, 3.14.2, 4.1.2, 9.8.5, 9.9.1, 9.10.2, 9.10.3, 13.2,

Consolidation or Joinder

15.4.4

CONSTRUCTION BY OWNER OR BY SEPARATE CONTRACTORS

1.1.4.6

Construction Change Directive, Definition of 7.3.1

Construction Change Directives

1.1.1, 3.4.2, 3.11, 3.12.8, 4.2.8, 7.1.1, 7.1.2, 7.1.3, **7.3**, 9.3.1.1

Construction Schedules, Contractor's 3.10, 3.11, 3.12.1, 3.12.2, 6.1.3, 15.1.6.2

Contingent Assignment of Subcontracts

5.4, 14.2.2.2

Continuing Contract Performance

15.1.4

Contract, Definition of

1.1.2

CONTRACT, TERMINATION OR SUSPENSION OF THE

5.4.1.1, 5.4.2, 11.5, 14

Contract Administration

3.1.3, 4, 9.4, 9.5

Contract Award and Execution, Conditions Relating

3.7.1, 3.10, 5.2, 6.1

Contract Documents, Copies Furnished and Use of 1.5.2, 2.3.6, 5.3

Contract Documents, Definition of

1.1.1

Contract Sum

2.2.2, 2.2.4, 3.7.4, 3.7.5, 3.8, 3.10.2, 5.2.3, 7.3, 7.4, **9.1**, 9.2, 9.4.2, 9.5.1.4, 9.6.7, 9.7, 10.3.2, 11.5, 12.1.2, 12.3, 14.2.4, 14.3.2, 15.1.4.2, **15.1.5, 15.2.5**

Contract Sum, Definition of

9.1

Contract Time

1.1.4, 2.2.1, 2.2.2, 3.7.4, 3.7.5, 3.10.2, 5.2.3, 6.1.5, 7.2.1.3, 7.3.1, 7.3.5, 7.3.6, 7, 7, 7.3.10, 7.4, 8.1.1, 8.2.1, 8.2.3, 8.3.1, 9.5.1, 9.7, 10.3.2, 12.1.1, 12.1.2, 14.3.2, 15.1.4.2, 15.1.6.1, 15.2.5

Contract Time. Definition of

8.1.1

CONTRACTOR

3

Contractor, Definition of

3.1, 6.1.2

Contractor's Construction and Submittal Schedules

3.10, 3.12.1, 3.12.2, 4.2.3, 6.1.3, 15.1.6.2

Init.

AIA Document A201® – 2017. Copyright © 1911, 1915, 1918, 1925, 1937, 1951, 1958, 1961, 1963, 1966, 1970, 1976, 1987, 1997, 2007 and 2017 by The American Institute of Architects. All rights reserved. The "American Institute of Architects," "AIA," the AIA Logo, "A201," and "AIA Contract Documents" are registered trademarks and may not be used without permission. This document was produced by AIA software at 10:57:44 ET on 01/24/2023 under Order No.2114341894 which expires on 07/20/2023, is not for resale, is licensed for one-time use only, and may only be used in accordance with the AIA Contract Documents® Terms of Service. To report copyright violations, e-mail copyright@aia.org.

3

Contractor's Employees Damage to Construction of Owner or Separate 2.2.4, 3.3.2, 3.4.3, 3.8.1, 3.9, 3.18.2, 4.2.3, 4.2.6, 10.2, Contractors 10.3, 11.3, 14.1, 14.2.1.1 3.14.2, 6.2.4, 10.2.1.2, 10.2.5, 10.4, 12.2.4 **Contractor's Liability Insurance** Damage to the Work 3.14.2, 9.9.1, 10.2.1.2, 10.2.5, 10.4, 12.2.4 11.1 Contractor's Relationship with Separate Contractors Damages, Claims for 3.2.4, 3.18, 6.1.1, 8.3.3, 9.5.1, 9.6.7, 10.3.3, 11.3.2, and Owner's Forces 3.12.5, 3.14.2, 4.2.4, 6, 11.3, 12.2.4 11.3, 14.2.4, 15.1.7 Contractor's Relationship with Subcontractors Damages for Delay 1.2.2, 2.2.4, 3.3.2, 3.18.1, 3.18.2, 4.2.4, 5, 9.6.2, 9.6.7, 6.2.3, 8.3.3, 9.5.1.6, 9.7, 10.3.2, 14.3.2 9.10.2, 11.2, 11.3, 11.4 Date of Commencement of the Work, Definition of Contractor's Relationship with the Architect 1.1.2, 1.5, 2.3.3, 3.1.3, 3.2.2, 3.2.3, 3.2.4, 3.3.1, 3.4.2, Date of Substantial Completion, Definition of 3.5.1, 3.7.4, 3.10, 3.11, 3.12, 3.16, 3.18, 4.2, 5.2, 6.2.2, 8.1.3 Day, Definition of 7, 8.3.1, 9.2, 9.3, 9.4, 9.5, 9.7, 9.8, 9.9, 10.2.6, 10.3, 11.3, 12, 13.4, 15.1.3, 15.2.1 8.1.4 Contractor's Representations Decisions of the Architect 3.7.4, 4.2.6, 4.2.7, 4.2.11, 4.2.12, 4.2.13, 6.3, 7.3.4,3.2.1, 3.2.2, 3.5, 3.12.6, 6.2.2, 8.2.1, 9.3.3, 9.8.2 Contractor's Responsibility for Those Performing the 7.3.9, 8.1.3, 8.3.1, 9.2, 9.4, 9.5.1, 9.8.4, 9.9.1, 13.4.2, Work 14.2.2, 14.2.4, 15.1, 15.2 3.3.2, 3.18, 5.3, 6.1.3, 6.2, 9.5.1, 10.2.8 **Decisions to Withhold Certification** Contractor's Review of Contract Documents 9.4.1, **9.5**, 9.7, 14.1.1.3 Defective or Nonconforming Work, Acceptance, Contractor's Right to Stop the Work Rejection and Correction of 2.2.2, 9.7 2.5, 3.5, 4.2.6, 6.2.3, 9.5.1, 9.5.3, 9.6.6, 9.8.2, 9.9.3, Contractor's Right to Terminate the Contract 9.10.4, 12.2.1 14.1 **Definitions** Contractor's Submittals 1.1, 2.1.1, 3.1.1, 3.5, 3.12.1, 3.12.2, 3.12.3, 4.1.1, 5.1, 3.10, 3.11, 3.12, 4.2.7, 5.2.1, 5.2.3, 9.2, 9.3, 9.8.2, 6.1.2, 7.2.1, 7.3.1, 8.1, 9.1, 9.8.1, 15.1.1 9.8.3, 9.9.1, 9.10.2, 9.10.3 **Delays and Extensions of Time** Contractor's Superintendent **3.2**, **3.7.4**, 5.2.3, 7.2.1, 7.3.1, **7.4**, **8.3**, 9.5.1, **9.7**, 3.9, 10.2.6 10.3.2, **10.4**, 14.3.2, **15.1.6**, 15.2.5 Contractor's Supervision and Construction **Digital Data Use and Transmission Procedures** 1.7 1.2.2, 3.3, 3.4, 3.12.10, 4.2.2, 4.2.7, 6.1.3, 6.2.4, 7.1.3, Disputes 7.3.4, 7.3.6, 8.2, 10, 12, 14, 15.1.4 6.3, 7.3.9, 15.1, 15.2 **Documents and Samples at the Site** Coordination and Correlation 1.2, 3.2.1, 3.3.1, 3.10, 3.12.6, 6.1.3, 6.2.1 3.11 Copies Furnished of Drawings and Specifications **Drawings**, Definition of 1.5, 2.3.6, 3.11 1.1.5 Copyrights Drawings and Specifications, Use and Ownership of 1.5, **3.17** Correction of Work Effective Date of Insurance 2.5, 3.7.3, 9.4.2, 9.8.2, 9.8.3, 9.9.1, 12.1.2, 12.2, 12.3, 8.2.2 15.1.3.1, 15.1.3.2, 15.2.1 **Emergencies Correlation and Intent of the Contract Documents 10.4**, 14.1.1.2, **15.1.5** 1.2 Employees, Contractor's Cost, Definition of 3.3.2, 3.4.3, 3.8.1, 3.9, 3.18.2, 4.2.3, 4.2.6, 10.2, 7.3.4 10.3.3, 11.3, 14.1, 14.2.1.1 Equipment, Labor, or Materials 2.5, 3.2.4, 3.7.3, 3.8.2, 3.15.2, 5.4.2, 6.1.1, 6.2.3, 1.1.3, 1.1.6, 3.4, 3.5, 3.8.2, 3.8.3, 3.12, 3.13, 3.15.1, 7.3.3.3, 7.3.4, 7.3.8, 7.3.9, 9.10.2, 10.3.2, 10.3.6, 11.2, 4.2.6, 4.2.7, 5.2.1, 6.2.1, 7.3.4, 9.3.2, 9.3.3, 9.5.1.3, 12.1.2, 12.2.1, 12.2.4, 13.4, 14 9.10.2, 10.2.1, 10.2.4, 14.2.1.1, 14.2.1.2 **Cutting and Patching** Execution and Progress of the Work **3.14**, 6.2.5 1.1.3, 1.2.1, 1.2.2, 2.3.4, 2.3.6, 3.1, 3.3.1, 3.4.1, 3.7.1, 3.10.1, 3.12, 3.14, 4.2, 6.2.2, 7.1.3, 7.3.6, 8.2, 9.5.1, 9.9.1, 10.2, 10.3, 12.1, 12.2, 14.2, 14.3.1, 15.1.4

Init.

User Notes:

(1817262161)

Extensions of Time Insurance, Stored Materials 3.2.4, 3.7.4, 5.2.3, 7.2.1, 7.3, 7.4, 9.5.1, 9.7, 10.3.2,9.3.2 INSURANCE AND BONDS 10.4, 14.3, 15.1.6, **15.2.5 Failure of Payment** 9.5.1.3, 9.7, 9.10.2, 13.5, 14.1.1.3, 14.2.1.2 Insurance Companies, Consent to Partial Occupancy Faulty Work (See Defective or Nonconforming Work) Insured loss, Adjustment and Settlement of **Final Completion and Final Payment** 4.2.1, 4.2.9, 9.8.2, **9.10**, 12.3, 14.2.4, 14.4.3 Intent of the Contract Documents Financial Arrangements, Owner's 1.2.1, 4.2.7, 4.2.12, 4.2.13 2.2.1, 13.2.2, 14.1.1.4 Interest **GENERAL PROVISIONS** 13.5 Interpretation 1.1.8, 1.2.3, **1.4**, 4.1.1, 5.1, 6.1.2, 15.1.1 **Governing Law** 13.1 Interpretations, Written Guarantees (See Warranty) 4.2.11, 4.2.12 **Hazardous Materials and Substances** Judgment on Final Award 10.2.4, 10.3 15.4.2 Identification of Subcontractors and Suppliers Labor and Materials, Equipment 5.2.1 1.1.3, 1.1.6, **3.4**, 3.5, 3.8.2, 3.8.3, 3.12, 3.13, 3.15.1, Indemnification 5.2.1, 6.2.1, 7.3.4, 9.3.2, 9.3.3, 9.5.1.3, 9.10.2, 10.2.1, 3.17, **3.18**, 9.6.8, 9.10.2, 10.3.3, 11.3 10.2.4, 14.2.1.1, 14.2.1.2 Information and Services Required of the Owner Labor Disputes 2.1.2, **2.2**, 2.3, 3.2.2, 3.12.10.1, 6.1.3, 6.1.4, 6.2.5, 8.3.1 9.6.1, 9.9.2, 9.10.3, 10.3.3, 11.2, 13.4.1, 13.4.2, Laws and Regulations 1.5, 2.3.2, 3.2.3, 3.2.4, 3.6, 3.7, 3.12.10, 3.13, 9.6.4, 14.1.1.4, 14.1.4, 15.1.4 **Initial Decision** 9.9.1, 10.2.2, 13.1, 13.3.1, 13.4.2, 13.5, 14, 15.2.8, 15.2 15.4 Initial Decision Maker, Definition of Liens 1.1.8 2.1.2, 9.3.1, 9.3.3, 9.6.8, 9.10.2, 9.10.4, 15.2.8 Initial Decision Maker, Decisions Limitations, Statutes of 14.2.4, 15.1.4.2, 15.2.1, 15.2.2, 15.2.3, 15.2.4, 15.2.5 12.2.5, 15.1.2, 15.4.1.1 Initial Decision Maker, Extent of Authority Limitations of Liability 14.2.4, 15.1.4.2, 15.2.1, 15.2.2, 15.2.3, 15.2.4, 15.2.5 3.2.2, 3.5, 3.12.10, 3.12.10.1, 3.17, 3.18.1, 4.2.6, Injury or Damage to Person or Property 4.2.7, 6.2.2, 9.4.2, 9.6.4, 9.6.7, 9.6.8, 10.2.5, 10.3.3, 10.2.8, 10.4 11.3, 12.2.5, 13.3.1 Inspections Limitations of Time 3.1.3, 3.3.3, 3.7.1, 4.2.2, 4.2.6, 4.2.9, 9.4.2, 9.8.3, 2.1.2, 2.2, 2.5, 3.2.2, 3.10, 3.11, 3.12.5, 3.15.1, 4.2.7,9.9.2, 9.10.1, 12.2.1, 13.4 5.2, 5.3, 5.4.1, 6.2.4, 7.3, 7.4, 8.2, 9.2, 9.3.1, 9.3.3, Instructions to Bidders 9.4.1, 9.5, 9.6, 9.7, 9.8, 9.9, 9.10, 12.2, 13.4, 14, 15, 1.1.1 15.1.2, 15.1.3, 15.1.5 Instructions to the Contractor Materials, Hazardous 3.2.4, 3.3.1, 3.8.1, 5.2.1, 7, 8.2.2, 12, 13.4.2 10.2.4, 10.3 Instruments of Service, Definition of Materials, Labor, Equipment and 1.1.7 1.1.3, 1.1.6, 3.4.1, 3.5, 3.8.2, 3.8.3, 3.12, 3.13, 3.15.1, 5.2.1, 6.2.1, 7.3.4, 9.3.2, 9.3.3, 9.5.1.3, 9.10.2, 6.1.1, 7.3.4, 8.2.2, 9.3.2, 9.8.4, 9.9.1, 9.10.2, 10.2.5, 11 10.2.1.2, 10.2.4, 14.2.1.1, 14.2.1.2 Insurance, Notice of Cancellation or Expiration Means, Methods, Techniques, Sequences and 11.1.4, 11.2.3 Procedures of Construction Insurance, Contractor's Liability 3.3.1, 3.12.10, 4.2.2, 4.2.7, 9.4.2 11.1 Mechanic's Lien Insurance, Effective Date of 2.1.2, 9.3.1, 9.3.3, 9.6.8, 9.10.2, 9.10.4, 15.2.8 8.2.2, 14.4.2 Mediation Insurance, Owner's Liability 8.3.1, 15.1.3.2, 15.2.1, 15.2.5, 15.2.6, **15.3**, 15.4.1, 15.4.1.1 **Insurance, Property** Minor Changes in the Work 1.1.1, 3.4.2, 3.12.8, 4.2.8, 7.1, 7.4 **10.2.5**, 11.2, 11.4, 11.5

Init.

User Notes:

(1817262161)

MISCELLANEOUS PROVISIONS

13

Modifications, Definition of

Modifications to the Contract

1.1.1, 1.1.2, 2.5, 3.11, 4.1.2, 4.2.1, 5.2.3, 7, 8.3.1, 9.7, 10.3.2

Mutual Responsibility

Nonconforming Work, Acceptance of

9.6.6, 9.9.3, 12.3

Nonconforming Work, Rejection and Correction of 2.4, 2.5, 3.5, 4.2.6, 6.2.4, 9.5.1, 9.8.2, 9.9.3, 9.10.4, 12.2

Notice

1.6, 1.6.1, 1.6.2, 2.1.2, 2.2.2., 2.2.3, 2.2.4, 2.5, 3.2.4, 3.3.1, 3.7.4, 3.7.5, 3.9.2, 3.12.9, 3.12.10, 5.2.1, 7.4, 8.2.2 9.6.8, 9.7, 9.10.1, 10.2.8, 10.3.2, 11.5, 12.2.2.1, 13.4.1, 13.4.2, 14.1, 14.2.2, 14.4.2, 15.1.3, 15.1.5, 15.1.6, 15.4.1

Notice of Cancellation or Expiration of Insurance 11.1.4, 11.2.3

Notice of Claims

1.6.2, 2.1.2, 3.7.4, 9.6.8, 10.2.8, **15.1.3**, 15.1.5, 15.1.6, 15.2.8, 15.3.2, 15.4.1

Notice of Testing and Inspections

13.4.1, 13.4.2

Observations, Contractor's

3.2, 3.7.4

Occupancy

2.3.1, 9.6.6, 9.8

Orders, Written

1.1.1, 2.4, 3.9.2, 7, 8.2.2, 11.5, 12.1, 12.2.2.1, 13.4.2, 14.3.1

OWNER

2

Owner, Definition of

2.1.1

Owner, Evidence of Financial Arrangements

2.2, 13.2.2, 14.1.1.4

Owner, Information and Services Required of the 2.1.2, **2.2**, 2.3, 3.2.2, 3.12.10, 6.1.3, 6.1.4, 6.2.5, 9.3.2, 9.6.1, 9.6.4, 9.9.2, 9.10.3, 10.3.3, 11.2, 13.4.1, 13.4.2, 14.1.1.4, 14.1.4, 15.1.4

Owner's Authority

1.5, 2.1.1, 2.3.32.4, 2.5, 3.4.2, 3.8.1, 3.12.10, 3.14.2, 4.1.2, 4.2.4, 4.2.9, 5.2.1, 5.2.4, 5.4.1, 6.1, 6.3, 7.2.1, 7.3.1, 8.2.2, 8.3.1, 9.3.2, 9.5.1, 9.6.4, 9.9.1, 9.10.2, 10.3.2, 11.4, 11.5, 12.2.2, 12.3, 13.2.2, 14.3, 14.4, 15.2.7

Owner's Insurance

Owner's Relationship with Subcontractors 1.1.2, 5.2, 5.3, 5.4, 9.6.4, 9.10.2, 14.2.2

Owner's Right to Carry Out the Work **2.5**, 14.2.2

Owner's Right to Clean Up

Owner's Right to Perform Construction and to **Award Separate Contracts**

6.1

Owner's Right to Stop the Work

Owner's Right to Suspend the Work

Owner's Right to Terminate the Contract

14.2, 14.4

Ownership and Use of Drawings, Specifications and Other Instruments of Service

1.1.1, 1.1.6, 1.1.7, **1.5**, 2.3.6, 3.2.2, 3.11, 3.17, 4.2.12,

Partial Occupancy or Use

9.6.6, **9.9**

Patching, Cutting and

3.14, 6.2.5 Patents

3.17

Payment, Applications for

4.2.5, 7.3.9, 9.2, **9.3**, 9.4, 9.5, 9.6.3, 9.7, 9.8.5, 9.10.1,

14.2.3, 14.2.4, 14.4.3

Payment, Certificates for

4.2.5, 4.2.9, 9.3.3, **9.4**, 9.5, 9.6.1, 9.6.6, 9.7, 9.10.1,

9.10.3, 14.1.1.3, 14.2.4

Payment, Failure of

9.5.1.3, **9.7**, 9.10.2, 13.5, 14.1.1.3, 14.2.1.2

Payment, Final

4.2.1, 4.2.9, **9.10**, 12.3, 14.2.4, 14.4.3

Payment Bond, Performance Bond and

7.3.4.4, 9.6.7, 9.10.3, **11.1.2**

Payments, Progress

9.3, **9.6**, 9.8.5, 9.10.3, 14.2.3, 15.1.4

PAYMENTS AND COMPLETION

Payments to Subcontractors

5.4.2, 9.5.1.3, 9.6.2, 9.6.3, 9.6.4, 9.6.7, 14.2.1.2

PCB

10.3.1

Performance Bond and Payment Bond

7.3.4.4, 9.6.7, 9.10.3, **11.1.2**

Permits, Fees, Notices and Compliance with Laws

2.3.1, **3.7**, 3.13, 7.3.4.4, 10.2.2

PERSONS AND PROPERTY, PROTECTION OF

Polychlorinated Biphenyl

10.3.1

Product Data, Definition of

3.12.2

Product Data and Samples, Shop Drawings

3.11, **3.12**, 4.2.7

Progress and Completion

4.2.2, **8.2**, 9.8, 9.9.1, 14.1.4, 15.1.4

Progress Payments

9.3, **9.6**, 9.8.5, 9.10.3, 14.2.3, 15.1.4

Init.

AIA Document A201® – 2017. Copyright © 1911, 1915, 1918, 1925, 1937, 1951, 1958, 1961, 1963, 1966, 1970, 1976, 1987, 1997, 2007 and 2017 by The American Institute of Architects. All rights reserved. The "American Institute of Architects," "AIA," the AIA Logo, "A201," and "AIA Contract Documents" are registered trademarks and may not be used without permission. This document was produced by AIA software at 10:57:44 ET on 01/24/2023 under Order No.2114341894 which expires on 07/20/2023, is not for resale, is licensed for one-time use only, and may only be used in accordance with the AIA Contract Documents® Terms of Service. To report copyright violations, e-mail copyright@aia.org. **User Notes:** (1817262161)

6

Project, Definition of Separate Contracts and Contractors 1.1.4, 3.12.5, 3.14.2, 4.2.4, 4.2.7, 6, 8.3.1, 12.1.2 1.1.4 Project Representatives Separate Contractors, Definition of 4.2.10 6.1.1 **Property Insurance** Shop Drawings, Definition of 10.2.5, **11.2** 3.12.1 **Proposal Requirements Shop Drawings, Product Data and Samples** 3.11, 3.12, 4.2.7 PROTECTION OF PERSONS AND PROPERTY Site, Use of 10 **3.13**, 6.1.1, 6.2.1 Site Inspections Regulations and Laws 3.2.2, 3.3.3, 3.7.1, 3.7.4, 4.2, 9.9.2, 9.4.2, 9.10.1, 13.4 1.5, 2.3.2, 3.2.3, 3.6, 3.7, 3.12.10, 3.13, 9.6.4, 9.9.1, 10.2.2, 13.1, 13.3, 13.4.1, 13.4.2, 13.5, 14, 15.2.8, 15.4 Site Visits, Architect's 3.7.4, 4.2.2, 4.2.9, 9.4.2, 9.5.1, 9.9.2, 9.10.1, 13.4 Rejection of Work 4.2.6, 12.2.1 Special Inspections and Testing Releases and Waivers of Liens 4.2.6, 12.2.1, 13.4 Specifications, Definition of 9.3.1, 9.10.2 Representations 1.1.6 3.2.1, 3.5, 3.12.6, 8.2.1, 9.3.3, 9.4.2, 9.5.1, 9.10.1**Specifications** Representatives 1.1.1, **1.1.6**, 1.2.2, 1.5, 3.12.10, 3.17, 4.2.14 2.1.1, 3.1.1, 3.9, 4.1.1, 4.2.10, 13.2.1 Statute of Limitations Responsibility for Those Performing the Work 15.1.2, 15.4.1.1 Stopping the Work 3.3.2, 3.18, 4.2.2, 4.2.3, 5.3, 6.1.3, 6.2, 6.3, 9.5.1, 10 2.2.2, 2.4, 9.7, 10.3, 14.1 9.3.1, 9.6.2, 9.8.5, 9.9.1, 9.10.2, 9.10.3 Stored Materials **Review of Contract Documents and Field** 6.2.1, 9.3.2, 10.2.1.2, 10.2.4 **Conditions by Contractor** Subcontractor, Definition of 5.1.1 **3.2**, 3.12.7, 6.1.3 Review of Contractor's Submittals by Owner and **SUBCONTRACTORS** Architect 3.10.1, 3.10.2, 3.11, 3.12, 4.2, 5.2, 6.1.3, 9.2, 9.8.2 Subcontractors, Work by Review of Shop Drawings, Product Data and Samples 1.2.2, 3.3.2, 3.12.1, 3.18, 4.2.3, 5.2.3, 5.3, 5.4, 9.3.1.2, by Contractor 3.12 **Subcontractual Relations Rights and Remedies 5.3**, 5.4, 9.3.1.2, 9.6, 9.10, 10.2.1, 14.1, 14.2.1 1.1.2, 2.4, 2.5, 3.5, 3.7.4, 3.15.2, 4.2.6, 5.3, 5.4, 6.1, Submittals 6.3, 7.3.1, 8.3, 9.5.1, 9.7, 10.2.5, 10.3, 12.2.1, 12.2.2, 3.10, 3.11, 3.12, 4.2.7, 5.2.1, 5.2.3, 7.3.4, 9.2, 9.3, 9.8, 9.9.1, 9.10.2, 9.10.3 12.2.4, **13.3**, 14, 15.4 Royalties, Patents and Copyrights Submittal Schedule 3.17 3.10.2, 3.12.5, 4.2.7 Rules and Notices for Arbitration Subrogation, Waivers of 15.4.1 6.1.1, **11.3** Safety of Persons and Property Substances, Hazardous 10.2, 10.4 10.3 **Safety Precautions and Programs Substantial Completion** 3.3.1, 4.2.2, 4.2.7, 5.3, **10.1**, 10.2, 10.4 4.2.9, 8.1.1, 8.1.3, 8.2.3, 9.4.2, **9.8**, 9.9.1, 9.10.3, 12.2, Samples, Definition of 15.1.2 3.12.3 Substantial Completion, Definition of Samples, Shop Drawings, Product Data and 9.8.1 Substitution of Subcontractors 3.11, **3.12**, 4.2.7 Samples at the Site, Documents and 5.2.3, 5.2.4 3.11 Substitution of Architect Schedule of Values 2.3.3 Substitutions of Materials **9.2**, 9.3.1 Schedules, Construction 3.4.2, 3.5, 7.3.8 3.10, 3.12.1, 3.12.2, 6.1.3, 15.1.6.2 Sub-subcontractor, Definition of

Init.

User Notes:

Subsurface Conditions

3.7.4

Successors and Assigns

13.2

Superintendent

3.9, 10.2.6

Supervision and Construction Procedures

1.2.2, **3.3**, 3.4, 3.12.10, 4.2.2, 4.2.7, 6.1.3, 6.2.4, 7.1.3,

7.3.4, 8.2, 8.3.1, 9.4.2, 10, 12, 14, 15.1.4

Suppliers

1.5, 3.12.1, 4.2.4, 4.2.6, 5.2.1, 9.3, 9.4.2, 9.5.4, 9.6,

9.10.5, 14.2.1

Surety

5.4.1.2, 9.6.8, 9.8.5, 9.10.2, 9.10.3, 11.1.2, 14.2.2,

15.2.7

Surety, Consent of

9.8.5, 9.10.2, 9.10.3

Surveys

1.1.7, 2.3.4

Suspension by the Owner for Convenience

14.3

Suspension of the Work

3.7.5, 5.4.2, 14.3

Suspension or Termination of the Contract

5.4.1.1, 14

Taxes

3.6, 3.8.2.1, 7.3.4.4

Termination by the Contractor

14.1, 15.1.7

Termination by the Owner for Cause

5.4.1.1, 14.2, 15.1.7

Termination by the Owner for Convenience

14.4

Termination of the Architect

2.3.3

Termination of the Contractor Employment

14.2.2

TERMINATION OR SUSPENSION OF THE CONTRACT

14

Tests and Inspections

3.1.3, 3.3.3, 3.7.1, 4.2.2, 4.2.6, 4.2.9, 9.4.2, 9.8.3,

9.9.2, 9.10.1, 10.3.2, 12.2.1, 13.4

TIME

User Notes:

8

Time, Delays and Extensions of

3.2.4, 3.7.4, 5.2.3, 7.2.1, 7.3.1, 7.4, **8.3**, 9.5.1, 9.7,

10.3.2, 10.4, 14.3.2, 15.1.6, 15.2.5

Time Limits

2.1.2, 2.2, 2.5, 3.2.2, 3.10, 3.11, 3.12.5, 3.15.1, 4.2,

5.2, 5.3, 5.4, 6.2.4, 7.3, 7.4, 8.2, 9.2, 9.3.1, 9.3.3, 9.4.1,

9.5, 9.6, 9.7, 9.8, 9.9, 9.10, 12.2, 13.4, 14, 15.1.2,

15.1.3, 15.4

Time Limits on Claims

3.7.4, 10.2.8, 15.1.2, 15.1.3

Title to Work

9.3.2, 9.3.3

UNCOVERING AND CORRECTION OF WORK

12

Uncovering of Work

12.1

Unforeseen Conditions, Concealed or Unknown

3.7.4, 8.3.1, 10.3

Unit Prices

7.3.3.2, 9.1.2

Use of Documents

1.1.1, 1.5, 2.3.6, 3.12.6, 5.3

Use of Site

3.13, 6.1.1, 6.2.1

Values, Schedule of

9.2, 9.3.1

Waiver of Claims by the Architect

13.3.2

Waiver of Claims by the Contractor

9.10.5, 13.3.2, **15.1.7**

Waiver of Claims by the Owner

9.9.3, 9.10.3, 9.10.4, 12.2.2.1, 13.3.2, 14.2.4, **15.1.7**

Waiver of Consequential Damages

14.2.4, 15.1.7

Waiver of Liens

9.3, 9.10.2, 9.10.4

Waivers of Subrogation

6.1.1, **11.3**

Warranty

3.5, 4.2.9, 9.3.3, 9.8.4, 9.9.1, 9.10.2, 9.10.4, 12.2.2,

15.1.2

Weather Delays

8.3, 15.1.6.2

Work, Definition of

1.1.3

Written Consent

1.5.2, 3.4.2, 3.7.4, 3.12.8, 3.14.2, 4.1.2, 9.3.2, 9.10.3,

13.2, 13.3.2, 15.4.4.2

Written Interpretations

4.2.11, 4.2.12

Written Orders

1.1.1, 2.4, 3.9, 7, 8.2.2, 12.1, 12.2, 13.4.2, 14.3.1

8

ARTICLE 1 GENERAL PROVISIONS

§ 1.1 Basic Definitions

§ 1.1.1 The Contract Documents

The Contract Documents are enumerated in the Agreement between the Owner and Contractor (hereinafter the Agreement) and consist of the Agreement, Conditions of the Contract (General, Supplementary and other Conditions), Drawings, Specifications, Addenda issued prior to execution of the Contract, other documents listed in the Agreement, and Modifications issued after execution of the Contract. A Modification is (1) a written amendment to the Contract signed by both parties, (2) a Change Order, (3) a Construction Change Directive, or (4) a written order for a minor change in the Work issued by the Architect. Unless specifically enumerated in the Agreement, the Contract Documents do not include the advertisement or invitation to bid, Instructions to Bidders, sample forms, other information furnished by the Owner in anticipation of receiving bids or proposals, the Contractor's bid or proposal, or portions of Addenda relating to bidding or proposal requirements.

§ 1.1.2 The Contract

The Contract Documents form the Contract for Construction. The Contract represents the entire and integrated agreement between the parties hereto and supersedes prior negotiations, representations, or agreements, either written or oral. The Contract may be amended or modified only by a Modification. The Contract Documents shall not be construed to create a contractual relationship of any kind (1) between the Contractor and the Architect or the Architect's consultants, (2) between the Owner and a Subcontractor or a Sub-subcontractor, (3) between the Owner and the Architect or the Architect's consultants, or (4) between any persons or entities other than the Owner and the Contractor. The Architect shall, however, be entitled to performance and enforcement of obligations under the Contract intended to facilitate performance of the Architect's duties.

§ 1.1.3 The Work

The term "Work" means the construction and services required by the Contract Documents, whether completed or partially completed, and includes all other labor, materials, equipment, and services provided or to be provided by the Contractor to fulfill the Contractor's obligations. The Work may constitute the whole or a part of the Project.

§ 1.1.4 The Project

The Project is the total construction of which the Work performed under the Contract Documents may be the whole or a part and which may include construction by the Owner and by Separate Contractors.

§ 1.1.5 The Drawings

The Drawings are the graphic and pictorial portions of the Contract Documents showing the design, location and dimensions of the Work, generally including plans, elevations, sections, details, schedules, and diagrams.

§ 1.1.6 The Specifications

The Specifications are that portion of the Contract Documents consisting of the written requirements for materials, equipment, systems, standards and workmanship for the Work, and performance of related services.

§ 1.1.7 Instruments of Service

Instruments of Service are representations, in any medium of expression now known or later developed, of the tangible and intangible creative work performed by the Architect and the Architect's consultants under their respective professional services agreements. Instruments of Service may include, without limitation, studies, surveys, models, sketches, drawings, specifications, and other similar materials.

§ 1.1.8 Initial Decision Maker

The Initial Decision Maker is the person identified in the Agreement to render initial decisions on Claims in accordance with Section 15.2. The Initial Decision Maker shall not show partiality to the Owner or Contractor and shall not be liable for results of interpretations or decisions rendered in good faith.

§ 1.2 Correlation and Intent of the Contract Documents

§ 1.2.1 The intent of the Contract Documents is to include all items necessary for the proper execution and completion of the Work by the Contractor. The Contract Documents are complementary, and what is required by one shall be as binding as if required by all; performance by the Contractor shall be required only to the extent consistent with the Contract Documents and reasonably inferable from them as being necessary to produce the indicated results.

- § 1.2.1.1 The invalidity of any provision of the Contract Documents shall not invalidate the Contract or its remaining provisions. If it is determined that any provision of the Contract Documents violates any law, or is otherwise invalid or unenforceable, then that provision shall be revised to the extent necessary to make that provision legal and enforceable. In such case the Contract Documents shall be construed, to the fullest extent permitted by law, to give effect to the parties' intentions and purposes in executing the Contract.
- § 1.2.2 Organization of the Specifications into divisions, sections and articles, and arrangement of Drawings shall not control the Contractor in dividing the Work among Subcontractors or in establishing the extent of Work to be performed by any trade.
- § 1.2.3 Unless otherwise stated in the Contract Documents, words that have well-known technical or construction industry meanings are used in the Contract Documents in accordance with such recognized meanings.

§ 1.3 Capitalization

Terms capitalized in these General Conditions include those that are (1) specifically defined, (2) the titles of numbered articles, or (3) the titles of other documents published by the American Institute of Architects.

§ 1.4 Interpretation

In the interest of brevity the Contract Documents frequently omit modifying words such as "all" and "any" and articles such as "the" and "an," but the fact that a modifier or an article is absent from one statement and appears in another is not intended to affect the interpretation of either statement.

§ 1.5 Ownership and Use of Drawings, Specifications, and Other Instruments of Service

- § 1.5.1 The Architect and the Architect's consultants shall be deemed the authors and owners of their respective Instruments of Service, including the Drawings and Specifications, and retain all common law, statutory, and other reserved rights in their Instruments of Service, including copyrights. The Contractor, Subcontractors, Sub-subcontractors, and suppliers shall not own or claim a copyright in the Instruments of Service. Submittal or distribution to meet official regulatory requirements or for other purposes in connection with the Project is not to be construed as publication in derogation of the Architect's or Architect's consultants' reserved rights.
- § 1.5.2 The Contractor, Subcontractors, Sub-subcontractors, and suppliers are authorized to use and reproduce the Instruments of Service provided to them, subject to any protocols established pursuant to Sections 1.7 and 1.8, solely and exclusively for execution of the Work. All copies made under this authorization shall bear the copyright notice, if any, shown on the Instruments of Service. The Contractor, Subcontractors, Sub-subcontractors, and suppliers may not use the Instruments of Service on other projects or for additions to the Project outside the scope of the Work without the specific written consent of the Owner, Architect, and the Architect's consultants.

§ 1.6 Notice

- § 1.6.1 Except as otherwise provided in Section 1.6.2, where the Contract Documents require one party to notify or give notice to the other party, such notice shall be provided in writing to the designated representative of the party to whom the notice is addressed and shall be deemed to have been duly served if delivered in person, by mail, by courier, or by electronic transmission if a method for electronic transmission is set forth in the Agreement.
- § 1.6.2 Notice of Claims as provided in Section 15.1.3 shall be provided in writing and shall be deemed to have been duly served only if delivered to the designated representative of the party to whom the notice is addressed by certified or registered mail, or by courier providing proof of delivery.

§ 1.7 Digital Data Use and Transmission

The parties shall agree upon protocols governing the transmission and use of Instruments of Service or any other information or documentation in digital form. The parties will use AIA Document E203TM–2013, Building Information Modeling and Digital Data Exhibit, to establish the protocols for the development, use, transmission, and exchange of digital data.

§ 1.8 Building Information Models Use and Reliance

Any use of, or reliance on, all or a portion of a building information model without agreement to protocols governing the use of, and reliance on, the information contained in the model and without having those protocols set forth in AIA Document E203TM_2013, Building Information Modeling and Digital Data Exhibit, and the requisite AIA Document

G202TM–2013, Project Building Information Modeling Protocol Form, shall be at the using or relying party's sole risk and without liability to the other party and its contractors or consultants, the authors of, or contributors to, the building information model, and each of their agents and employees.

ARTICLE 2 OWNER

§ 2.1 General

- § 2.1.1 The Owner is the person or entity identified as such in the Agreement and is referred to throughout the Contract Documents as if singular in number. The Owner shall designate in writing a representative who shall have express authority to bind the Owner with respect to all matters requiring the Owner's approval or authorization. Except as otherwise provided in Section 4.2.1, the Architect does not have such authority. The term "Owner" means the Owner or the Owner's authorized representative.
- § 2.1.2 The Owner shall furnish to the Contractor, within fifteen days after receipt of a written request, information necessary and relevant for the Contractor to evaluate, give notice of, or enforce mechanic's lien rights. Such information shall include a correct statement of the record legal title to the property on which the Project is located, usually referred to as the site, and the Owner's interest therein.

§ 2.2 Evidence of the Owner's Financial Arrangements

- § 2.2.1 Prior to commencement of the Work and upon written request by the Contractor, the Owner shall furnish to the Contractor reasonable evidence that the Owner has made financial arrangements to fulfill the Owner's obligations under the Contract. The Contractor shall have no obligation to commence the Work until the Owner provides such evidence. If commencement of the Work is delayed under this Section 2.2.1, the Contract Time shall be extended appropriately.
- § 2.2.2 Following commencement of the Work and upon written request by the Contractor, the Owner shall furnish to the Contractor reasonable evidence that the Owner has made financial arrangements to fulfill the Owner's obligations under the Contract only if (1) the Owner fails to make payments to the Contractor as the Contract Documents require; (2) the Contractor identifies in writing a reasonable concern regarding the Owner's ability to make payment when due; or (3) a change in the Work materially changes the Contract Sum. If the Owner fails to provide such evidence, as required, within fourteen days of the Contractor's request, the Contractor may immediately stop the Work and, in that event, shall notify the Owner that the Work has stopped. However, if the request is made because a change in the Work materially changes the Contract Sum under (3) above, the Contractor may immediately stop only that portion of the Work affected by the change until reasonable evidence is provided. If the Work is stopped under this Section 2.2.2, the Contract Time shall be extended appropriately and the Contract Sum shall be increased by the amount of the Contractor's reasonable costs of shutdown, delay and start-up, plus interest as provided in the Contract Documents.
- **§ 2.2.3** After the Owner furnishes evidence of financial arrangements under this Section 2.2, the Owner shall not materially vary such financial arrangements without prior notice to the Contractor.
- § 2.2.4 Where the Owner has designated information furnished under this Section 2.2 as "confidential," the Contractor shall keep the information confidential and shall not disclose it to any other person. However, the Contractor may disclose "confidential" information, after seven (7) days' notice to the Owner, where disclosure is required by law, including a subpoena or other form of compulsory legal process issued by a court or governmental entity, or by court or arbitrator(s) order. The Contractor may also disclose "confidential" information to its employees, consultants, sureties, Subcontractors and their employees, Sub-subcontractors, and others who need to know the content of such information solely and exclusively for the Project and who agree to maintain the confidentiality of such information.

§ 2.3 Information and Services Required of the Owner

- § 2.3.1 Except for permits and fees that are the responsibility of the Contractor under the Contract Documents, including those required under Section 3.7.1, the Owner shall secure and pay for necessary approvals, easements, assessments and charges required for construction, use or occupancy of permanent structures or for permanent changes in existing facilities.
- § 2.3.2 The Owner shall retain an architect lawfully licensed to practice architecture, or an entity lawfully practicing architecture, in the jurisdiction where the Project is located. That person or entity is identified as the Architect in the Agreement and is referred to throughout the Contract Documents as if singular in number.

- § 2.3.3 If the employment of the Architect terminates, the Owner shall employ a successor to whom the Contractor has no reasonable objection and whose status under the Contract Documents shall be that of the Architect.
- § 2.3.4 The Owner shall furnish surveys describing physical characteristics, legal limitations and utility locations for the site of the Project, and a legal description of the site. The Contractor shall be entitled to rely on the accuracy of information furnished by the Owner but shall exercise proper precautions relating to the safe performance of the Work.
- § 2.3.5 The Owner shall furnish information or services required of the Owner by the Contract Documents with reasonable promptness. The Owner shall also furnish any other information or services under the Owner's control and relevant to the Contractor's performance of the Work with reasonable promptness after receiving the Contractor's written request for such information or services.
- § 2.3.6 Unless otherwise provided in the Contract Documents, the Owner shall furnish to the Contractor one copy of the Contract Documents for purposes of making reproductions pursuant to Section 1.5.2.

§ 2.4 Owner's Right to Stop the Work

If the Contractor fails to correct Work that is not in accordance with the requirements of the Contract Documents as required by Section 12.2 or repeatedly fails to carry out Work in accordance with the Contract Documents, the Owner may issue a written order to the Contractor to stop the Work, or any portion thereof, until the cause for such order has been eliminated; however, the right of the Owner to stop the Work shall not give rise to a duty on the part of the Owner to exercise this right for the benefit of the Contractor or any other person or entity, except to the extent required by Section 6.1.3.

§ 2.5 Owner's Right to Carry Out the Work

If the Contractor defaults or neglects to carry out the Work in accordance with the Contract Documents and fails within a ten-day period after receipt of notice from the Owner to commence and continue correction of such default or neglect with diligence and promptness, the Owner may, without prejudice to other remedies the Owner may have, correct such default or neglect. Such action by the Owner and amounts charged to the Contractor are both subject to prior approval of the Architect and the Architect may, pursuant to Section 9.5.1, withhold or nullify a Certificate for Payment in whole or in part, to the extent reasonably necessary to reimburse the Owner for the reasonable cost of correcting such deficiencies, including Owner's expenses and compensation for the Architect's additional services made necessary by such default, neglect, or failure. If current and future payments are not sufficient to cover such amounts, the Contractor shall pay the difference to the Owner. If the Contractor disagrees with the actions of the Owner or the Architect, or the amounts claimed as costs to the Owner, the Contractor may file a Claim pursuant to Article 15.

ARTICLE 3 CONTRACTOR

§ 3.1 General

- § 3.1.1 The Contractor is the person or entity identified as such in the Agreement and is referred to throughout the Contract Documents as if singular in number. The Contractor shall be lawfully licensed, if required in the jurisdiction where the Project is located. The Contractor shall designate in writing a representative who shall have express authority to bind the Contractor with respect to all matters under this Contract. The term "Contractor" means the Contractor or the Contractor's authorized representative.
- § 3.1.2 The Contractor shall perform the Work in accordance with the Contract Documents.
- § 3.1.3 The Contractor shall not be relieved of its obligations to perform the Work in accordance with the Contract Documents either by activities or duties of the Architect in the Architect's administration of the Contract, or by tests, inspections or approvals required or performed by persons or entities other than the Contractor.

§ 3.2 Review of Contract Documents and Field Conditions by Contractor

§ 3.2.1 Execution of the Contract by the Contractor is a representation that the Contractor has visited the site, become generally familiar with local conditions under which the Work is to be performed, and correlated personal observations with requirements of the Contract Documents.

- § 3.2.2 Because the Contract Documents are complementary, the Contractor shall, before starting each portion of the Work, carefully study and compare the various Contract Documents relative to that portion of the Work, as well as the information furnished by the Owner pursuant to Section 2.3.4, shall take field measurements of any existing conditions related to that portion of the Work, and shall observe any conditions at the site affecting it. These obligations are for the purpose of facilitating coordination and construction by the Contractor and are not for the purpose of discovering errors, omissions, or inconsistencies in the Contract Documents; however, the Contractor shall promptly report to the Architect any errors, inconsistencies or omissions discovered by or made known to the Contractor as a request for information in such form as the Architect may require. It is recognized that the Contractor's review is made in the Contractor's capacity as a contractor and not as a licensed design professional, unless otherwise specifically provided in the Contract Documents.
- § 3.2.3 The Contractor is not required to ascertain that the Contract Documents are in accordance with applicable laws, statutes, ordinances, codes, rules and regulations, or lawful orders of public authorities, but the Contractor shall promptly report to the Architect any nonconformity discovered by or made known to the Contractor as a request for information in such form as the Architect may require.
- § 3.2.4 If the Contractor believes that additional cost or time is involved because of clarifications or instructions the Architect issues in response to the Contractor's notices or requests for information pursuant to Sections 3.2.2 or 3.2.3, the Contractor shall submit Claims as provided in Article 15. If the Contractor fails to perform the obligations of Sections 3.2.2 or 3.2.3, the Contractor shall pay such costs and damages to the Owner, subject to Section 15.1.7, as would have been avoided if the Contractor had performed such obligations. If the Contractor performs those obligations, the Contractor shall not be liable to the Owner or Architect for damages resulting from errors, inconsistencies or omissions in the Contract Documents, for differences between field measurements or conditions and the Contract Documents, or for nonconformities of the Contract Documents to applicable laws, statutes, ordinances, codes, rules and regulations, and lawful orders of public authorities.

§ 3.3 Supervision and Construction Procedures

- § 3.3.1 The Contractor shall supervise and direct the Work, using the Contractor's best skill and attention. The Contractor shall be solely responsible for, and have control over, construction means, methods, techniques, sequences, and procedures, and for coordinating all portions of the Work under the Contract. If the Contract Documents give specific instructions concerning construction means, methods, techniques, sequences, or procedures, the Contractor shall evaluate the jobsite safety thereof and shall be solely responsible for the jobsite safety of such means, methods, techniques, sequences, or procedures. If the Contractor determines that such means, methods, techniques, sequences or procedures may not be safe, the Contractor shall give timely notice to the Owner and Architect, and shall propose alternative means, methods, techniques, sequences, or procedures. The Architect shall evaluate the proposed alternative solely for conformance with the design intent for the completed construction. Unless the Architect objects to the Contractor's proposed alternative, the Contractor shall perform the Work using its alternative means, methods, techniques, sequences, or procedures.
- § 3.3.2 The Contractor shall be responsible to the Owner for acts and omissions of the Contractor's employees, Subcontractors and their agents and employees, and other persons or entities performing portions of the Work for, or on behalf of, the Contractor or any of its Subcontractors.
- § 3.3.3 The Contractor shall be responsible for inspection of portions of Work already performed to determine that such portions are in proper condition to receive subsequent Work.

§ 3.4 Labor and Materials

- § 3.4.1 Unless otherwise provided in the Contract Documents, the Contractor shall provide and pay for labor, materials, equipment, tools, construction equipment and machinery, water, heat, utilities, transportation, and other facilities and services necessary for proper execution and completion of the Work, whether temporary or permanent and whether or not incorporated or to be incorporated in the Work.
- § 3.4.2 Except in the case of minor changes in the Work approved by the Architect in accordance with Section 3.12.8 or ordered by the Architect in accordance with Section 7.4, the Contractor may make substitutions only with the consent of the Owner, after evaluation by the Architect and in accordance with a Change Order or Construction Change Directive.

§ 3.4.3 The Contractor shall enforce strict discipline and good order among the Contractor's employees and other persons carrying out the Work. The Contractor shall not permit employment of unfit persons or persons not properly skilled in tasks assigned to them.

§ 3.5 Warranty

- § 3.5.1 The Contractor warrants to the Owner and Architect that materials and equipment furnished under the Contract will be of good quality and new unless the Contract Documents require or permit otherwise. The Contractor further warrants that the Work will conform to the requirements of the Contract Documents and will be free from defects, except for those inherent in the quality of the Work the Contract Documents require or permit. Work, materials, or equipment not conforming to these requirements may be considered defective. The Contractor's warranty excludes remedy for damage or defect caused by abuse, alterations to the Work not executed by the Contractor, improper or insufficient maintenance, improper operation, or normal wear and tear and normal usage. If required by the Architect, the Contractor shall furnish satisfactory evidence as to the kind and quality of materials and equipment.
- § 3.5.2 All material, equipment, or other special warranties required by the Contract Documents shall be issued in the name of the Owner, or shall be transferable to the Owner, and shall commence in accordance with Section 9.8.4.

§ 3.6 Taxes

The Contractor shall pay sales, consumer, use and similar taxes for the Work provided by the Contractor that are legally enacted when bids are received or negotiations concluded, whether or not yet effective or merely scheduled to go into effect.

§ 3.7 Permits, Fees, Notices and Compliance with Laws

- § 3.7.1 Unless otherwise provided in the Contract Documents, the Contractor shall secure and pay for the building permit as well as for other permits, fees, licenses, and inspections by government agencies necessary for proper execution and completion of the Work that are customarily secured after execution of the Contract and legally required at the time bids are received or negotiations concluded.
- § 3.7.2 The Contractor shall comply with and give notices required by applicable laws, statutes, ordinances, codes, rules and regulations, and lawful orders of public authorities applicable to performance of the Work.
- § 3.7.3 If the Contractor performs Work knowing it to be contrary to applicable laws, statutes, ordinances, codes, rules and regulations, or lawful orders of public authorities, the Contractor shall assume appropriate responsibility for such Work and shall bear the costs attributable to correction.

§ 3.7.4 Concealed or Unknown Conditions

If the Contractor encounters conditions at the site that are (1) subsurface or otherwise concealed physical conditions that differ materially from those indicated in the Contract Documents or (2) unknown physical conditions of an unusual nature that differ materially from those ordinarily found to exist and generally recognized as inherent in construction activities of the character provided for in the Contract Documents, the Contractor shall promptly provide notice to the Owner and the Architect before conditions are disturbed and in no event later than 14 days after first observance of the conditions. The Architect will promptly investigate such conditions and, if the Architect determines that they differ materially and cause an increase or decrease in the Contractor's cost of, or time required for, performance of any part of the Work, will recommend that an equitable adjustment be made in the Contract Sum or Contract Time, or both. If the Architect determines that the conditions at the site are not materially different from those indicated in the Contract Documents and that no change in the terms of the Contract is justified, the Architect shall promptly notify the Owner and Contractor, stating the reasons. If either party disputes the Architect's determination or recommendation, that party may submit a Claim as provided in Article 15.

§ 3.7.5 If, in the course of the Work, the Contractor encounters human remains or recognizes the existence of burial markers, archaeological sites or wetlands not indicated in the Contract Documents, the Contractor shall immediately suspend any operations that would affect them and shall notify the Owner and Architect. Upon receipt of such notice, the Owner shall promptly take any action necessary to obtain governmental authorization required to resume the operations. The Contractor shall continue to suspend such operations until otherwise instructed by the Owner but shall continue with all other operations that do not affect those remains or features. Requests for adjustments in the Contract Sum and Contract Time arising from the existence of such remains or features may be made as provided in Article 15.

§ 3.8 Allowances

- § 3.8.1 The Contractor shall include in the Contract Sum all allowances stated in the Contract Documents. Items covered by allowances shall be supplied for such amounts and by such persons or entities as the Owner may direct, but the Contractor shall not be required to employ persons or entities to whom the Contractor has reasonable objection.
- § 3.8.2 Unless otherwise provided in the Contract Documents,
 - allowances shall cover the cost to the Contractor of materials and equipment delivered at the site and all required taxes, less applicable trade discounts;
 - .2 Contractor's costs for unloading and handling at the site, labor, installation costs, overhead, profit, and other expenses contemplated for stated allowance amounts shall be included in the Contract Sum but not in the allowances; and
 - whenever costs are more than or less than allowances, the Contract Sum shall be adjusted accordingly by Change Order. The amount of the Change Order shall reflect (1) the difference between actual costs and the allowances under Section 3.8.2.1 and (2) changes in Contractor's costs under Section 3.8.2.2.
- § 3.8.3 Materials and equipment under an allowance shall be selected by the Owner with reasonable promptness.

§ 3.9 Superintendent

- § 3.9.1 The Contractor shall employ a competent superintendent and necessary assistants who shall be in attendance at the Project site during performance of the Work. The superintendent shall represent the Contractor, and communications given to the superintendent shall be as binding as if given to the Contractor.
- § 3.9.2 The Contractor, as soon as practicable after award of the Contract, shall notify the Owner and Architect of the name and qualifications of a proposed superintendent. Within 14 days of receipt of the information, the Architect may notify the Contractor, stating whether the Owner or the Architect (1) has reasonable objection to the proposed superintendent or (2) requires additional time for review. Failure of the Architect to provide notice within the 14-day period shall constitute notice of no reasonable objection.
- § 3.9.3 The Contractor shall not employ a proposed superintendent to whom the Owner or Architect has made reasonable and timely objection. The Contractor shall not change the superintendent without the Owner's consent, which shall not unreasonably be withheld or delayed.

§ 3.10 Contractor's Construction and Submittal Schedules

- § 3.10.1 The Contractor, promptly after being awarded the Contract, shall submit for the Owner's and Architect's information a Contractor's construction schedule for the Work. The schedule shall contain detail appropriate for the Project, including (1) the date of commencement of the Work, interim schedule milestone dates, and the date of Substantial Completion; (2) an apportionment of the Work by construction activity; and (3) the time required for completion of each portion of the Work. The schedule shall provide for the orderly progression of the Work to completion and shall not exceed time limits current under the Contract Documents. The schedule shall be revised at appropriate intervals as required by the conditions of the Work and Project.
- § 3.10.2 The Contractor, promptly after being awarded the Contract and thereafter as necessary to maintain a current submittal schedule, shall submit a submittal schedule for the Architect's approval. The Architect's approval shall not be unreasonably delayed or withheld. The submittal schedule shall (1) be coordinated with the Contractor's construction schedule, and (2) allow the Architect reasonable time to review submittals. If the Contractor fails to submit a submittal schedule, or fails to provide submittals in accordance with the approved submittal schedule, the Contractor shall not be entitled to any increase in Contract Sum or extension of Contract Time based on the time required for review of submittals.
- § 3.10.3 The Contractor shall perform the Work in general accordance with the most recent schedules submitted to the Owner and Architect.

§ 3.11 Documents and Samples at the Site

The Contractor shall make available, at the Project site, the Contract Documents, including Change Orders, Construction Change Directives, and other Modifications, in good order and marked currently to indicate field changes and selections made during construction, and the approved Shop Drawings, Product Data, Samples, and similar required submittals. These shall be in electronic form or paper copy, available to the Architect and Owner, and

delivered to the Architect for submittal to the Owner upon completion of the Work as a record of the Work as constructed.

§ 3.12 Shop Drawings, Product Data and Samples

- § 3.12.1 Shop Drawings are drawings, diagrams, schedules, and other data specially prepared for the Work by the Contractor or a Subcontractor, Sub-subcontractor, manufacturer, supplier, or distributor to illustrate some portion of the Work.
- § 3.12.2 Product Data are illustrations, standard schedules, performance charts, instructions, brochures, diagrams, and other information furnished by the Contractor to illustrate materials or equipment for some portion of the Work.
- § 3.12.3 Samples are physical examples that illustrate materials, equipment, or workmanship, and establish standards by which the Work will be judged.
- § 3.12.4 Shop Drawings, Product Data, Samples, and similar submittals are not Contract Documents. Their purpose is to demonstrate how the Contractor proposes to conform to the information given and the design concept expressed in the Contract Documents for those portions of the Work for which the Contract Documents require submittals. Review by the Architect is subject to the limitations of Section 4.2.7. Informational submittals upon which the Architect is not expected to take responsive action may be so identified in the Contract Documents. Submittals that are not required by the Contract Documents may be returned by the Architect without action.
- § 3.12.5 The Contractor shall review for compliance with the Contract Documents, approve, and submit to the Architect, Shop Drawings, Product Data, Samples, and similar submittals required by the Contract Documents, in accordance with the submittal schedule approved by the Architect or, in the absence of an approved submittal schedule, with reasonable promptness and in such sequence as to cause no delay in the Work or in the activities of the Owner or of Separate Contractors.
- § 3.12.6 By submitting Shop Drawings, Product Data, Samples, and similar submittals, the Contractor represents to the Owner and Architect that the Contractor has (1) reviewed and approved them, (2) determined and verified materials, field measurements and field construction criteria related thereto, or will do so, and (3) checked and coordinated the information contained within such submittals with the requirements of the Work and of the Contract Documents.
- § 3.12.7 The Contractor shall perform no portion of the Work for which the Contract Documents require submittal and review of Shop Drawings, Product Data, Samples, or similar submittals, until the respective submittal has been approved by the Architect.
- § 3.12.8 The Work shall be in accordance with approved submittals except that the Contractor shall not be relieved of responsibility for deviations from the requirements of the Contract Documents by the Architect's approval of Shop Drawings, Product Data, Samples, or similar submittals, unless the Contractor has specifically notified the Architect of such deviation at the time of submittal and (1) the Architect has given written approval to the specific deviation as a minor change in the Work, or (2) a Change Order or Construction Change Directive has been issued authorizing the deviation. The Contractor shall not be relieved of responsibility for errors or omissions in Shop Drawings, Product Data, Samples, or similar submittals, by the Architect's approval thereof.
- § 3.12.9 The Contractor shall direct specific attention, in writing or on resubmitted Shop Drawings, Product Data, Samples, or similar submittals, to revisions other than those requested by the Architect on previous submittals. In the absence of such notice, the Architect's approval of a resubmission shall not apply to such revisions.
- § 3.12.10 The Contractor shall not be required to provide professional services that constitute the practice of architecture or engineering unless such services are specifically required by the Contract Documents for a portion of the Work or unless the Contractor needs to provide such services in order to carry out the Contractor's responsibilities for construction means, methods, techniques, sequences, and procedures. The Contractor shall not be required to provide professional services in violation of applicable law.
- § 3.12.10.1 If professional design services or certifications by a design professional related to systems, materials, or equipment are specifically required of the Contractor by the Contract Documents, the Owner and the Architect will

specify all performance and design criteria that such services must satisfy. The Contractor shall be entitled to rely upon the adequacy and accuracy of the performance and design criteria provided in the Contract Documents. The Contractor shall cause such services or certifications to be provided by an appropriately licensed design professional, whose signature and seal shall appear on all drawings, calculations, specifications, certifications, Shop Drawings, and other submittals prepared by such professional. Shop Drawings, and other submittals related to the Work, designed or certified by such professional, if prepared by others, shall bear such professional's written approval when submitted to the Architect. The Owner and the Architect shall be entitled to rely upon the adequacy and accuracy of the services, certifications, and approvals performed or provided by such design professionals, provided the Owner and Architect have specified to the Contractor the performance and design criteria that such services must satisfy. Pursuant to this Section 3.12.10, the Architect will review and approve or take other appropriate action on submittals only for the limited purpose of checking for conformance with information given and the design concept expressed in the Contract Documents.

§ 3.12.10.2 If the Contract Documents require the Contractor's design professional to certify that the Work has been performed in accordance with the design criteria, the Contractor shall furnish such certifications to the Architect at the time and in the form specified by the Architect.

§ 3.13 Use of Site

The Contractor shall confine operations at the site to areas permitted by applicable laws, statutes, ordinances, codes, rules and regulations, lawful orders of public authorities, and the Contract Documents and shall not unreasonably encumber the site with materials or equipment.

§ 3.14 Cutting and Patching

- § 3.14.1 The Contractor shall be responsible for cutting, fitting, or patching required to complete the Work or to make its parts fit together properly. All areas requiring cutting, fitting, or patching shall be restored to the condition existing prior to the cutting, fitting, or patching, unless otherwise required by the Contract Documents.
- § 3.14.2 The Contractor shall not damage or endanger a portion of the Work or fully or partially completed construction of the Owner or Separate Contractors by cutting, patching, or otherwise altering such construction, or by excavation. The Contractor shall not cut or otherwise alter construction by the Owner or a Separate Contractor except with written consent of the Owner and of the Separate Contractor. Consent shall not be unreasonably withheld. The Contractor shall not unreasonably withhold, from the Owner or a Separate Contractor, its consent to cutting or otherwise altering the Work.

§ 3.15 Cleaning Up

- § 3.15.1 The Contractor shall keep the premises and surrounding area free from accumulation of waste materials and rubbish caused by operations under the Contract. At completion of the Work, the Contractor shall remove waste materials, rubbish, the Contractor's tools, construction equipment, machinery, and surplus materials from and about the Project.
- § 3.15.2 If the Contractor fails to clean up as provided in the Contract Documents, the Owner may do so and the Owner shall be entitled to reimbursement from the Contractor.

§ 3.16 Access to Work

The Contractor shall provide the Owner and Architect with access to the Work in preparation and progress wherever located.

§ 3.17 Royalties, Patents and Copyrights

The Contractor shall pay all royalties and license fees. The Contractor shall defend suits or claims for infringement of copyrights and patent rights and shall hold the Owner and Architect harmless from loss on account thereof, but shall not be responsible for defense or loss when a particular design, process, or product of a particular manufacturer or manufacturers is required by the Contract Documents, or where the copyright violations are contained in Drawings, Specifications, or other documents prepared by the Owner or Architect. However, if an infringement of a copyright or patent is discovered by, or made known to, the Contractor, the Contractor shall be responsible for the loss unless the information is promptly furnished to the Architect.

§ 3.18 Indemnification

- § 3.18.1 To the fullest extent permitted by law, the Contractor shall indemnify and hold harmless the Owner, Architect, Architect's consultants, and agents and employees of any of them from and against claims, damages, losses, and expenses, including but not limited to attorneys' fees, arising out of or resulting from performance of the Work, provided that such claim, damage, loss, or expense is attributable to bodily injury, sickness, disease or death, or to injury to or destruction of tangible property (other than the Work itself), but only to the extent caused by the negligent acts or omissions of the Contractor, a Subcontractor, anyone directly or indirectly employed by them, or anyone for whose acts they may be liable, regardless of whether or not such claim, damage, loss, or expense is caused in part by a party indemnified hereunder. Such obligation shall not be construed to negate, abridge, or reduce other rights or obligations of indemnity that would otherwise exist as to a party or person described in this Section 3.18.
- § 3.18.2 In claims against any person or entity indemnified under this Section 3.18 by an employee of the Contractor, a Subcontractor, anyone directly or indirectly employed by them, or anyone for whose acts they may be liable, the indemnification obligation under Section 3.18.1 shall not be limited by a limitation on amount or type of damages, compensation, or benefits payable by or for the Contractor or a Subcontractor under workers' compensation acts, disability benefit acts, or other employee benefit acts.

ARTICLE 4 ARCHITECT

§ 4.1 General

- § 4.1.1 The Architect is the person or entity retained by the Owner pursuant to Section 2.3.2 and identified as such in the Agreement.
- § 4.1.2 Duties, responsibilities, and limitations of authority of the Architect as set forth in the Contract Documents shall not be restricted, modified, or extended without written consent of the Owner, Contractor, and Architect. Consent shall not be unreasonably withheld.

§ 4.2 Administration of the Contract

- § 4.2.1 The Architect will provide administration of the Contract as described in the Contract Documents and will be an Owner's representative during construction until the date the Architect issues the final Certificate for Payment. The Architect will have authority to act on behalf of the Owner only to the extent provided in the Contract Documents.
- § 4.2.2 The Architect will visit the site at intervals appropriate to the stage of construction, or as otherwise agreed with the Owner, to become generally familiar with the progress and quality of the portion of the Work completed, and to determine in general if the Work observed is being performed in a manner indicating that the Work, when fully completed, will be in accordance with the Contract Documents. However, the Architect will not be required to make exhaustive or continuous on-site inspections to check the quality or quantity of the Work. The Architect will not have control over, charge of, or responsibility for the construction means, methods, techniques, sequences or procedures, or for the safety precautions and programs in connection with the Work, since these are solely the Contractor's rights and responsibilities under the Contract Documents.
- § 4.2.3 On the basis of the site visits, the Architect will keep the Owner reasonably informed about the progress and quality of the portion of the Work completed, and promptly report to the Owner (1) known deviations from the Contract Documents, (2) known deviations from the most recent construction schedule submitted by the Contractor, and (3) defects and deficiencies observed in the Work. The Architect will not be responsible for the Contractor's failure to perform the Work in accordance with the requirements of the Contract Documents. The Architect will not have control over or charge of, and will not be responsible for acts or omissions of, the Contractor, Subcontractors, or their agents or employees, or any other persons or entities performing portions of the Work.

§ 4.2.4 Communications

The Owner and Contractor shall include the Architect in all communications that relate to or affect the Architect's services or professional responsibilities. The Owner shall promptly notify the Architect of the substance of any direct communications between the Owner and the Contractor otherwise relating to the Project. Communications by and with the Architect's consultants shall be through the Architect. Communications by and with Subcontractors and suppliers shall be through the Contractor. Communications by and with Separate Contractors shall be through the Owner. The Contract Documents may specify other communication protocols.

- § 4.2.5 Based on the Architect's evaluations of the Contractor's Applications for Payment, the Architect will review and certify the amounts due the Contractor and will issue Certificates for Payment in such amounts.
- § 4.2.6 The Architect has authority to reject Work that does not conform to the Contract Documents. Whenever the Architect considers it necessary or advisable, the Architect will have authority to require inspection or testing of the Work in accordance with Sections 13.4.2 and 13.4.3, whether or not the Work is fabricated, installed or completed. However, neither this authority of the Architect nor a decision made in good faith either to exercise or not to exercise such authority shall give rise to a duty or responsibility of the Architect to the Contractor, Subcontractors, suppliers, their agents or employees, or other persons or entities performing portions of the Work.
- § 4.2.7 The Architect will review and approve, or take other appropriate action upon, the Contractor's submittals such as Shop Drawings, Product Data, and Samples, but only for the limited purpose of checking for conformance with information given and the design concept expressed in the Contract Documents. The Architect's action will be taken in accordance with the submittal schedule approved by the Architect or, in the absence of an approved submittal schedule, with reasonable promptness while allowing sufficient time in the Architect's professional judgment to permit adequate review. Review of such submittals is not conducted for the purpose of determining the accuracy and completeness of other details such as dimensions and quantities, or for substantiating instructions for installation or performance of equipment or systems, all of which remain the responsibility of the Contractor as required by the Contract Documents. The Architect's review of the Contractor's submittals shall not relieve the Contractor of the obligations under Sections 3.3, 3.5, and 3.12. The Architect's review shall not constitute approval of safety precautions or of any construction means, methods, techniques, sequences, or procedures. The Architect's approval of a specific item shall not indicate approval of an assembly of which the item is a component.
- § 4.2.8 The Architect will prepare Change Orders and Construction Change Directives, and may order minor changes in the Work as provided in Section 7.4. The Architect will investigate and make determinations and recommendations regarding concealed and unknown conditions as provided in Section 3.7.4.
- § 4.2.9 The Architect will conduct inspections to determine the date or dates of Substantial Completion and the date of final completion; issue Certificates of Substantial Completion pursuant to Section 9.8; receive and forward to the Owner, for the Owner's review and records, written warranties and related documents required by the Contract and assembled by the Contractor pursuant to Section 9.10; and issue a final Certificate for Payment pursuant to Section 9.10.
- § 4.2.10 If the Owner and Architect agree, the Architect will provide one or more Project representatives to assist in carrying out the Architect's responsibilities at the site. The Owner shall notify the Contractor of any change in the duties, responsibilities and limitations of authority of the Project representatives.
- § 4.2.11 The Architect will interpret and decide matters concerning performance under, and requirements of, the Contract Documents on written request of either the Owner or Contractor. The Architect's response to such requests will be made in writing within any time limits agreed upon or otherwise with reasonable promptness.
- § 4.2.12 Interpretations and decisions of the Architect will be consistent with the intent of, and reasonably inferable from, the Contract Documents and will be in writing or in the form of drawings. When making such interpretations and decisions, the Architect will endeavor to secure faithful performance by both Owner and Contractor, will not show partiality to either, and will not be liable for results of interpretations or decisions rendered in good faith.
- § 4.2.13 The Architect's decisions on matters relating to aesthetic effect will be final if consistent with the intent expressed in the Contract Documents.
- § 4.2.14 The Architect will review and respond to requests for information about the Contract Documents. The Architect's response to such requests will be made in writing within any time limits agreed upon or otherwise with reasonable promptness. If appropriate, the Architect will prepare and issue supplemental Drawings and Specifications in response to the requests for information.

User Notes:

ARTICLE 5 **SUBCONTRACTORS**

§ 5.1 Definitions

- § 5.1.1 A Subcontractor is a person or entity who has a direct contract with the Contractor to perform a portion of the Work at the site. The term "Subcontractor" is referred to throughout the Contract Documents as if singular in number and means a Subcontractor or an authorized representative of the Subcontractor. The term "Subcontractor" does not include a Separate Contractor or the subcontractors of a Separate Contractor.
- § 5.1.2 A Sub-subcontractor is a person or entity who has a direct or indirect contract with a Subcontractor to perform a portion of the Work at the site. The term "Sub-subcontractor" is referred to throughout the Contract Documents as if singular in number and means a Sub-subcontractor or an authorized representative of the Sub-subcontractor.

§ 5.2 Award of Subcontracts and Other Contracts for Portions of the Work

- § 5.2.1 Unless otherwise stated in the Contract Documents, the Contractor, as soon as practicable after award of the Contract, shall notify the Owner and Architect of the persons or entities proposed for each principal portion of the Work, including those who are to furnish materials or equipment fabricated to a special design. Within 14 days of receipt of the information, the Architect may notify the Contractor whether the Owner or the Architect (1) has reasonable objection to any such proposed person or entity or (2) requires additional time for review. Failure of the Architect to provide notice within the 14-day period shall constitute notice of no reasonable objection.
- § 5.2.2 The Contractor shall not contract with a proposed person or entity to whom the Owner or Architect has made reasonable and timely objection. The Contractor shall not be required to contract with anyone to whom the Contractor has made reasonable objection.
- § 5.2.3 If the Owner or Architect has reasonable objection to a person or entity proposed by the Contractor, the Contractor shall propose another to whom the Owner or Architect has no reasonable objection. If the proposed but rejected Subcontractor was reasonably capable of performing the Work, the Contract Sum and Contract Time shall be increased or decreased by the difference, if any, occasioned by such change, and an appropriate Change Order shall be issued before commencement of the substitute Subcontractor's Work. However, no increase in the Contract Sum or Contract Time shall be allowed for such change unless the Contractor has acted promptly and responsively in submitting names as required.
- § 5.2.4 The Contractor shall not substitute a Subcontractor, person, or entity for one previously selected if the Owner or Architect makes reasonable objection to such substitution.

§ 5.3 Subcontractual Relations

By appropriate written agreement, the Contractor shall require each Subcontractor, to the extent of the Work to be performed by the Subcontractor, to be bound to the Contractor by terms of the Contract Documents, and to assume toward the Contractor all the obligations and responsibilities, including the responsibility for safety of the Subcontractor's Work that the Contractor, by these Contract Documents, assumes toward the Owner and Architect. Each subcontract agreement shall preserve and protect the rights of the Owner and Architect under the Contract Documents with respect to the Work to be performed by the Subcontractor so that subcontracting thereof will not prejudice such rights, and shall allow to the Subcontractor, unless specifically provided otherwise in the subcontract agreement, the benefit of all rights, remedies, and redress against the Contractor that the Contractor, by the Contract Documents, has against the Owner. Where appropriate, the Contractor shall require each Subcontractor to enter into similar agreements with Sub-subcontractors. The Contractor shall make available to each proposed Subcontractor, prior to the execution of the subcontract agreement, copies of the Contract Documents to which the Subcontractor will be bound, and, upon written request of the Subcontractor, identify to the Subcontractor terms and conditions of the proposed subcontract agreement that may be at variance with the Contract Documents. Subcontractors will similarly make copies of applicable portions of such documents available to their respective proposed Sub-subcontractors.

§ 5.4 Contingent Assignment of Subcontracts

- § 5.4.1 Each subcontract agreement for a portion of the Work is assigned by the Contractor to the Owner, provided that
 - assignment is effective only after termination of the Contract by the Owner for cause pursuant to Section 14.2 and only for those subcontract agreements that the Owner accepts by notifying the Subcontractor and Contractor; and
 - .2 assignment is subject to the prior rights of the surety, if any, obligated under bond relating to the

When the Owner accepts the assignment of a subcontract agreement, the Owner assumes the Contractor's rights and obligations under the subcontract.

- § 5.4.2 Upon such assignment, if the Work has been suspended for more than 30 days, the Subcontractor's compensation shall be equitably adjusted for increases in cost resulting from the suspension.
- § 5.4.3 Upon assignment to the Owner under this Section 5.4, the Owner may further assign the subcontract to a successor contractor or other entity. If the Owner assigns the subcontract to a successor contractor or other entity, the Owner shall nevertheless remain legally responsible for all of the successor contractor's obligations under the subcontract.

ARTICLE 6 CONSTRUCTION BY OWNER OR BY SEPARATE CONTRACTORS

- § 6.1 Owner's Right to Perform Construction and to Award Separate Contracts
- § 6.1.1 The term "Separate Contractor(s)" shall mean other contractors retained by the Owner under separate agreements. The Owner reserves the right to perform construction or operations related to the Project with the Owner's own forces, and with Separate Contractors retained under Conditions of the Contract substantially similar to those of this Contract, including those provisions of the Conditions of the Contract related to insurance and waiver of subrogation.
- § 6.1.2 When separate contracts are awarded for different portions of the Project or other construction or operations on the site, the term "Contractor" in the Contract Documents in each case shall mean the Contractor who executes each separate Owner-Contractor Agreement.
- § 6.1.3 The Owner shall provide for coordination of the activities of the Owner's own forces and of each Separate Contractor with the Work of the Contractor, who shall cooperate with them. The Contractor shall participate with any Separate Contractors and the Owner in reviewing their construction schedules. The Contractor shall make any revisions to its construction schedule deemed necessary after a joint review and mutual agreement. The construction schedules shall then constitute the schedules to be used by the Contractor, Separate Contractors, and the Owner until subsequently revised.
- § 6.1.4 Unless otherwise provided in the Contract Documents, when the Owner performs construction or operations related to the Project with the Owner's own forces or with Separate Contractors, the Owner or its Separate Contractors shall have the same obligations and rights that the Contractor has under the Conditions of the Contract, including, without excluding others, those stated in Article 3, this Article 6, and Articles 10, 11, and 12.

§ 6.2 Mutual Responsibility

- § 6.2.1 The Contractor shall afford the Owner and Separate Contractors reasonable opportunity for introduction and storage of their materials and equipment and performance of their activities, and shall connect and coordinate the Contractor's construction and operations with theirs as required by the Contract Documents.
- § 6.2.2 If part of the Contractor's Work depends for proper execution or results upon construction or operations by the Owner or a Separate Contractor, the Contractor shall, prior to proceeding with that portion of the Work, promptly notify the Architect of apparent discrepancies or defects in the construction or operations by the Owner or Separate Contractor that would render it unsuitable for proper execution and results of the Contractor's Work. Failure of the Contractor to notify the Architect of apparent discrepancies or defects prior to proceeding with the Work shall constitute an acknowledgment that the Owner's or Separate Contractor's completed or partially completed construction is fit and proper to receive the Contractor's Work. The Contractor shall not be responsible for discrepancies or defects in the construction or operations by the Owner or Separate Contractor that are not apparent.
- § 6.2.3 The Contractor shall reimburse the Owner for costs the Owner incurs that are payable to a Separate Contractor because of the Contractor's delays, improperly timed activities or defective construction. The Owner shall be responsible to the Contractor for costs the Contractor incurs because of a Separate Contractor's delays, improperly timed activities, damage to the Work or defective construction.
- § 6.2.4 The Contractor shall promptly remedy damage that the Contractor wrongfully causes to completed or partially completed construction or to property of the Owner or Separate Contractor as provided in Section 10.2.5.

§ 6.2.5 The Owner and each Separate Contractor shall have the same responsibilities for cutting and patching as are described for the Contractor in Section 3.14.

§ 6.3 Owner's Right to Clean Up

If a dispute arises among the Contractor, Separate Contractors, and the Owner as to the responsibility under their respective contracts for maintaining the premises and surrounding area free from waste materials and rubbish, the Owner may clean up and the Architect will allocate the cost among those responsible.

ARTICLE 7 CHANGES IN THE WORK

§ 7.1 General

- § 7.1.1 Changes in the Work may be accomplished after execution of the Contract, and without invalidating the Contract, by Change Order, Construction Change Directive or order for a minor change in the Work, subject to the limitations stated in this Article 7 and elsewhere in the Contract Documents.
- § 7.1.2 A Change Order shall be based upon agreement among the Owner, Contractor, and Architect. A Construction Change Directive requires agreement by the Owner and Architect and may or may not be agreed to by the Contractor. An order for a minor change in the Work may be issued by the Architect alone.
- § 7.1.3 Changes in the Work shall be performed under applicable provisions of the Contract Documents. The Contractor shall proceed promptly with changes in the Work, unless otherwise provided in the Change Order, Construction Change Directive, or order for a minor change in the Work.

§ 7.2 Change Orders

- § 7.2.1 A Change Order is a written instrument prepared by the Architect and signed by the Owner, Contractor, and Architect stating their agreement upon all of the following:
 - .1 The change in the Work;
 - .2 The amount of the adjustment, if any, in the Contract Sum; and
 - .3 The extent of the adjustment, if any, in the Contract Time.

§ 7.3 Construction Change Directives

- § 7.3.1 A Construction Change Directive is a written order prepared by the Architect and signed by the Owner and Architect, directing a change in the Work prior to agreement on adjustment, if any, in the Contract Sum or Contract Time, or both. The Owner may by Construction Change Directive, without invalidating the Contract, order changes in the Work within the general scope of the Contract consisting of additions, deletions, or other revisions, the Contract Sum and Contract Time being adjusted accordingly.
- § 7.3.2 A Construction Change Directive shall be used in the absence of total agreement on the terms of a Change Order.
- § 7.3.3 If the Construction Change Directive provides for an adjustment to the Contract Sum, the adjustment shall be based on one of the following methods:
 - .1 Mutual acceptance of a lump sum properly itemized and supported by sufficient substantiating data to permit evaluation;
 - .2 Unit prices stated in the Contract Documents or subsequently agreed upon;
 - .3 Cost to be determined in a manner agreed upon by the parties and a mutually acceptable fixed or percentage fee; or
 - .4 As provided in Section 7.3.4.
- § 7.3.4 If the Contractor does not respond promptly or disagrees with the method for adjustment in the Contract Sum, the Architect shall determine the adjustment on the basis of reasonable expenditures and savings of those performing the Work attributable to the change, including, in case of an increase in the Contract Sum, an amount for overhead and profit as set forth in the Agreement, or if no such amount is set forth in the Agreement, a reasonable amount. In such case, and also under Section 7.3.3.3, the Contractor shall keep and present, in such form as the Architect may prescribe, an itemized accounting together with appropriate supporting data. Unless otherwise provided in the Contract Documents, costs for the purposes of this Section 7.3.4 shall be limited to the following:

User Notes:

- .1 Costs of labor, including applicable payroll taxes, fringe benefits required by agreement or custom, workers' compensation insurance, and other employee costs approved by the Architect;
- .2 Costs of materials, supplies, and equipment, including cost of transportation, whether incorporated or consumed:
- .3 Rental costs of machinery and equipment, exclusive of hand tools, whether rented from the Contractor or others;
- .4 Costs of premiums for all bonds and insurance, permit fees, and sales, use, or similar taxes, directly related to the change; and
- .5 Costs of supervision and field office personnel directly attributable to the change.
- § 7.3.5 If the Contractor disagrees with the adjustment in the Contract Time, the Contractor may make a Claim in accordance with applicable provisions of Article 15.
- § 7.3.6 Upon receipt of a Construction Change Directive, the Contractor shall promptly proceed with the change in the Work involved and advise the Architect of the Contractor's agreement or disagreement with the method, if any, provided in the Construction Change Directive for determining the proposed adjustment in the Contract Sum or Contract Time.
- § 7.3.7 A Construction Change Directive signed by the Contractor indicates the Contractor's agreement therewith, including adjustment in Contract Sum and Contract Time or the method for determining them. Such agreement shall be effective immediately and shall be recorded as a Change Order.
- § 7.3.8 The amount of credit to be allowed by the Contractor to the Owner for a deletion or change that results in a net decrease in the Contract Sum shall be actual net cost as confirmed by the Architect. When both additions and credits covering related Work or substitutions are involved in a change, the allowance for overhead and profit shall be figured on the basis of net increase, if any, with respect to that change.
- § 7.3.9 Pending final determination of the total cost of a Construction Change Directive to the Owner, the Contractor may request payment for Work completed under the Construction Change Directive in Applications for Payment. The Architect will make an interim determination for purposes of monthly certification for payment for those costs and certify for payment the amount that the Architect determines, in the Architect's professional judgment, to be reasonably justified. The Architect's interim determination of cost shall adjust the Contract Sum on the same basis as a Change Order, subject to the right of either party to disagree and assert a Claim in accordance with Article 15.
- § 7.3.10 When the Owner and Contractor agree with a determination made by the Architect concerning the adjustments in the Contract Sum and Contract Time, or otherwise reach agreement upon the adjustments, such agreement shall be effective immediately and the Architect will prepare a Change Order. Change Orders may be issued for all or any part of a Construction Change Directive.

§ 7.4 Minor Changes in the Work

The Architect may order minor changes in the Work that are consistent with the intent of the Contract Documents and do not involve an adjustment in the Contract Sum or an extension of the Contract Time. The Architect's order for minor changes shall be in writing. If the Contractor believes that the proposed minor change in the Work will affect the Contract Sum or Contract Time, the Contractor shall notify the Architect and shall not proceed to implement the change in the Work. If the Contractor performs the Work set forth in the Architect's order for a minor change without prior notice to the Architect that such change will affect the Contract Sum or Contract Time, the Contractor waives any adjustment to the Contract Sum or extension of the Contract Time.

ARTICLE 8 TIME

§ 8.1 Definitions

- **§ 8.1.1** Unless otherwise provided, Contract Time is the period of time, including authorized adjustments, allotted in the Contract Documents for Substantial Completion of the Work.
- § 8.1.2 The date of commencement of the Work is the date established in the Agreement.
- § 8.1.3 The date of Substantial Completion is the date certified by the Architect in accordance with Section 9.8.

§ 8.1.4 The term "day" as used in the Contract Documents shall mean calendar day unless otherwise specifically defined.

§ 8.2 Progress and Completion

- § 8.2.1 Time limits stated in the Contract Documents are of the essence of the Contract. By executing the Agreement, the Contractor confirms that the Contract Time is a reasonable period for performing the Work.
- § 8.2.2 The Contractor shall not knowingly, except by agreement or instruction of the Owner in writing, commence the Work prior to the effective date of insurance required to be furnished by the Contractor and Owner.
- § 8.2.3 The Contractor shall proceed expeditiously with adequate forces and shall achieve Substantial Completion within the Contract Time.

§ 8.3 Delays and Extensions of Time

- § 8.3.1 If the Contractor is delayed at any time in the commencement or progress of the Work by (1) an act or neglect of the Owner or Architect, of an employee of either, or of a Separate Contractor; (2) by changes ordered in the Work; (3) by labor disputes, fire, unusual delay in deliveries, unavoidable casualties, adverse weather conditions documented in accordance with Section 15.1.6.2, or other causes beyond the Contractor's control; (4) by delay authorized by the Owner pending mediation and binding dispute resolution; or (5) by other causes that the Contractor asserts, and the Architect determines, justify delay, then the Contract Time shall be extended for such reasonable time as the Architect may determine.
- § 8.3.2 Claims relating to time shall be made in accordance with applicable provisions of Article 15.
- § 8.3.3 This Section 8.3 does not preclude recovery of damages for delay by either party under other provisions of the Contract Documents.

ARTICLE 9 PAYMENTS AND COMPLETION

§ 9.1 Contract Sum

- § 9.1.1 The Contract Sum is stated in the Agreement and, including authorized adjustments, is the total amount payable by the Owner to the Contractor for performance of the Work under the Contract Documents.
- § 9.1.2 If unit prices are stated in the Contract Documents or subsequently agreed upon, and if quantities originally contemplated are materially changed so that application of such unit prices to the actual quantities causes substantial inequity to the Owner or Contractor, the applicable unit prices shall be equitably adjusted.

§ 9.2 Schedule of Values

Where the Contract is based on a stipulated sum or Guaranteed Maximum Price, the Contractor shall submit a schedule of values to the Architect before the first Application for Payment, allocating the entire Contract Sum to the various portions of the Work. The schedule of values shall be prepared in the form, and supported by the data to substantiate its accuracy, required by the Architect. This schedule, unless objected to by the Architect, shall be used as a basis for reviewing the Contractor's Applications for Payment. Any changes to the schedule of values shall be submitted to the Architect and supported by such data to substantiate its accuracy as the Architect may require, and unless objected to by the Architect, shall be used as a basis for reviewing the Contractor's subsequent Applications for Payment.

§ 9.3 Applications for Payment

- § 9.3.1 At least ten days before the date established for each progress payment, the Contractor shall submit to the Architect an itemized Application for Payment prepared in accordance with the schedule of values, if required under Section 9.2, for completed portions of the Work. The application shall be notarized, if required, and supported by all data substantiating the Contractor's right to payment that the Owner or Architect require, such as copies of requisitions, and releases and waivers of liens from Subcontractors and suppliers, and shall reflect retainage if provided for in the Contract Documents.
- § 9.3.1.1 As provided in Section 7.3.9, such applications may include requests for payment on account of changes in the Work that have been properly authorized by Construction Change Directives, or by interim determinations of the Architect, but not yet included in Change Orders.

- § 9.3.1.2 Applications for Payment shall not include requests for payment for portions of the Work for which the Contractor does not intend to pay a Subcontractor or supplier, unless such Work has been performed by others whom the Contractor intends to pay.
- § 9.3.2 Unless otherwise provided in the Contract Documents, payments shall be made on account of materials and equipment delivered and suitably stored at the site for subsequent incorporation in the Work. If approved in advance by the Owner, payment may similarly be made for materials and equipment suitably stored off the site at a location agreed upon in writing. Payment for materials and equipment stored on or off the site shall be conditioned upon compliance by the Contractor with procedures satisfactory to the Owner to establish the Owner's title to such materials and equipment or otherwise protect the Owner's interest, and shall include the costs of applicable insurance, storage, and transportation to the site, for such materials and equipment stored off the site.
- § 9.3.3 The Contractor warrants that title to all Work covered by an Application for Payment will pass to the Owner no later than the time of payment. The Contractor further warrants that upon submittal of an Application for Payment all Work for which Certificates for Payment have been previously issued and payments received from the Owner shall, to the best of the Contractor's knowledge, information, and belief, be free and clear of liens, claims, security interests, or encumbrances, in favor of the Contractor, Subcontractors, suppliers, or other persons or entities that provided labor, materials, and equipment relating to the Work.

§ 9.4 Certificates for Payment

- § 9.4.1 The Architect will, within seven days after receipt of the Contractor's Application for Payment, either (1) issue to the Owner a Certificate for Payment in the full amount of the Application for Payment, with a copy to the Contractor; or (2) issue to the Owner a Certificate for Payment for such amount as the Architect determines is properly due, and notify the Contractor and Owner of the Architect's reasons for withholding certification in part as provided in Section 9.5.1; or (3) withhold certification of the entire Application for Payment, and notify the Contractor and Owner of the Architect's reason for withholding certification in whole as provided in Section 9.5.1.
- § 9.4.2 The issuance of a Certificate for Payment will constitute a representation by the Architect to the Owner, based on the Architect's evaluation of the Work and the data in the Application for Payment, that, to the best of the Architect's knowledge, information, and belief, the Work has progressed to the point indicated, the quality of the Work is in accordance with the Contract Documents, and that the Contractor is entitled to payment in the amount certified. The foregoing representations are subject to an evaluation of the Work for conformance with the Contract Documents upon Substantial Completion, to results of subsequent tests and inspections, to correction of minor deviations from the Contract Documents prior to completion, and to specific qualifications expressed by the Architect. However, the issuance of a Certificate for Payment will not be a representation that the Architect has (1) made exhaustive or continuous on-site inspections to check the quality or quantity of the Work; (2) reviewed construction means, methods, techniques, sequences, or procedures; (3) reviewed copies of requisitions received from Subcontractors and suppliers and other data requested by the Owner to substantiate the Contractor's right to payment; or (4) made examination to ascertain how or for what purpose the Contractor has used money previously paid on account of the Contract Sum.

§ 9.5 Decisions to Withhold Certification

- § 9.5.1 The Architect may withhold a Certificate for Payment in whole or in part, to the extent reasonably necessary to protect the Owner, if in the Architect's opinion the representations to the Owner required by Section 9.4.2 cannot be made. If the Architect is unable to certify payment in the amount of the Application, the Architect will notify the Contractor and Owner as provided in Section 9.4.1. If the Contractor and Architect cannot agree on a revised amount, the Architect will promptly issue a Certificate for Payment for the amount for which the Architect is able to make such representations to the Owner. The Architect may also withhold a Certificate for Payment or, because of subsequently discovered evidence, may nullify the whole or a part of a Certificate for Payment previously issued, to such extent as may be necessary in the Architect's opinion to protect the Owner from loss for which the Contractor is responsible, including loss resulting from acts and omissions described in Section 3.3.2, because of
 - .1 defective Work not remedied;
 - .2 third party claims filed or reasonable evidence indicating probable filing of such claims, unless security acceptable to the Owner is provided by the Contractor;
 - **.3** failure of the Contractor to make payments properly to Subcontractors or suppliers for labor, materials or equipment;

- reasonable evidence that the Work cannot be completed for the unpaid balance of the Contract Sum; .4
- .5 damage to the Owner or a Separate Contractor;
- .6 reasonable evidence that the Work will not be completed within the Contract Time, and that the unpaid balance would not be adequate to cover actual or liquidated damages for the anticipated delay; or
- .7 repeated failure to carry out the Work in accordance with the Contract Documents.
- § 9.5.2 When either party disputes the Architect's decision regarding a Certificate for Payment under Section 9.5.1, in whole or in part, that party may submit a Claim in accordance with Article 15.
- § 9.5.3 When the reasons for withholding certification are removed, certification will be made for amounts previously withheld.
- § 9.5.4 If the Architect withholds certification for payment under Section 9.5.1.3, the Owner may, at its sole option, issue joint checks to the Contractor and to any Subcontractor or supplier to whom the Contractor failed to make payment for Work properly performed or material or equipment suitably delivered. If the Owner makes payments by joint check, the Owner shall notify the Architect and the Contractor shall reflect such payment on its next Application for Payment.

§ 9.6 Progress Payments

- § 9.6.1 After the Architect has issued a Certificate for Payment, the Owner shall make payment in the manner and within the time provided in the Contract Documents, and shall so notify the Architect.
- § 9.6.2 The Contractor shall pay each Subcontractor, no later than seven days after receipt of payment from the Owner, the amount to which the Subcontractor is entitled, reflecting percentages actually retained from payments to the Contractor on account of the Subcontractor's portion of the Work. The Contractor shall, by appropriate agreement with each Subcontractor, require each Subcontractor to make payments to Sub-subcontractors in a similar manner.
- § 9.6.3 The Architect will, on request, furnish to a Subcontractor, if practicable, information regarding percentages of completion or amounts applied for by the Contractor and action taken thereon by the Architect and Owner on account of portions of the Work done by such Subcontractor.
- § 9.6.4 The Owner has the right to request written evidence from the Contractor that the Contractor has properly paid Subcontractors and suppliers amounts paid by the Owner to the Contractor for subcontracted Work. If the Contractor fails to furnish such evidence within seven days, the Owner shall have the right to contact Subcontractors and suppliers to ascertain whether they have been properly paid. Neither the Owner nor Architect shall have an obligation to pay, or to see to the payment of money to, a Subcontractor or supplier, except as may otherwise be required by law.
- § 9.6.5 The Contractor's payments to suppliers shall be treated in a manner similar to that provided in Sections 9.6.2, 9.6.3 and 9.6.4.
- § 9.6.6 A Certificate for Payment, a progress payment, or partial or entire use or occupancy of the Project by the Owner shall not constitute acceptance of Work not in accordance with the Contract Documents.
- § 9.6.7 Unless the Contractor provides the Owner with a payment bond in the full penal sum of the Contract Sum, payments received by the Contractor for Work properly performed by Subcontractors or provided by suppliers shall be held by the Contractor for those Subcontractors or suppliers who performed Work or furnished materials, or both, under contract with the Contractor for which payment was made by the Owner. Nothing contained herein shall require money to be placed in a separate account and not commingled with money of the Contractor, create any fiduciary liability or tort liability on the part of the Contractor for breach of trust, or entitle any person or entity to an award of punitive damages against the Contractor for breach of the requirements of this provision.
- § 9.6.8 Provided the Owner has fulfilled its payment obligations under the Contract Documents, the Contractor shall defend and indemnify the Owner from all loss, liability, damage or expense, including reasonable attorney's fees and litigation expenses, arising out of any lien claim or other claim for payment by any Subcontractor or supplier of any tier. Upon receipt of notice of a lien claim or other claim for payment, the Owner shall notify the Contractor. If approved by the applicable court, when required, the Contractor may substitute a surety bond for the property against which the lien or other claim for payment has been asserted.

§ 9.7 Failure of Payment

If the Architect does not issue a Certificate for Payment, through no fault of the Contractor, within seven days after receipt of the Contractor's Application for Payment, or if the Owner does not pay the Contractor within seven days after the date established in the Contract Documents, the amount certified by the Architect or awarded by binding dispute resolution, then the Contractor may, upon seven additional days' notice to the Owner and Architect, stop the Work until payment of the amount owing has been received. The Contract Time shall be extended appropriately and the Contract Sum shall be increased by the amount of the Contractor's reasonable costs of shutdown, delay and start-up, plus interest as provided for in the Contract Documents.

§ 9.8 Substantial Completion

- § 9.8.1 Substantial Completion is the stage in the progress of the Work when the Work or designated portion thereof is sufficiently complete in accordance with the Contract Documents so that the Owner can occupy or utilize the Work for its intended use.
- § 9.8.2 When the Contractor considers that the Work, or a portion thereof which the Owner agrees to accept separately, is substantially complete, the Contractor shall prepare and submit to the Architect a comprehensive list of items to be completed or corrected prior to final payment. Failure to include an item on such list does not alter the responsibility of the Contractor to complete all Work in accordance with the Contract Documents.
- § 9.8.3 Upon receipt of the Contractor's list, the Architect will make an inspection to determine whether the Work or designated portion thereof is substantially complete. If the Architect's inspection discloses any item, whether or not included on the Contractor's list, which is not sufficiently complete in accordance with the Contract Documents so that the Owner can occupy or utilize the Work or designated portion thereof for its intended use, the Contractor shall, before issuance of the Certificate of Substantial Completion, complete or correct such item upon notification by the Architect. In such case, the Contractor shall then submit a request for another inspection by the Architect to determine Substantial Completion.
- § 9.8.4 When the Work or designated portion thereof is substantially complete, the Architect will prepare a Certificate of Substantial Completion that shall establish the date of Substantial Completion; establish responsibilities of the Owner and Contractor for security, maintenance, heat, utilities, damage to the Work and insurance; and fix the time within which the Contractor shall finish all items on the list accompanying the Certificate. Warranties required by the Contract Documents shall commence on the date of Substantial Completion of the Work or designated portion thereof unless otherwise provided in the Certificate of Substantial Completion.
- § 9.8.5 The Certificate of Substantial Completion shall be submitted to the Owner and Contractor for their written acceptance of responsibilities assigned to them in the Certificate. Upon such acceptance, and consent of surety if any, the Owner shall make payment of retainage applying to the Work or designated portion thereof. Such payment shall be adjusted for Work that is incomplete or not in accordance with the requirements of the Contract Documents.

§ 9.9 Partial Occupancy or Use

- § 9.9.1 The Owner may occupy or use any completed or partially completed portion of the Work at any stage when such portion is designated by separate agreement with the Contractor, provided such occupancy or use is consented to by the insurer and authorized by public authorities having jurisdiction over the Project. Such partial occupancy or use may commence whether or not the portion is substantially complete, provided the Owner and Contractor have accepted in writing the responsibilities assigned to each of them for payments, retainage, if any, security, maintenance, heat, utilities, damage to the Work and insurance, and have agreed in writing concerning the period for correction of the Work and commencement of warranties required by the Contract Documents. When the Contractor considers a portion substantially complete, the Contractor shall prepare and submit a list to the Architect as provided under Section 9.8.2. Consent of the Contractor to partial occupancy or use shall not be unreasonably withheld. The stage of the progress of the Work shall be determined by written agreement between the Owner and Contractor or, if no agreement is reached, by decision of the Architect.
- § 9.9.2 Immediately prior to such partial occupancy or use, the Owner, Contractor, and Architect shall jointly inspect the area to be occupied or portion of the Work to be used in order to determine and record the condition of the Work.

User Notes:

§ 9.9.3 Unless otherwise agreed upon, partial occupancy or use of a portion or portions of the Work shall not constitute acceptance of Work not complying with the requirements of the Contract Documents.

§ 9.10 Final Completion and Final Payment

§ 9.10.1 Upon receipt of the Contractor's notice that the Work is ready for final inspection and acceptance and upon receipt of a final Application for Payment, the Architect will promptly make such inspection. When the Architect finds the Work acceptable under the Contract Documents and the Contract fully performed, the Architect will promptly issue a final Certificate for Payment stating that to the best of the Architect's knowledge, information and belief, and on the basis of the Architect's on-site visits and inspections, the Work has been completed in accordance with the Contract Documents and that the entire balance found to be due the Contractor and noted in the final Certificate is due and payable. The Architect's final Certificate for Payment will constitute a further representation that conditions listed in Section 9.10.2 as precedent to the Contractor's being entitled to final payment have been fulfilled.

§ 9.10.2 Neither final payment nor any remaining retained percentage shall become due until the Contractor submits to the Architect (1) an affidavit that payrolls, bills for materials and equipment, and other indebtedness connected with the Work for which the Owner or the Owner's property might be responsible or encumbered (less amounts withheld by Owner) have been paid or otherwise satisfied, (2) a certificate evidencing that insurance required by the Contract Documents to remain in force after final payment is currently in effect, (3) a written statement that the Contractor knows of no reason that the insurance will not be renewable to cover the period required by the Contract Documents, (4) consent of surety, if any, to final payment, (5) documentation of any special warranties, such as manufacturers' warranties or specific Subcontractor warranties, and (6) if required by the Owner, other data establishing payment or satisfaction of obligations, such as receipts and releases and waivers of liens, claims, security interests, or encumbrances arising out of the Contract, to the extent and in such form as may be designated by the Owner. If a Subcontractor refuses to furnish a release or waiver required by the Owner, the Contractor may furnish a bond satisfactory to the Owner to indemnify the Owner against such lien, claim, security interest, or encumbrance. If a lien, claim, security interest, or encumbrance remains unsatisfied after payments are made, the Contractor shall refund to the Owner all money that the Owner may be compelled to pay in discharging the lien, claim, security interest, or encumbrance, including all costs and reasonable attorneys' fees.

§ 9.10.3 If, after Substantial Completion of the Work, final completion thereof is materially delayed through no fault of the Contractor or by issuance of Change Orders affecting final completion, and the Architect so confirms, the Owner shall, upon application by the Contractor and certification by the Architect, and without terminating the Contract, make payment of the balance due for that portion of the Work fully completed, corrected, and accepted. If the remaining balance for Work not fully completed or corrected is less than retainage stipulated in the Contract Documents, and if bonds have been furnished, the written consent of the surety to payment of the balance due for that portion of the Work fully completed and accepted shall be submitted by the Contractor to the Architect prior to certification of such payment. Such payment shall be made under terms and conditions governing final payment, except that it shall not constitute a waiver of Claims.

§ 9.10.4 The making of final payment shall constitute a waiver of Claims by the Owner except those arising from

- .1 liens, Claims, security interests, or encumbrances arising out of the Contract and unsettled;
- .2 failure of the Work to comply with the requirements of the Contract Documents;
- .3 terms of special warranties required by the Contract Documents; or
- .4 audits performed by the Owner, if permitted by the Contract Documents, after final payment.

§ 9.10.5 Acceptance of final payment by the Contractor, a Subcontractor, or a supplier, shall constitute a waiver of claims by that payee except those previously made in writing and identified by that payee as unsettled at the time of final Application for Payment.

ARTICLE 10 PROTECTION OF PERSONS AND PROPERTY

§ 10.1 Safety Precautions and Programs

The Contractor shall be responsible for initiating, maintaining, and supervising all safety precautions and programs in connection with the performance of the Contract.

§ 10.2 Safety of Persons and Property

§ 10.2.1 The Contractor shall take reasonable precautions for safety of, and shall provide reasonable protection to prevent damage, injury, or loss to

- employees on the Work and other persons who may be affected thereby; .1
- .2 the Work and materials and equipment to be incorporated therein, whether in storage on or off the site, under care, custody, or control of the Contractor, a Subcontractor, or a Sub-subcontractor; and
- .3 other property at the site or adjacent thereto, such as trees, shrubs, lawns, walks, pavements, roadways, structures, and utilities not designated for removal, relocation, or replacement in the course of construction.
- § 10.2.2 The Contractor shall comply with, and give notices required by applicable laws, statutes, ordinances, codes, rules and regulations, and lawful orders of public authorities, bearing on safety of persons or property or their protection from damage, injury, or loss.
- § 10.2.3 The Contractor shall implement, erect, and maintain, as required by existing conditions and performance of the Contract, reasonable safeguards for safety and protection, including posting danger signs and other warnings against hazards; promulgating safety regulations; and notifying the owners and users of adjacent sites and utilities of the safeguards.
- § 10.2.4 When use or storage of explosives or other hazardous materials or equipment, or unusual methods are necessary for execution of the Work, the Contractor shall exercise utmost care and carry on such activities under supervision of properly qualified personnel.
- § 10.2.5 The Contractor shall promptly remedy damage and loss (other than damage or loss insured under property insurance required by the Contract Documents) to property referred to in Sections 10.2.1.2 and 10.2.1.3 caused in whole or in part by the Contractor, a Subcontractor, a Sub-subcontractor, or anyone directly or indirectly employed by any of them, or by anyone for whose acts they may be liable and for which the Contractor is responsible under Sections 10.2.1.2 and 10.2.1.3. The Contractor may make a Claim for the cost to remedy the damage or loss to the extent such damage or loss is attributable to acts or omissions of the Owner or Architect or anyone directly or indirectly employed by either of them, or by anyone for whose acts either of them may be liable, and not attributable to the fault or negligence of the Contractor. The foregoing obligations of the Contractor are in addition to the Contractor's obligations under Section 3.18.
- § 10.2.6 The Contractor shall designate a responsible member of the Contractor's organization at the site whose duty shall be the prevention of accidents. This person shall be the Contractor's superintendent unless otherwise designated by the Contractor in writing to the Owner and Architect.
- § 10.2.7 The Contractor shall not permit any part of the construction or site to be loaded so as to cause damage or create an unsafe condition.

§ 10.2.8 Injury or Damage to Person or Property

If either party suffers injury or damage to person or property because of an act or omission of the other party, or of others for whose acts such party is legally responsible, notice of the injury or damage, whether or not insured, shall be given to the other party within a reasonable time not exceeding 21 days after discovery. The notice shall provide sufficient detail to enable the other party to investigate the matter.

§ 10.3 Hazardous Materials and Substances

- § 10.3.1 The Contractor is responsible for compliance with any requirements included in the Contract Documents regarding hazardous materials or substances. If the Contractor encounters a hazardous material or substance not addressed in the Contract Documents and if reasonable precautions will be inadequate to prevent foreseeable bodily injury or death to persons resulting from a material or substance, including but not limited to asbestos or polychlorinated biphenyl (PCB), encountered on the site by the Contractor, the Contractor shall, upon recognizing the condition, immediately stop Work in the affected area and notify the Owner and Architect of the condition.
- § 10.3.2 Upon receipt of the Contractor's notice, the Owner shall obtain the services of a licensed laboratory to verify the presence or absence of the material or substance reported by the Contractor and, in the event such material or substance is found to be present, to cause it to be rendered harmless. Unless otherwise required by the Contract Documents, the Owner shall furnish in writing to the Contractor and Architect the names and qualifications of persons or entities who are to perform tests verifying the presence or absence of the material or substance or who are to perform the task of removal or safe containment of the material or substance. The Contractor and the Architect will

promptly reply to the Owner in writing stating whether or not either has reasonable objection to the persons or entities proposed by the Owner. If either the Contractor or Architect has an objection to a person or entity proposed by the Owner, the Owner shall propose another to whom the Contractor and the Architect have no reasonable objection. When the material or substance has been rendered harmless, Work in the affected area shall resume upon written agreement of the Owner and Contractor. By Change Order, the Contract Time shall be extended appropriately and the Contract Sum shall be increased by the amount of the Contractor's reasonable additional costs of shutdown, delay, and start-up.

- § 10.3.3 To the fullest extent permitted by law, the Owner shall indemnify and hold harmless the Contractor, Subcontractors, Architect, Architect's consultants, and agents and employees of any of them from and against claims, damages, losses, and expenses, including but not limited to attorneys' fees, arising out of or resulting from performance of the Work in the affected area if in fact the material or substance presents the risk of bodily injury or death as described in Section 10.3.1 and has not been rendered harmless, provided that such claim, damage, loss, or expense is attributable to bodily injury, sickness, disease or death, or to injury to or destruction of tangible property (other than the Work itself), except to the extent that such damage, loss, or expense is due to the fault or negligence of the party seeking indemnity.
- § 10.3.4 The Owner shall not be responsible under this Section 10.3 for hazardous materials or substances the Contractor brings to the site unless such materials or substances are required by the Contract Documents. The Owner shall be responsible for hazardous materials or substances required by the Contract Documents, except to the extent of the Contractor's fault or negligence in the use and handling of such materials or substances.
- § 10.3.5 The Contractor shall reimburse the Owner for the cost and expense the Owner incurs (1) for remediation of hazardous materials or substances the Contractor brings to the site and negligently handles, or (2) where the Contractor fails to perform its obligations under Section 10.3.1, except to the extent that the cost and expense are due to the Owner's fault or negligence.
- § 10.3.6 If, without negligence on the part of the Contractor, the Contractor is held liable by a government agency for the cost of remediation of a hazardous material or substance solely by reason of performing Work as required by the Contract Documents, the Owner shall reimburse the Contractor for all cost and expense thereby incurred.

§ 10.4 Emergencies

In an emergency affecting safety of persons or property, the Contractor shall act, at the Contractor's discretion, to prevent threatened damage, injury, or loss. Additional compensation or extension of time claimed by the Contractor on account of an emergency shall be determined as provided in Article 15 and Article 7.

ARTICLE 11 INSURANCE AND BONDS

§ 11.1 Contractor's Insurance and Bonds

- § 11.1.1 The Contractor shall purchase and maintain insurance of the types and limits of liability, containing the endorsements, and subject to the terms and conditions, as described in the Agreement or elsewhere in the Contract Documents. The Contractor shall purchase and maintain the required insurance from an insurance company or insurance companies lawfully authorized to issue insurance in the jurisdiction where the Project is located. The Owner, Architect, and Architect's consultants shall be named as additional insureds under the Contractor's commercial general liability policy or as otherwise described in the Contract Documents.
- § 11.1.2 The Contractor shall provide surety bonds of the types, for such penal sums, and subject to such terms and conditions as required by the Contract Documents. The Contractor shall purchase and maintain the required bonds from a company or companies lawfully authorized to issue surety bonds in the jurisdiction where the Project is located.
- § 11.1.3 Upon the request of any person or entity appearing to be a potential beneficiary of bonds covering payment of obligations arising under the Contract, the Contractor shall promptly furnish a copy of the bonds or shall authorize a copy to be furnished.
- § 11.1.4 Notice of Cancellation or Expiration of Contractor's Required Insurance. Within three (3) business days of the date the Contractor becomes aware of an impending or actual cancellation or expiration of any insurance required by the Contract Documents, the Contractor shall provide notice to the Owner of such impending or actual cancellation or expiration. Upon receipt of notice from the Contractor, the Owner shall, unless the lapse in coverage arises from an act

or omission of the Owner, have the right to stop the Work until the lapse in coverage has been cured by the procurement of replacement coverage by the Contractor. The furnishing of notice by the Contractor shall not relieve the Contractor of any contractual obligation to provide any required coverage.

§ 11.2 Owner's Insurance

§ 11.2.1 The Owner shall purchase and maintain insurance of the types and limits of liability, containing the endorsements, and subject to the terms and conditions, as described in the Agreement or elsewhere in the Contract Documents. The Owner shall purchase and maintain the required insurance from an insurance company or insurance companies lawfully authorized to issue insurance in the jurisdiction where the Project is located.

§ 11.2.2 Failure to Purchase Required Property Insurance. If the Owner fails to purchase and maintain the required property insurance, with all of the coverages and in the amounts described in the Agreement or elsewhere in the Contract Documents, the Owner shall inform the Contractor in writing prior to commencement of the Work. Upon receipt of notice from the Owner, the Contractor may delay commencement of the Work and may obtain insurance that will protect the interests of the Contractor, Subcontractors, and Sub-Subcontractors in the Work. When the failure to provide coverage has been cured or resolved, the Contract Sum and Contract Time shall be equitably adjusted. In the event the Owner fails to procure coverage, the Owner waives all rights against the Contractor, Subcontractors, and Sub-subcontractors to the extent the loss to the Owner would have been covered by the insurance to have been procured by the Owner. The cost of the insurance shall be charged to the Owner by a Change Order. If the Owner does not provide written notice, and the Contractor is damaged by the failure or neglect of the Owner to purchase or maintain the required insurance, the Owner shall reimburse the Contractor for all reasonable costs and damages attributable thereto.

§ 11.2.3 Notice of Cancellation or Expiration of Owner's Required Property Insurance. Within three (3) business days of the date the Owner becomes aware of an impending or actual cancellation or expiration of any property insurance required by the Contract Documents, the Owner shall provide notice to the Contractor of such impending or actual cancellation or expiration. Unless the lapse in coverage arises from an act or omission of the Contractor: (1) the Contractor, upon receipt of notice from the Owner, shall have the right to stop the Work until the lapse in coverage has been cured by the procurement of replacement coverage by either the Owner or the Contractor; (2) the Contract Time and Contract Sum shall be equitably adjusted; and (3) the Owner waives all rights against the Contractor, Subcontractors, and Sub-subcontractors to the extent any loss to the Owner would have been covered by the insurance had it not expired or been cancelled. If the Contractor purchases replacement coverage, the cost of the insurance shall be charged to the Owner by an appropriate Change Order. The furnishing of notice by the Owner shall not relieve the Owner of any contractual obligation to provide required insurance.

§ 11.3 Waivers of Subrogation

§ 11.3.1 The Owner and Contractor waive all rights against (1) each other and any of their subcontractors, sub-subcontractors, agents, and employees, each of the other; (2) the Architect and Architect's consultants; and (3) Separate Contractors, if any, and any of their subcontractors, sub-subcontractors, agents, and employees, for damages caused by fire, or other causes of loss, to the extent those losses are covered by property insurance required by the Agreement or other property insurance applicable to the Project, except such rights as they have to proceeds of such insurance. The Owner or Contractor, as appropriate, shall require similar written waivers in favor of the individuals and entities identified above from the Architect, Architect's consultants, Separate Contractors, subcontractors, and sub-subcontractors. The policies of insurance purchased and maintained by each person or entity agreeing to waive claims pursuant to this section 11.3.1 shall not prohibit this waiver of subrogation. This waiver of subrogation shall be effective as to a person or entity (1) even though that person or entity would otherwise have a duty of indemnification, contractual or otherwise, (2) even though that person or entity did not pay the insurance premium directly or indirectly, or (3) whether or not the person or entity had an insurable interest in the damaged property.

§ 11.3.2 If during the Project construction period the Owner insures properties, real or personal or both, at or adjacent to the site by property insurance under policies separate from those insuring the Project, or if after final payment property insurance is to be provided on the completed Project through a policy or policies other than those insuring the Project during the construction period, to the extent permissible by such policies, the Owner waives all rights in accordance with the terms of Section 11.3.1 for damages caused by fire or other causes of loss covered by this separate property insurance.

§ 11.4 Loss of Use, Business Interruption, and Delay in Completion Insurance

The Owner, at the Owner's option, may purchase and maintain insurance that will protect the Owner against loss of use of the Owner's property, or the inability to conduct normal operations, due to fire or other causes of loss. The Owner waives all rights of action against the Contractor and Architect for loss of use of the Owner's property, due to fire or other hazards however caused.

§11.5 Adjustment and Settlement of Insured Loss

§ 11.5.1 A loss insured under the property insurance required by the Agreement shall be adjusted by the Owner as fiduciary and made payable to the Owner as fiduciary for the insureds, as their interests may appear, subject to requirements of any applicable mortgagee clause and of Section 11.5.2. The Owner shall pay the Architect and Contractor their just shares of insurance proceeds received by the Owner, and by appropriate agreements the Architect and Contractor shall make payments to their consultants and Subcontractors in similar manner.

§ 11.5.2 Prior to settlement of an insured loss, the Owner shall notify the Contractor of the terms of the proposed settlement as well as the proposed allocation of the insurance proceeds. The Contractor shall have 14 days from receipt of notice to object to the proposed settlement or allocation of the proceeds. If the Contractor does not object, the Owner shall settle the loss and the Contractor shall be bound by the settlement and allocation. Upon receipt, the Owner shall deposit the insurance proceeds in a separate account and make the appropriate distributions. Thereafter, if no other agreement is made or the Owner does not terminate the Contract for convenience, the Owner and Contractor shall execute a Change Order for reconstruction of the damaged or destroyed Work in the amount allocated for that purpose. If the Contractor timely objects to either the terms of the proposed settlement or the allocation of the proceeds, the Owner may proceed to settle the insured loss, and any dispute between the Owner and Contractor arising out of the settlement or allocation of the proceeds shall be resolved pursuant to Article 15. Pending resolution of any dispute, the Owner may issue a Construction Change Directive for the reconstruction of the damaged or destroyed Work.

ARTICLE 12 UNCOVERING AND CORRECTION OF WORK

§ 12.1 Uncovering of Work

§ 12.1.1 If a portion of the Work is covered contrary to the Architect's request or to requirements specifically expressed in the Contract Documents, it must, if requested in writing by the Architect, be uncovered for the Architect's examination and be replaced at the Contractor's expense without change in the Contract Time.

§ 12.1.2 If a portion of the Work has been covered that the Architect has not specifically requested to examine prior to its being covered, the Architect may request to see such Work and it shall be uncovered by the Contractor. If such Work is in accordance with the Contract Documents, the Contractor shall be entitled to an equitable adjustment to the Contract Sum and Contract Time as may be appropriate. If such Work is not in accordance with the Contract Documents, the costs of uncovering the Work, and the cost of correction, shall be at the Contractor's expense.

§ 12.2 Correction of Work

§ 12.2.1 Before Substantial Completion

The Contractor shall promptly correct Work rejected by the Architect or failing to conform to the requirements of the Contract Documents, discovered before Substantial Completion and whether or not fabricated, installed or completed. Costs of correcting such rejected Work, including additional testing and inspections, the cost of uncovering and replacement, and compensation for the Architect's services and expenses made necessary thereby, shall be at the Contractor's expense.

§ 12.2.2 After Substantial Completion

§ 12.2.2.1 In addition to the Contractor's obligations under Section 3.5, if, within one year after the date of Substantial Completion of the Work or designated portion thereof or after the date for commencement of warranties established under Section 9.9.1, or by terms of any applicable special warranty required by the Contract Documents, any of the Work is found to be not in accordance with the requirements of the Contract Documents, the Contractor shall correct it promptly after receipt of notice from the Owner to do so, unless the Owner has previously given the Contractor a written acceptance of such condition. The Owner shall give such notice promptly after discovery of the condition. During the one-year period for correction of Work, if the Owner fails to notify the Contractor and give the Contractor an opportunity to make the correction, the Owner waives the rights to require correction by the Contractor and to make a claim for breach of warranty. If the Contractor fails to correct nonconforming Work within a reasonable time during that period after receipt of notice from the Owner or Architect, the Owner may correct it in accordance with Section 2.5.

- § 12.2.2.2 The one-year period for correction of Work shall be extended with respect to portions of Work first performed after Substantial Completion by the period of time between Substantial Completion and the actual completion of that portion of the Work.
- § 12.2.2.3 The one-year period for correction of Work shall not be extended by corrective Work performed by the Contractor pursuant to this Section 12.2.
- § 12.2.3 The Contractor shall remove from the site portions of the Work that are not in accordance with the requirements of the Contract Documents and are neither corrected by the Contractor nor accepted by the Owner.
- § 12.2.4 The Contractor shall bear the cost of correcting destroyed or damaged construction of the Owner or Separate Contractors, whether completed or partially completed, caused by the Contractor's correction or removal of Work that is not in accordance with the requirements of the Contract Documents.
- § 12.2.5 Nothing contained in this Section 12.2 shall be construed to establish a period of limitation with respect to other obligations the Contractor has under the Contract Documents. Establishment of the one-year period for correction of Work as described in Section 12.2.2 relates only to the specific obligation of the Contractor to correct the Work, and has no relationship to the time within which the obligation to comply with the Contract Documents may be sought to be enforced, nor to the time within which proceedings may be commenced to establish the Contractor's liability with respect to the Contractor's obligations other than specifically to correct the Work.

§ 12.3 Acceptance of Nonconforming Work

If the Owner prefers to accept Work that is not in accordance with the requirements of the Contract Documents, the Owner may do so instead of requiring its removal and correction, in which case the Contract Sum will be reduced as appropriate and equitable. Such adjustment shall be effected whether or not final payment has been made.

ARTICLE 13 MISCELLANEOUS PROVISIONS

§ 13.1 Governing Law

The Contract shall be governed by the law of the place where the Project is located, excluding that jurisdiction's choice of law rules. If the parties have selected arbitration as the method of binding dispute resolution, the Federal Arbitration Act shall govern Section 15.4.

§ 13.2 Successors and Assigns

- § 13.2.1 The Owner and Contractor respectively bind themselves, their partners, successors, assigns, and legal representatives to covenants, agreements, and obligations contained in the Contract Documents. Except as provided in Section 13.2.2, neither party to the Contract shall assign the Contract as a whole without written consent of the other. If either party attempts to make an assignment without such consent, that party shall nevertheless remain legally responsible for all obligations under the Contract.
- § 13.2.2 The Owner may, without consent of the Contractor, assign the Contract to a lender providing construction financing for the Project, if the lender assumes the Owner's rights and obligations under the Contract Documents. The Contractor shall execute all consents reasonably required to facilitate the assignment.

§ 13.3 Rights and Remedies

- § 13.3.1 Duties and obligations imposed by the Contract Documents and rights and remedies available thereunder shall be in addition to and not a limitation of duties, obligations, rights, and remedies otherwise imposed or available by law.
- § 13.3.2 No action or failure to act by the Owner, Architect, or Contractor shall constitute a waiver of a right or duty afforded them under the Contract, nor shall such action or failure to act constitute approval of or acquiescence in a breach thereunder, except as may be specifically agreed upon in writing.

§ 13.4 Tests and Inspections

§ 13.4.1 Tests, inspections, and approvals of portions of the Work shall be made as required by the Contract Documents and by applicable laws, statutes, ordinances, codes, rules, and regulations or lawful orders of public authorities. Unless otherwise provided, the Contractor shall make arrangements for such tests, inspections, and

approvals with an independent testing laboratory or entity acceptable to the Owner, or with the appropriate public authority, and shall bear all related costs of tests, inspections, and approvals. The Contractor shall give the Architect timely notice of when and where tests and inspections are to be made so that the Architect may be present for such procedures. The Owner shall bear costs of tests, inspections, or approvals that do not become requirements until after bids are received or negotiations concluded. The Owner shall directly arrange and pay for tests, inspections, or approvals where building codes or applicable laws or regulations so require.

- § 13.4.2 If the Architect, Owner, or public authorities having jurisdiction determine that portions of the Work require additional testing, inspection, or approval not included under Section 13.4.1, the Architect will, upon written authorization from the Owner, instruct the Contractor to make arrangements for such additional testing, inspection, or approval, by an entity acceptable to the Owner, and the Contractor shall give timely notice to the Architect of when and where tests and inspections are to be made so that the Architect may be present for such procedures. Such costs, except as provided in Section 13.4.3, shall be at the Owner's expense.
- § 13.4.3 If procedures for testing, inspection, or approval under Sections 13.4.1 and 13.4.2 reveal failure of the portions of the Work to comply with requirements established by the Contract Documents, all costs made necessary by such failure, including those of repeated procedures and compensation for the Architect's services and expenses, shall be at the Contractor's expense.
- § 13.4.4 Required certificates of testing, inspection, or approval shall, unless otherwise required by the Contract Documents, be secured by the Contractor and promptly delivered to the Architect.
- § 13.4.5 If the Architect is to observe tests, inspections, or approvals required by the Contract Documents, the Architect will do so promptly and, where practicable, at the normal place of testing.
- § 13.4.6 Tests or inspections conducted pursuant to the Contract Documents shall be made promptly to avoid unreasonable delay in the Work.

§ 13.5 Interest

Payments due and unpaid under the Contract Documents shall bear interest from the date payment is due at the rate the parties agree upon in writing or, in the absence thereof, at the legal rate prevailing from time to time at the place where the Project is located.

ARTICLE 14 TERMINATION OR SUSPENSION OF THE CONTRACT

§ 14.1 Termination by the Contractor

- § 14.1.1 The Contractor may terminate the Contract if the Work is stopped for a period of 30 consecutive days through no act or fault of the Contractor, a Subcontractor, a Sub-subcontractor, their agents or employees, or any other persons or entities performing portions of the Work, for any of the following reasons:
 - .1 Issuance of an order of a court or other public authority having jurisdiction that requires all Work to be stopped:
 - **.2** An act of government, such as a declaration of national emergency, that requires all Work to be stopped;
 - .3 Because the Architect has not issued a Certificate for Payment and has not notified the Contractor of the reason for withholding certification as provided in Section 9.4.1, or because the Owner has not made payment on a Certificate for Payment within the time stated in the Contract Documents; or
 - .4 The Owner has failed to furnish to the Contractor reasonable evidence as required by Section 2.2.
- § 14.1.2 The Contractor may terminate the Contract if, through no act or fault of the Contractor, a Subcontractor, a Sub-subcontractor, their agents or employees, or any other persons or entities performing portions of the Work, repeated suspensions, delays, or interruptions of the entire Work by the Owner as described in Section 14.3, constitute in the aggregate more than 100 percent of the total number of days scheduled for completion, or 120 days in any 365-day period, whichever is less.
- § 14.1.3 If one of the reasons described in Section 14.1.1 or 14.1.2 exists, the Contractor may, upon seven days' notice to the Owner and Architect, terminate the Contract and recover from the Owner payment for Work executed, as well as reasonable overhead and profit on Work not executed, and costs incurred by reason of such termination.

§ 14.1.4 If the Work is stopped for a period of 60 consecutive days through no act or fault of the Contractor, a Sub-subcontractor, or their agents or employees or any other persons or entities performing portions of the Work because the Owner has repeatedly failed to fulfill the Owner's obligations under the Contract Documents with respect to matters important to the progress of the Work, the Contractor may, upon seven additional days' notice to the Owner and the Architect, terminate the Contract and recover from the Owner as provided in Section 14.1.3.

§ 14.2 Termination by the Owner for Cause

- § 14.2.1 The Owner may terminate the Contract if the Contractor
 - .1 repeatedly refuses or fails to supply enough properly skilled workers or proper materials;
 - .2 fails to make payment to Subcontractors or suppliers in accordance with the respective agreements between the Contractor and the Subcontractors or suppliers;
 - .3 repeatedly disregards applicable laws, statutes, ordinances, codes, rules and regulations, or lawful orders of a public authority; or
 - .4 otherwise is guilty of substantial breach of a provision of the Contract Documents.
- § 14.2.2 When any of the reasons described in Section 14.2.1 exist, and upon certification by the Architect that sufficient cause exists to justify such action, the Owner may, without prejudice to any other rights or remedies of the Owner and after giving the Contractor and the Contractor's surety, if any, seven days' notice, terminate employment of the Contractor and may, subject to any prior rights of the surety:
 - Exclude the Contractor from the site and take possession of all materials, equipment, tools, and construction equipment and machinery thereon owned by the Contractor;
 - .2 Accept assignment of subcontracts pursuant to Section 5.4; and
 - .3 Finish the Work by whatever reasonable method the Owner may deem expedient. Upon written request of the Contractor, the Owner shall furnish to the Contractor a detailed accounting of the costs incurred by the Owner in finishing the Work.
- § 14.2.3 When the Owner terminates the Contract for one of the reasons stated in Section 14.2.1, the Contractor shall not be entitled to receive further payment until the Work is finished.
- § 14.2.4 If the unpaid balance of the Contract Sum exceeds costs of finishing the Work, including compensation for the Architect's services and expenses made necessary thereby, and other damages incurred by the Owner and not expressly waived, such excess shall be paid to the Contractor. If such costs and damages exceed the unpaid balance, the Contractor shall pay the difference to the Owner. The amount to be paid to the Contractor or Owner, as the case may be, shall be certified by the Initial Decision Maker, upon application, and this obligation for payment shall survive termination of the Contract.

§ 14.3 Suspension by the Owner for Convenience

- § 14.3.1 The Owner may, without cause, order the Contractor in writing to suspend, delay or interrupt the Work, in whole or in part for such period of time as the Owner may determine.
- § 14.3.2 The Contract Sum and Contract Time shall be adjusted for increases in the cost and time caused by suspension, delay, or interruption under Section 14.3.1. Adjustment of the Contract Sum shall include profit. No adjustment shall be made to the extent
 - .1 that performance is, was, or would have been, so suspended, delayed, or interrupted, by another cause for which the Contractor is responsible; or
 - .2 that an equitable adjustment is made or denied under another provision of the Contract.

§ 14.4 Termination by the Owner for Convenience

- § 14.4.1 The Owner may, at any time, terminate the Contract for the Owner's convenience and without cause.
- § 14.4.2 Upon receipt of notice from the Owner of such termination for the Owner's convenience, the Contractor shall
 - .1 cease operations as directed by the Owner in the notice;
 - .2 take actions necessary, or that the Owner may direct, for the protection and preservation of the Work;
 - .3 except for Work directed to be performed prior to the effective date of termination stated in the notice, terminate all existing subcontracts and purchase orders and enter into no further subcontracts and purchase orders.

§ 14.4.3 In case of such termination for the Owner's convenience, the Owner shall pay the Contractor for Work properly executed; costs incurred by reason of the termination, including costs attributable to termination of Subcontracts; and the termination fee, if any, set forth in the Agreement.

ARTICLE 15 CLAIMS AND DISPUTES

§ 15.1 Claims

§ 15.1.1 Definition

A Claim is a demand or assertion by one of the parties seeking, as a matter of right, payment of money, a change in the Contract Time, or other relief with respect to the terms of the Contract. The term "Claim" also includes other disputes and matters in question between the Owner and Contractor arising out of or relating to the Contract. The responsibility to substantiate Claims shall rest with the party making the Claim. This Section 15.1.1 does not require the Owner to file a Claim in order to impose liquidated damages in accordance with the Contract Documents.

§ 15.1.2 Time Limits on Claims

The Owner and Contractor shall commence all Claims and causes of action against the other and arising out of or related to the Contract, whether in contract, tort, breach of warranty or otherwise, in accordance with the requirements of the binding dispute resolution method selected in the Agreement and within the period specified by applicable law, but in any case not more than 10 years after the date of Substantial Completion of the Work. The Owner and Contractor waive all Claims and causes of action not commenced in accordance with this Section 15.1.2.

§ 15.1.3 Notice of Claims

§ 15.1.3.1 Claims by either the Owner or Contractor, where the condition giving rise to the Claim is first discovered prior to expiration of the period for correction of the Work set forth in Section 12.2.2, shall be initiated by notice to the other party and to the Initial Decision Maker with a copy sent to the Architect, if the Architect is not serving as the Initial Decision Maker. Claims by either party under this Section 15.1.3.1 shall be initiated within 21 days after occurrence of the event giving rise to such Claim or within 21 days after the claimant first recognizes the condition giving rise to the Claim, whichever is later.

§ 15.1.3.2 Claims by either the Owner or Contractor, where the condition giving rise to the Claim is first discovered after expiration of the period for correction of the Work set forth in Section 12.2.2, shall be initiated by notice to the other party. In such event, no decision by the Initial Decision Maker is required.

§ 15.1.4 Continuing Contract Performance

§ 15.1.4.1 Pending final resolution of a Claim, except as otherwise agreed in writing or as provided in Section 9.7 and Article 14, the Contractor shall proceed diligently with performance of the Contract and the Owner shall continue to make payments in accordance with the Contract Documents.

§ 15.1.4.2 The Contract Sum and Contract Time shall be adjusted in accordance with the Initial Decision Maker's decision, subject to the right of either party to proceed in accordance with this Article 15. The Architect will issue Certificates for Payment in accordance with the decision of the Initial Decision Maker.

§ 15.1.5 Claims for Additional Cost

If the Contractor wishes to make a Claim for an increase in the Contract Sum, notice as provided in Section 15.1.3 shall be given before proceeding to execute the portion of the Work that is the subject of the Claim. Prior notice is not required for Claims relating to an emergency endangering life or property arising under Section 10.4.

§ 15.1.6 Claims for Additional Time

§ 15.1.6.1 If the Contractor wishes to make a Claim for an increase in the Contract Time, notice as provided in Section 15.1.3 shall be given. The Contractor's Claim shall include an estimate of cost and of probable effect of delay on progress of the Work. In the case of a continuing delay, only one Claim is necessary.

§ 15.1.6.2 If adverse weather conditions are the basis for a Claim for additional time, such Claim shall be documented by data substantiating that weather conditions were abnormal for the period of time, could not have been reasonably anticipated, and had an adverse effect on the scheduled construction.

§ 15.1.7 Waiver of Claims for Consequential Damages

The Contractor and Owner waive Claims against each other for consequential damages arising out of or relating to this Contract. This mutual waiver includes

- damages incurred by the Owner for rental expenses, for losses of use, income, profit, financing, business and reputation, and for loss of management or employee productivity or of the services of such
- damages incurred by the Contractor for principal office expenses including the compensation of personnel stationed there, for losses of financing, business and reputation, and for loss of profit, except anticipated profit arising directly from the Work.

This mutual waiver is applicable, without limitation, to all consequential damages due to either party's termination in accordance with Article 14. Nothing contained in this Section 15.1.7 shall be deemed to preclude assessment of liquidated damages, when applicable, in accordance with the requirements of the Contract Documents.

§ 15.2 Initial Decision

- § 15.2.1 Claims, excluding those where the condition giving rise to the Claim is first discovered after expiration of the period for correction of the Work set forth in Section 12.2.2 or arising under Sections 10.3, 10.4, and 11.5, shall be referred to the Initial Decision Maker for initial decision. The Architect will serve as the Initial Decision Maker, unless otherwise indicated in the Agreement. Except for those Claims excluded by this Section 15.2.1, an initial decision shall be required as a condition precedent to mediation of any Claim. If an initial decision has not been rendered within 30 days after the Claim has been referred to the Initial Decision Maker, the party asserting the Claim may demand mediation and binding dispute resolution without a decision having been rendered. Unless the Initial Decision Maker and all affected parties agree, the Initial Decision Maker will not decide disputes between the Contractor and persons or entities other than the Owner.
- § 15.2.2 The Initial Decision Maker will review Claims and within ten days of the receipt of a Claim take one or more of the following actions: (1) request additional supporting data from the claimant or a response with supporting data from the other party, (2) reject the Claim in whole or in part, (3) approve the Claim, (4) suggest a compromise, or (5) advise the parties that the Initial Decision Maker is unable to resolve the Claim if the Initial Decision Maker lacks sufficient information to evaluate the merits of the Claim or if the Initial Decision Maker concludes that, in the Initial Decision Maker's sole discretion, it would be inappropriate for the Initial Decision Maker to resolve the Claim.
- § 15.2.3 In evaluating Claims, the Initial Decision Maker may, but shall not be obligated to, consult with or seek information from either party or from persons with special knowledge or expertise who may assist the Initial Decision Maker in rendering a decision. The Initial Decision Maker may request the Owner to authorize retention of such persons at the Owner's expense.
- § 15.2.4 If the Initial Decision Maker requests a party to provide a response to a Claim or to furnish additional supporting data, such party shall respond, within ten days after receipt of the request, and shall either (1) provide a response on the requested supporting data, (2) advise the Initial Decision Maker when the response or supporting data will be furnished, or (3) advise the Initial Decision Maker that no supporting data will be furnished. Upon receipt of the response or supporting data, if any, the Initial Decision Maker will either reject or approve the Claim in whole or in
- § 15.2.5 The Initial Decision Maker will render an initial decision approving or rejecting the Claim, or indicating that the Initial Decision Maker is unable to resolve the Claim. This initial decision shall (1) be in writing; (2) state the reasons therefor; and (3) notify the parties and the Architect, if the Architect is not serving as the Initial Decision Maker, of any change in the Contract Sum or Contract Time or both. The initial decision shall be final and binding on the parties but subject to mediation and, if the parties fail to resolve their dispute through mediation, to binding dispute resolution.
- § 15.2.6 Either party may file for mediation of an initial decision at any time, subject to the terms of Section 15.2.6.1.
- § 15.2.6.1 Either party may, within 30 days from the date of receipt of an initial decision, demand in writing that the other party file for mediation. If such a demand is made and the party receiving the demand fails to file for mediation within 30 days after receipt thereof, then both parties waive their rights to mediate or pursue binding dispute resolution proceedings with respect to the initial decision.

- § 15.2.7 In the event of a Claim against the Contractor, the Owner may, but is not obligated to, notify the surety, if any, of the nature and amount of the Claim. If the Claim relates to a possibility of a Contractor's default, the Owner may, but is not obligated to, notify the surety and request the surety's assistance in resolving the controversy.
- § 15.2.8 If a Claim relates to or is the subject of a mechanic's lien, the party asserting such Claim may proceed in accordance with applicable law to comply with the lien notice or filing deadlines.

§ 15.3 Mediation

- § 15.3.1 Claims, disputes, or other matters in controversy arising out of or related to the Contract, except those waived as provided for in Sections 9.10.4, 9.10.5, and 15.1.7, shall be subject to mediation as a condition precedent to binding dispute resolution.
- § 15.3.2 The parties shall endeavor to resolve their Claims by mediation which, unless the parties mutually agree otherwise, shall be administered by the American Arbitration Association in accordance with its Construction Industry Mediation Procedures in effect on the date of the Agreement. A request for mediation shall be made in writing, delivered to the other party to the Contract, and filed with the person or entity administering the mediation. The request may be made concurrently with the filing of binding dispute resolution proceedings but, in such event, mediation shall proceed in advance of binding dispute resolution proceedings, which shall be stayed pending mediation for a period of 60 days from the date of filing, unless stayed for a longer period by agreement of the parties or court order. If an arbitration is stayed pursuant to this Section 15.3.2, the parties may nonetheless proceed to the selection of the arbitrator(s) and agree upon a schedule for later proceedings.
- § 15.3.3 Either party may, within 30 days from the date that mediation has been concluded without resolution of the dispute or 60 days after mediation has been demanded without resolution of the dispute, demand in writing that the other party file for binding dispute resolution. If such a demand is made and the party receiving the demand fails to file for binding dispute resolution within 60 days after receipt thereof, then both parties waive their rights to binding dispute resolution proceedings with respect to the initial decision.
- § 15.3.4 The parties shall share the mediator's fee and any filing fees equally. The mediation shall be held in the place where the Project is located, unless another location is mutually agreed upon. Agreements reached in mediation shall be enforceable as settlement agreements in any court having jurisdiction thereof.

§ 15.4 Arbitration

- § 15.4.1 If the parties have selected arbitration as the method for binding dispute resolution in the Agreement, any Claim subject to, but not resolved by, mediation shall be subject to arbitration which, unless the parties mutually agree otherwise, shall be administered by the American Arbitration Association in accordance with its Construction Industry Arbitration Rules in effect on the date of the Agreement. The Arbitration shall be conducted in the place where the Project is located, unless another location is mutually agreed upon. A demand for arbitration shall be made in writing, delivered to the other party to the Contract, and filed with the person or entity administering the arbitration. The party filing a notice of demand for arbitration must assert in the demand all Claims then known to that party on which arbitration is permitted to be demanded.
- § 15.4.1.1 A demand for arbitration shall be made no earlier than concurrently with the filing of a request for mediation, but in no event shall it be made after the date when the institution of legal or equitable proceedings based on the Claim would be barred by the applicable statute of limitations. For statute of limitations purposes, receipt of a written demand for arbitration by the person or entity administering the arbitration shall constitute the institution of legal or equitable proceedings based on the Claim.
- § 15.4.2 The award rendered by the arbitrator or arbitrators shall be final, and judgment may be entered upon it in accordance with applicable law in any court having jurisdiction thereof.
- § 15.4.3 The foregoing agreement to arbitrate and other agreements to arbitrate with an additional person or entity duly consented to by parties to the Agreement, shall be specifically enforceable under applicable law in any court having jurisdiction thereof.

(1817262161)

§ 15.4.4 Consolidation or Joinder

§ 15.4.4.1 Subject to the rules of the American Arbitration Association or other applicable arbitration rules, either party may consolidate an arbitration conducted under this Agreement with any other arbitration to which it is a party provided that (1) the arbitration agreement governing the other arbitration permits consolidation, (2) the arbitrations to be consolidated substantially involve common questions of law or fact, and (3) the arbitrations employ materially similar procedural rules and methods for selecting arbitrator(s).

§ 15.4.4.2 Subject to the rules of the American Arbitration Association or other applicable arbitration rules, either party may include by joinder persons or entities substantially involved in a common question of law or fact whose presence is required if complete relief is to be accorded in arbitration, provided that the party sought to be joined consents in writing to such joinder. Consent to arbitration involving an additional person or entity shall not constitute consent to arbitration of any claim, dispute or other matter in question not described in the written consent.

§ 15.4.4.3 The Owner and Contractor grant to any person or entity made a party to an arbitration conducted under this Section 15.4, whether by joinder or consolidation, the same rights of joinder and consolidation as those of the Owner and Contractor under this Agreement.





SECTION 00 7300 SUPPLEMENTARY CONDITIONS

The following supplements modify the *General Conditions of the Contract for Construction*, AIA Document A201-2017. Where a portion of the General Conditions is modified or deleted by these supplementary conditions, the unaltered portions of the General Conditions shall remain in effect.

ARTICLE 1 - GENERAL PROVISIONS

1.1 BASIC DEFINITIONS

Add the following sentence to the End of Section 1.1.1:

The Contract Documents executed or identified in accordance with Subparagraph 1.5.1 shall prevail in case of an inconsistency with subsequent versions made through manipulatable electronic operations involving computers.

1.2 CORRELATION AND INTENT OF THE CONTRACT DOCUMENTS

Add Section 1.2.1.2 to Section 1.2.1:

- 1.2.1.2 In the event of conflicts or discrepancies among the Contract Documents, interpretations will be based on the following priorities:
- 1. The Agreement.
- 2. Addenda, with those of later date having precedence over those of earlier date.
- 3. The Supplementary Conditions.
- 4. The General Conditions of the Contract for Construction.
- 5. Division 1 of the Specifications.
- 6. Drawings and Division 2-33 of the Specifications.

In the case of conflicts or discrepancies between Drawings and Divisions 2-33 of the Specifications or within either Document not clarified by Addendum; the Architect will determine which takes precedence in accordance with Subparagraph 4.2.11.

1.7 DIGITAL DATA USE AND TRANSMISSION

Add the following Section 1.7.1 to Section 1.7:

- 1.7.1 Contractor's Use of Instruments of Service in Electronic Form.
- 1.7.1.1 The Architect may, with the concurrence of the Owner, furnish to the Contractor versions of Instruments of Service in electronic form. The Contract Documents executed or identified in accordance with Subparagraph 1.5.1 shall prevail in case of an inconsistency with subsequent versions made through manipulatable electronic operations involving computers.
- 1.7.1.2 The Contractor shall not transfer or reuse Instruments of Service in electronic or machine readable form without the prior written consent of the Architect.
- 1.7.1.3 The Contractor may obtain these computer aided design files for use in preparation of shop drawings and/or coordination drawings by completing the Architect's Agreement and

Waiver for Use of Computer Aided Design File. See attached. This form is bound in the specifications manual.

Add the following Section 1.9 to Article 1:

1.9 Representatives of the Owner, Contractor and Architect shall meet periodically at mutually agreed-upon intervals for the purpose of establishing procedures to facilitate cooperation, communication and timely responses among the participants. By participating in this arrangement, the parties do not intend to create additional contractual obligations or modify the legal relationships which may otherwise exist.

ARTICLE 2 - OWNER

2.3 INFORMATION AND SERVICES REQUIRED BY THE OWNER

Delete Section 2.3.6 and substitute the following:

The General Contractor will be furnished free of charge, electronic copies of Drawings and Project Manual.

ARTICLE 3 - CONTRACTOR

3.2 REVIEW OF CONTRACT DOCUMENTS AND FIELD CONDITIONS BY CONTRACTOR

To Paragraph 3.2 add the following Subparagraph 3.2.5:

3.2.5 Do not scale the Drawings. Follow indicated dimensions. In case of any discrepancy in the figures, bring the matter to the attention of the Architect for decision before proceeding with the Work. Failure to follow this procedure shall be at the Contractor's own risk, and the Architect's decision shall be final.

3.4 LABOR AND MATERIALS

Delete Section 3.4.2 and substitute the following:

- 3.4.2 After the Contract has been executed, the Owner and Architect will consider a formal request for the substitution of products in place of those specified only under the conditions set forth in the General Requirements (Division 1 of the Specifications). By making requests for substitutions, the Contractor:
- .1 represents that the Contractor has personally investigated the proposed substitute product and determined that it is equal or superior in all respects to that specified;
- represents that the Contractor will provide the same warranty for the substitution that the Contractor would for that specified;
- .3 certifies that the cost data presented is complete and includes all related costs under this Contract except the Architect's redesign costs, and waives all claims for additional costs related to the substitution which subsequently become apparent; and
- .4 will coordinate the installation of the accepted substitute, making such changes as may be required for the Work to be complete in all respects.

Add the following Section 3.4.4 to Section 3.4:

3.4.4 The Owner shall be entitled to deduct from the Contract Sum amounts paid to the Architect to evaluate the Contractor's proposed substitutions and to make agreed-upon changes in the Drawings and Specifications made necessary by the Owner's acceptance of such substitutions.

3.6 TAXES

Add Subparagraph 3.6.1 to Section 3.6:

3.6.1 The Owner is exempt from State of Ohio sales and use tax laws and such taxes shall not be included in bid.

3.7 PERMITS, FEES, AND NOTICES

Add the following two sentences to Section 3.7.1:

The Owner shall pay fees for public or private water, gas, electrical, and other utility extensions at the site. The Contractor shall secure and arrange for all necessary utility connections.

3.8 ALLOWANCES

Delete semicolon at end of Section 3.8.2.2 and add the following:

, except that if installation is included as part of an allowance in Divisions 1-33 of the Specifications, the installation and labor cost for greater or lesser quantities of Work shall be determined in accordance with Subparagraph 7.3.6;

3.9 SUPERINTENDENT

Delete Section 3.9.1 and substitute the following:

3.9.1 The Contractor shall employ a superintendent or an assistant to the superintendent who is responsible for coordinating Drawings, Specifications, and shop drawings pertaining to such systems. The coordinator shall assist the Subcontractors in arranging space conditions to eliminate interference between the mechanical and electrical systems and other Work and shall supervise will perform as a coordinator for mechanical and electrical Work. The coordinator shall be knowledgeable in mechanical and electrical systems and capable of reading, interpreting and the preparation of coordination drawings documenting the spatial arrangements for such systems within restricted spaces. The coordinator shall assist in planning and expediting the proper sequence of delivery of mechanical and electrical equipment to the site.

Add the following Sections to 3.9.1:

- 3.9.1.1 The Contractor shall submit an outline of the qualifications and experience of the Contractor's proposed superintendent, including references, to the Architect within ten (10) days of the Notice to Proceed.
- 3.9.1.2 The Owner reserves the right to reject the Contractor's proposed superintendent. Failure of the Architect to notify the Contractor within 30 days of receipt of the required information shall constitute notice that the Owner has no objection.
- 3.9.1.3 Should the Owner reject the Contractor's superintendent, the Contractor shall replace the superintendent at no additional cost.

- 3.9.1.4 The Contractor shall not change the Contractor's superintendent without written approval of the Owner.
- 3.9.1.5 If the Contractor proposes to change the Contractor's superintendent, the Contractor shall submit to the Architect a written justification for the change, along with the name and qualifications of the individual whom the Contractor proposes to be the new superintendent.

4.1 ARCHITECT

No Changes.

ARTICLE 5 - SUBCONTRACTORS

Delete Section 5.2.1, 5.2.2 and 5.2.3 and substitute the following:

5.2.1 Not later than 30 days after the date of commencement of the Work, the Contractor shall furnish in writing to the Owner through the Architect the names of persons or entities proposed as manufacturers, fabricators or material suppliers for the products, equipment and systems identified in the General Requirements (Division 1 of the Specifications) and, where applicable, the name of the installing Subcontractor.

ARTICLE 6 - CONSTRUCTION BY OWNER OF BY SEPARATE CONTRACT

No changes.

ARTICLE 7 - CHANGES IN THE WORK

7.1 GENERAL

Add the following Section 7.1.4 to Section 7.1:

- 7.1.4 The combined overhead and profit included in the total cost to the Owner of a change in the Work shall be based on the following schedule:
- .1 For the Contractor, for Work performed by the Contractor's own forces, <u>10</u> percent of the cost.
- .2 For the Contractor, for Work performed by the Contractor's Subcontractor, $\underline{5}$ percent of the amount due the Subcontractor.
- .3 For each Subcontractor involved, for Work performed by that Subcontractor's own forces, 10 percent of the cost.
- .4 For each Subcontractor involved, for Work performed by the Subcontractor's subcontractors, <u>5</u> percent of the amount due the Sub-subcontractor.
- .5 Cost to which overhead and profit is to be applied shall be determined in accordance with Subparagraph 7.3.6.
- .6 In order to facilitate checking of quotations for extras or credits, all proposals, except those so minor that their propriety can be seen by inspection, shall be accompanied by a complete itemization of costs including labor, materials and Subcontracts. Labor and materials shall be itemized in a manner prescribed above. Where major cost items are Subcontracts, they shall be itemized also. In no case will a change involving over \$500. be approved without such itemization.

ARTICLE 8 - TIME

No changes.

ARTICLE 9 - PAYMENTS AND COMPLETION

9.2 SCHEDULE OF VALUES

Add the following sentence to Section 9.2:

The form of Schedule of Values shall be that each major item of Work and each subcontracted item of Work is shown as a single line item on a current AIA Document G703 - 1992, Certificate of Payment, Continuation Sheet.

9.3 APPLICATIONS FOR PAYMENT

To Subparagraph 9.3.1 add the following sentence:

The form of application for Payment, duly notarized, shall be a current authorized edition of AIA Document G702 -1992, Application and Certification for Payment, supported by a current authorized edition of AIA Document G703 - 1992, Continuation Sheet.

Add the following Section 9.3.1.3 to Section 9.3.1:

9.3.1.3 Until the Work is 50 percent complete, the Owner shall pay 90 percent of the amount due the Contractor on account of progress payments. At the time the Work is 50 percent complete and thereafter, the Architect will authorize remaining partial payments to be paid in full.

ARTICLE 10 - PROTECTION OF PERSONS AND PROPERTY

No changes.

ARTICLE 11 - INSURANCE AND BONDS

To Section 11.1.1, add the following:

- 11.1.1.1 As part of its proposal, each Bidder shall submit evidence of the following insurance coverage, and if awarded the contract, shall always during the term of the contract maintain such insurance. The insurance company(ies) providing the required insurance shall be authorized by the Ohio Department of Insurance to do business in Ohio and rated "A" or above by A. M. Best Company or equivalent. The successful Bidder shall provide a copy of the policy or policies and any necessary endorsements, or a substitute for them satisfactory to and approved by the Owner, evidencing the required insurances upon execution of the contract.
- 1. Commercial General Liability Insurance, including Contractual Liability Coverage Products and Completed Operations Coverage and Broad Form Property Damage, written on an "occurrence" basis, with limited of liability not less than One Million Dollars (\$1,000,000) per person/One Million Dollars (\$1,000,000) per occurrence/ Two Million Dollars (\$2,000,000) annual aggregate, and with a deductible no greater than \$25,000, covering bodily injury, personal injury, property damage and loss of use of property.
- 2. Business automobile liability insurance to cover each automobile, truck or other vehicle used in the performance of the Contract in an amount not less than a combined single limit of One Million Dollars (\$1,000,000) for bodily injury (including death at any time occurring) and property damage per occurrence.

- 3. Workers' compensation and employer's liability insurance as provided under the laws of the State of Ohio.
- 4. Statutory unemployment insurance protection for all its employees.
- 5. The successful Bidder will name Westcare Ohio, DBA East End Community Services as additional insured on all policies, and all policies will contain a clause stating the coverage will be primary and noncontributor as respect to all work being performed for WestCare Ohio, DBA East End Community Services.
- 7. The successful Bidder will provide the Owner with no less than thirty days' written notice if the Bidder's insurance will be cancelled, non-renewed, or has any material changes in coverage.

ARTICLE 12 - UNCOVERING AND CORRECTION OF WORK No change.

ARTICLE 13 - MISCELLANEOUS PROVISIONS

To Article 13 add the following Section 13.6:

13.6 MECHANICS LIEN LAW

13.6.1 The Owner and all Contractors will comply with the regulations and requirements of Chapter 1311 of the Ohio Revised Code. Prior to the start of construction, the Owner will file a Notice of Commencement (NOC) with the county recorder where the project is located. A copy of the NOC will be posted on the job site and copies will be given to the Original Contractors, who, in turn, must provide copies to its Subcontractors, lower tier Subcontractors, suppliers and materialmen.

ARTICLE 14 - TERMINATION OR SUSPENSION OF CONTRACT

No changes.

SECTION 00 8300 WAGE DETERMINATION

Wages to be paid for a legal day's work to laborers, mechanics, and supervisory employees engaged in work under the project shall not be less than the respective current prevailing rates predetermined for Darke County, Ohio, by the Ohio Department of Commerce, Bureau of Wage & Hour Administration.

The current wage rates are available from the State of Ohio Department of Commerce:

View Prevailing Wage Rates | Ohio Department of Commerce



SECTION 01 1000 SUMMARY

PART 1 GENERAL

1.01 PROJECT

- A. Project Name: Darke County Wagner Avenue Interior Renovation.
- B. Owner's Name: Darke County.
- C. Architect's Name: App Architecture, Inc..
- D. The Project consists of the construction of AN INTERIOR RENOVATION (ALTERATION) OF THE ADMINISTRATIVE OFFICES FOR THE DARKE COUNTY DEPARTMENT OF JOB AND FAMILY SERVICES. PROJECT IS PHASED: PHASE 1 IS THE INTERIOR RENOVATION OF 4,350 SF IN THE FAMILY SERVICES DIVISION AND PHASE 2 IS THE INTERIOR RENOVATION OF 4,950 SF FOR THE OHIO MEANS JOBS DIVISION. WORK INCLUDES GENERAL TRADES (PARTITIONS, OPENINGS, CASEWORK, FINISHES) AND REQUIRED REVISIONS TO FIRE PROTECTION SYSTEMS, MECHANICAL AND ELECTRICAL AS REQUIRED FOR THE NEW LAYOUT..

1.02 CONTRACT DESCRIPTION

A. Contract Type: A single prime contract based on a Stipulated Price as described in Document 00 5200 - Agreement Form.

1.03 DESCRIPTION OF ALTERATIONS WORK

- A. Scope of demolition and removal work is indicated on drawings and specified in Section 02
- B. Renovate the following areas, complete including operational mechanical and electrical work and finishes:
 - 1. As indicated on the drawings...
- C. Plumbing: Alter existing system and add new construction, keeping existing in operation.
- D. HVAC: Alter existing system and add new construction, keeping existing in operation.
- E. Electrical Power and Lighting: Alter existing system and add new construction, keeping existing in operation.
- F. Fire Suppression Sprinklers: Alter existing system and add new construction, keeping existing in operation.
- G. Fire Alarm: Alter existing system and add new construction, keeping existing in operation.
- H. Telecommunications: Alter existing system and add new construction, keeping existing in operation.
- I. Owner will remove the following items before start of work:
 - 1. Systems furniture.
 - 2. Electronic Equipment (i.e. computers, monitors, etc.).
 - 3. Furniture / File Cabinets.
 - 4. Wall mounted art work, display boards, bulletin boards, etc..
- J. Contractor is required to remove and deliver the following to Owner prior to start of work:
 - Refer to construction documents..
- K. Contractor is required to remove and store the following prior to start of work, for later reinstallation by Contractor:
 - 1. White Boards.
 - 2. Projection Screens.
 - 3. Items as indicated in the construction documents...

1.04 WORK BY OWNER

- A. Owner will be replacing existing Roof Top Units that serve the Area of Work. General Contractor, HVAC Contractor shall coordinate with Owner's RTU Contractor as required. Projects are anticipated to run concurrently.
- B. Items noted NIC (Not in Contract) will be supplied and installed by Owner before Date of Substantial Completion. Some items include:
 - Refer to construction documents.

1.05 OWNER OCCUPANCY

- Owner intends to continue to occupy adjacent portions of the existing building during the entire construction period.
- B. Owner intends to occupy Phase 1 of the new construction prior to the completion date for Phase 2 of the new construction..
- C. Cooperate with Owner to minimize conflict and to facilitate Owner's operations.
- D. Schedule the Work to accommodate Owner occupancy.

1.06 CONTRACTOR USE OF SITE AND PREMISES

- A. Construction Operations: Limited to areas noted on Drawings.
 - 1. Locate and conduct construction activities in ways that will limit disturbance to site.
- B. Arrange use of site and premises to allow:
 - 1. Owner occupancy.
 - 2. Work by Others.
 - 3. Work by Owner.
- C. Provide access to and from site as required by law and by Owner:
 - Emergency Building Exits During Construction: Keep all exits required by code open during construction period; provide temporary exit signs if exit routes are temporarily altered.
 - 2. Do not obstruct roadways, sidewalks, or other public ways without permit.
- D. Time Restrictions:
 - 1. Limit conduct of especially noisy work to the hours before 9:00 a.m. and after 4:00 p.m..
 - 2. Limit conduct of the hours of 7:00 a.m. to 5:00 p.m..
 - 3. Weekend Hours: As approved by Owner...
 - 4. Early morning or late evening hours: As approved by the Owner...
- E. Utility Outages and Shutdown:
 - 1. Do not disrupt or shut down life safety systems, including but not limited to fire sprinklers and fire alarm system, without 7 days notice to Owner and authorities having jurisdiction.
 - 2. Limit shutdown of utility services to 3 hours at a time, arranged at least 24 hours in advance with Owner.
 - Prevent accidental disruption of utility services to other facilities.

1.07 WORK SEQUENCE

- A. Construct Work in phases during the construction period as indicated on the drawings.
 - 1. Phase 1: Work associated with (9) new Offices located in the CORRIDOR 130 area and the adjacent spaces. Work occurs east of CORRIDOR 180..
 - 2. Phase 2: Work associated with the new Ohio Means Jobs (OMJ) Department, Work occurs west of CORRIDOR 180..
- B. Coordinate construction schedule and operations with Owner.

SECTION 01 2000 PRICE AND PAYMENT PROCEDURES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Procedures for preparation and submittal of applications for progress payments.
- B. Documentation of changes in Contract Sum and Contract Time.
- C. Change procedures.
- D. Procedures for preparation and submittal of application for final payment.

1.02 RELATED REQUIREMENTS

- A. Section 00 5200 Agreement Form: Contract Sum, retainages, payment period, monetary values of unit prices.
- B. Section 00 7200 General Conditions: Additional requirements for progress payments, final payment, changes in the Work.
- C. Section 01 2100 Allowances: Payment procedures relating to allowances.
- D. Section 01 2200 Unit Prices: Monetary values of unit prices; Payment and modification procedures relating to unit prices.
- E. Section 01 7800 Closeout Submittals: Project record documents.

1.03 SCHEDULE OF VALUES

- A. Use Schedule of Values Form: AIA G703, edition stipulated in the Agreement.
- B. Electronic media printout including equivalent information will be considered in lieu of standard form specified; submit draft to Architect for approval.
- C. Forms filled out by hand will not be accepted.
- Submit Schedule of Values in duplicate within 15 days after date of Owner-Contractor Agreement.
- E. Format: Utilize the Table of Contents of this Project Manual. Identify each line item with number and title of the specification section. Identify site mobilization.
- F. Revise schedule to list approved Change Orders, with each Application For Payment.

1.04 APPLICATIONS FOR PROGRESS PAYMENTS

- A. Payment Period: Submit at intervals stipulated in the Agreement.
- B. Use Form AIA G702 and Form AIA G703, edition stipulated in the Agreement.
- C. Electronic media printout including equivalent information will be considered in lieu of standard form specified; submit sample to Architect for approval.
- D. Forms filled out by hand will not be accepted.
- E. Execute certification by signature of authorized officer.
- F. Use data from approved Schedule of Values. Provide dollar value in each column for each line item for portion of work performed and for stored products.
- G. List each authorized Change Order as a separate line item, listing Change Order number and dollar amount as for an original item of work.
- H. Submit one electronic and Zero hard-copies of each Application for Payment.
- I. Include the following with the application:
 - 1. Transmittal letter as specified for submittals in Section 01 3000.
 - 2. Construction progress schedule, revised and current as specified in Section 01 3000.
 - 3. Partial release of liens from major subcontractors and vendors.
 - 4. Release of liens from General Contractor.

- 5. Affidavits attesting to off-site stored products.
- J. When Architect requires substantiating information, submit data justifying dollar amounts in question. For stored material provide:
 - 1. Certificate of Insurance from subcontractor for stored material.
 - 2. Invoices showing dollar amount of stored material. Only material cost can be invoiced for stored material.
 - 3. Photos of stored material with labels visable of project material is designated for.

1.05 MODIFICATION PROCEDURES

- A. For minor changes not involving an adjustment to the Contract Sum or Contract Time, Architect will issue instructions directly to Contractor.
- B. For other required changes, Architect will issue a document instructing Contractor to proceed with the change, for subsequent inclusion in a Change Order.
 - 1. The document will describe the required changes and will designate method of determining any change in Contract Sum or Contract Time.
 - 2. Promptly execute the change.
- C. For changes for which advance pricing is desired, Architect will issue a document that includes a detailed description of a proposed change with supplementary or revised drawings and specifications, a change in Contract Time for executing the change with a stipulation of any overtime work required and the period of time during which the requested price will be considered valid. Contractor shall prepare and submit a fixed price quotation within 10 days.
- Computation of Change in Contract Amount: As specified in the Agreement and Conditions of the Contract.
 - 1. For change requested by Architect for work falling under a fixed price contract, the amount will be based on Contractor's price quotation.
 - 2. For change requested by Contractor, the amount will be based on the Contractor's request for a Change Order as approved by Architect.
 - 3. For pre-determined unit prices and quantities, the amount will be based on the fixed unit prices.
- E. Substantiation of Costs: Provide full information required for evaluation.
 - 1. On request, provide the following data:
 - a. Quantities of products, labor, and equipment.
 - b. Overhead and profit.
 - c. Justification for any change in Contract Time.
 - d. Credit for deletions from Contract, similarly documented.
 - 2. Support each claim for additional costs with additional information:
 - a. Origin and date of claim.
 - b. Dates and times work was performed, and by whom.
 - c. Time records and wage rates paid.
 - Invoices and receipts for products, equipment, and subcontracts, similarly documented.
 - 3. For Time and Material work, submit itemized account and supporting data after completion of change, within time limits indicated in the Conditions of the Contract.
- F. Execution of Change Orders: Architect will issue Change Orders for signatures of parties as provided in the Conditions of the Contract.
- G. After execution of Change Order, promptly revise Schedule of Values and Application for Payment forms to record each authorized Change Order as a separate line item and adjust the Contract Sum.
- H. Promptly revise progress schedules to reflect any change in Contract Time, revise subschedules to adjust times for other items of work affected by the change, and resubmit.
- I. Promptly enter changes in Project Record Documents.

1.06 APPLICATION FOR FINAL PAYMENT

- A. Prepare Application for Final Payment as specified for progress payments, identifying total adjusted Contract Sum, previous payments, and sum remaining due.
- B. Application for Final Payment will not be considered until the following have been accomplished:
 - 1. All closeout procedures specified in Section 01 7000.



SECTION 01 2100 ALLOWANCES

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Building permit allowance.

1.02 BUILDING PERMIT ALLOWANCE

- A. Costs Included in Building Permit Allowance: Cost of the Building permit to Contractor
- B. Costs Not Included in Cash Allowances: Trade permits, inspections and testing.
- C. Contractor Responsibilities:
 - 1. Pay for and pick up the Building Permit at the Offices of the Miami County Department of Building regulations. Assist Architect in selection of products, suppliers, and installers.
 - 2. Submit to the Architect and Owner invoice for Building Permit cost.
- D. Differences in costs will be adjusted by Change Order.

1.03 ALLOWANCES SCHEDULE

A. Section 00-4100: Include the stipulated sum of \$5,000.00 for purchase and delivery of Building Permit.

PART 2 PRODUCTS - NOT USED PART 3 EXECUTION - NOT USED



SECTION 01 2200 UNIT PRICES

PART 1 GENERAL

1.01 SECTION INCLUDES

1.02 COSTS INCLUDED

A. Unit Prices included on the Bid Form shall include full compensation for all required labor, products, tools, equipment, plant, transportation, services and incidentals; erection, application or installation of an item of the Work; overhead and profit.

1.03 UNIT QUANTITIES SPECIFIED

A. Quantities indicated in the Bid Form are for bidding and contract purposes only. Quantities and measurements of actual Work will determine the payment amount.

1.04 PAYMENT

A. Payment for Work governed by unit prices will be made on the basis of the actual measurements and quantities of Work that is incorporated in or made necessary by the Work and accepted by the Architect, multiplied by the unit price.

1.05 SCHEDULE OF UNIT PRICES

- A. Item: Acoustical Panel Ceiling System inclusive of grid and panels and all accessory items for a complete installation. Cost shall include labor & material for Acoustical Panel Ceiling Work. Work is inclusive of demolition of existing ACP ceilings and installation of new ACP ceilings, products as specified.; Section 09-5113.
- B. Item: Tile Carpeting inclusive of flooring, adhesive and all accessories for a complete installation. Cost shall include labor & material for Carpet Tile flooring Work. Work is inclusive of demolition of existing carpet flooring and installation of new Carpet Tile, products as specified.; Section 09 6813.

PART 2 PRODUCTS - NOT USED PART 3 EXECUTION - NOT USED



SECTION 01 2500 SUBSTITUTION PROCEDURES

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Procedural requirements for proposed substitutions.

1.02 RELATED REQUIREMENTS

- A. Section 00 2113 Instructions to Bidders: Restrictions on timing of substitution requests.
- B. Section 01 3000 Administrative Requirements: Submittal procedures, coordination.
- C. Section 01 6000 Product Requirements: Fundamental product requirements, product options, delivery, storage, and handling.

1.03 DEFINITIONS

- A. Substitutions: Changes from Contract Documents requirements proposed by Contractor to materials, products, assemblies, and equipment.
 - Substitutions for Cause: Proposed due to changed Project circumstances beyond Contractor's control.
 - a. Unavailability.
 - b. Regulatory changes.
 - 2. Substitutions for Convenience: Proposed due to possibility of offering substantial advantage to the Project.
 - Substitution requests offering advantages solely to the Contractor will not be considered.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 GENERAL REQUIREMENTS

- A. A Substitution Request for products, assemblies, materials, and equipment constitutes a representation that the submitter:
 - 1. Has investigated proposed product and determined that it meets or exceeds the quality level of the specified product, equipment, assembly, or system.
 - 2. Agrees to provide the same warranty for the substitution as for the specified product.
 - 3. Agrees to provide same or equivalent maintenance service and source of replacement parts, as applicable.
 - 4. Agrees to coordinate installation and make changes to other work that may be required for the work to be complete, with no additional cost to Owner.
 - 5. Waives claims for additional costs or time extension that may subsequently become apparent.
 - 6. Agrees to reimburse Owner and Architect for review or redesign services associated with re-approval by authorities.
- B. A Substitution Request for specified installer constitutes a representation that the submitter:
 - 1. Has acted in good faith to obtain services of specified installer, but was unable to come to commercial, or other terms.
- C. Document each request with complete data substantiating compliance of proposed substitution with Contract Documents. Burden of proof is on proposer.
 - 1. Note explicitly any non-compliant characteristics.
- D. Content: Include information necessary for tracking the status of each Substitution Request, and information necessary to provide an actionable response.
 - 1. No specific form is required. Contractor's Substitution Request documentation must include the following:
 - a. Project Information:

- Official project name and number, and any additional required identifiers established in Contract Documents.
- 2) Owner's, Architect's, and Contractor's names.
- b. Substitution Request Information:
 - 1) Discrete and consecutive Substitution Request number, and descriptive subject/title.
 - 2) Indication of whether the substitution is for cause or convenience.
 - 3) Issue date.
 - 4) Reference to particular Contract Document(s) specification section number, title, and article/paragraph(s).
 - 5) Description of Substitution.
 - 6) Reason why the specified item cannot be provided.
 - 7) Differences between proposed substitution and specified item.
 - 8) Description of how proposed substitution affects other parts of work.
- c. Attached Comparative Data: Provide point-by-point, side-by-side comparison addressing essential attributes specified, as appropriate and relevant for the item:
 - 1) Physical characteristics.
 - 2) In-service performance.
 - 3) Expected durability.
 - 4) Visual effect.
 - 5) Warranties.
 - 6) Other salient features and requirements.
 - 7) Include, as appropriate or requested, the following types of documentation:
 - (a) Product Data:
 - (b) Samples.
 - (c) Certificates, test, reports or similar qualification data.
- d. Impact of Substitution:
 - 1) Savings to Owner for accepting substitution.
 - 2) Change to Contract Time due to accepting substitution.
- E. Limit each request to a single proposed substitution item.
 - 1. Submit an electronic document, combining the request form with supporting data into single document.

3.02 SUBSTITUTION PROCEDURES DURING PROCUREMENT

- A. Submittal Time Restrictions:
 - 1. Section 00 2113 Instructions to Bidders specifies time restrictions and the documents required for submitting substitution requests during the bidding period.

3.03 SUBSTITUTION PROCEDURES DURING CONSTRUCTION

- A. Architect will consider requests for substitutions only within 15 days after date of Agreement.
- B. Submit request for Substitution for Cause within 14 days of discovery of need for substitution, but not later than 14 days prior to time required for review and approval by Architect, in order to stay on approved project schedule.
- C. Submit request for Substitution for Convenience within 14 days of discovery of its potential advantage to the project, but not later than 14 days prior to time required for review and approval by Architect, in order to stay on approved project schedule.
 - 1. In addition to meeting general documentation requirements, document how the requested substitution benefits the Owner through cost savings, time savings, greater energy conservation, or in other specific ways.
 - 2. Document means of coordinating of substitution item with other portions of the work, including work by affected subcontractors.
 - 3. Bear the costs engendered by proposed substitution of:

- a. Owner's compensation to the Architect for any required redesign, time spent processing and evaluating the request.
- b. Other construction by Owner.
- c. Other unanticipated project considerations.
- D. Substitutions will not be considered under one or more of the following circumstances:
 - 1. When they are indicated or implied on shop drawing or product data submittals, without having received prior approval.
 - 2. Without a separate written request.
 - 3. When acceptance will require revisions to Contract Documents.

3.04 RESOLUTION

- A. Architect may request additional information and documentation prior to rendering a decision. Provide this data in an expeditious manner.
- B. Architect will notify Contractor in writing of decision to accept or reject request.
 - 1. Architect's decision following review of proposed substitution will be noted on the submitted form.

3.05 ACCEPTANCE

A. Accepted substitutions change the work of the Project. They will be documented and incorporated into work of the project by Change Order, Construction Change Directive, Architectural Supplementary Instructions, or similar instruments provided for in the Conditions of the Contract.

3.06 CLOSEOUT ACTIVITIES

A. See Section 01 7800 - Closeout Submittals, for closeout submittals.

3.07 ATTACHMENTS

A. A facsimile of the Substitution Request Form (During Construction) required to be used on the Project is included after this section.



Agreement & Waiver For Transfer and Use of Architectural Electronic Files



615 Woodside Drive, Englewood, Ohio 45322 T 937.836.8898 F 937.832.3696

www.app-arch.com

PROJECT:			
•			
OWNER:			

You (hereinafter "User") have requested App Architecture (hereinafter "AA") provide electronic files, which may include BIM files, (hereinafter "Electronic Files) for User's convenience and use in the preparation of shop drawings/coordination drawings related to this project only. AA is willing to accommodate this request subject to the following terms and conditions:

AA and User fully understand that the data contained in these Electronic Files are part of AA's Instruments of Service, AA shall be deemed the author of the drawings and data, and shall retain all common law, statutory law, and other rights. Modifications to the Electronic Files are to be made only by AA or its Subconsultants through the RFI process. User shall not transfer the Electronic Files to any other party without the express written authorization of AA. These files are not a product and shall not be used by User or anyone else receiving this data through or from User for any other purpose other than as a convenience as described above. AA makes no warranties, either express or implied, of merchantability and fitness for any particular purpose. Furthermore, any description of said Electronic Files shall not be deemed to create an implied or express warranty that such Electronic Files shall conform to said description.

User understands and accepts that Electronic Files deteriorate or can be modified inadvertently or otherwise without authorization by AA. Therefore, AA may remove all indication of its ownership or involvement from these Electronic Files. Furthermore, AA makes no representations as to compatibility, usability or readability of the files resulting from the use of software, application packages, operating systems, or computer hardware differing from those of AA. Nor does AA make any representation that these Electronic Files will have any particular durability or that they will not damage or impair the User's computer or software.

The User acknowledges that the furnishing of these files in no way relieves the User from the responsibility for the preparation of shop drawings or other schedules as required by the Contract between the Contractor and the Owner including the need to check, confirm and coordinate the work with that of other contractors for this project.

User understands that these Electronic Files are not contract documents, they do not contain all the information of the contract documents. Significant differences may exist between these Electronic Files and corresponding hard copy documents due to addenda, change orders, revisions, layer visibility or other reasons. AA makes no representations as to the accuracy or completeness of these Electronic Files. User understands and agrees that in the event of a conflict, printed hard copy drawings and specifications issued by AA shall take precedence over Electronic Files. User understands and agrees that User alone is completely responsible, without limitation, to check and otherwise confirm the accuracy of all data on these Electronic Files. The User recognizes that the

6/24/2022 Page 1 of 3

AA does not have, and will not have, any duty or obligation to advise or give notice to the User of any future revisions or modifications to the originating Electronic Files.

The User acknowledges that the Electronic Files provided by AA are a graphical representation of the building in order to generate two-dimensional industry standard drawings. A Revit model will contain both 2D and 3D components. The data contained in the Electronic Files may not be 100% accurate and should not be used for dimensional control, building layout or similar purposes. Additionally, the User acknowledges that the information in the Electronic Files should be use for comparative purposes only and shall not be relied upon for accurate quantity estimates.

The User shall assume all risks and liabilities resulting from use of these Electronic Files. User agrees to make no claims and hereby waives, to the fullest extent permitted by law, any claims or causes of action of any nature whatsoever, including claims for consequential damages, against AA, its officers, directors, employees, agents, or sub-consultants which may arise out of or in connection with the use of the Electronic Files. Furthermore, User shall, to the fullest extent permitted by law, indemnify, defend, and hold harmless AA, its officers, directors, employees, agents, or sub-consultants from and against all claims, damages, losses, and expenses, including attorney fees, arising out of, or related to User's, or anyone else receiving this data through or from User, use of the Electronic Files. If User reproduces the Electronic Files or creates a derivative work based upon them, User shall remove or completely obliterate any professional seals, logos, and other indications on the documents of the identity of AA, its officers, directors, employees, agents, or sub-consultants.

Neither this Agreement nor use of these files shall alter the contractor's Contract for Construction in any way.

□.DWG Format – List drawing sheets requested:

The User agrees that the AA shall have no responsibility whatsoever for problems of any nature

arising from transmitting and storing electronic files at a User requested FTP site or project management site or the conversion of the Electronic Files by the User or others for use in non-native applications. AA will not provide Electronic Files in compressed formats. The User agrees to accept the files in the format provided by AA, and that the User's conversion or electronic file storage at the User's at the User's requested site, shall be at the User's sole risk.

AA, at its sole discretion, may modify the Electronic Files before they are provided to the User. Such modifications may include, but are not limited to, removal of certain information. AA, at its sole discretion, may refuse to provide some or all Electronic Files requested by the User.

The availability of Electronic Files that were not prepared by AA is subject to the consent of the Owner and/or consultant that prepared those Electronic Files. AA will not negotiate with the Owner or consultant or repeatedly solicit the Owner or consultant to obtain consent. Neither this

6/24/2022 Page 2 of 3

USER (FIRM NAME): _______ DATE: ______

ADDRESS: ______

CITY: ______ STATE: _____ ZIP: ______

PHONE NO.: ______

SIGNED: _____ EMAIL: ______

Agreement and Waiver for Transfer and Use of Electronic Files nor any such separate Consultant's

consent may be assigned or transferred by the User to any other person or entity.

6/24/2022 Page 3 of 3



SECTION 01 3000 ADMINISTRATIVE REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. General administrative requirements.
- B. Web-based project software service.
- C. Preconstruction meeting.
- D. Progress meetings.
- E. Construction progress schedule.
- F. Contractor's daily reports.
- G. Progress photographs.
- H. Submittals for review, information, and project closeout.
- Number of copies of submittals.
- J. Requests for Interpretation (RFI) procedures.
- K. Submittal procedures.

1.02 RELATED REQUIREMENTS

- A. Section 00 7200 General Conditions: Dates for applications for payment.
- B. Section 01 6000 Product Requirements: General product requirements.
- C. Section 01 7000 Execution and Closeout Requirements: Additional coordination requirements.
- D. Section 01 7800 Closeout Submittals: Project record documents; operation and maintenance data: warranties and bonds.

1.03 GENERAL ADMINISTRATIVE REQUIREMENTS

- A. Comply with requirements of Section 01 7000 Execution and Closeout Requirements for coordination of execution of administrative tasks with timing of construction activities.
- B. Make the following types of submittals to Architect:
 - 1. Requests for Interpretation (RFI).
 - 2. Requests for substitution.
 - 3. Shop drawings, product data, and samples.
 - 4. Test and inspection reports.
 - 5. Design data.
 - 6. Manufacturer's instructions and field reports.
 - 7. Applications for payment and change order requests.
 - 8. Progress schedules.
 - 9. Coordination drawings.
 - 10. Correction Punch List and Final Correction Punch List for Substantial Completion.
 - 11. Closeout submittals.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 WEB-BASED PROJECT SOFTWARE SERVICE

- A. Web-Based Project Software Service: Provide, administer, and use web-based project software to host and manage project communication and documentation.
 - 1. Include, at minimum, the following features:
 - a. Project directory, including Owner, Contractor, subcontractors, Architect, Architect's consultants, and other entities involved in the project. Include names of contact

- persons and contact information for each entity.
- b. Access control for each entity and for each workflow process to determine each entity's digital rights to create, modify, view, and print documents.
- c. Workflow planning, allowing customization of workflow for each project entity.
- d. Creation, logging, tracking, and notification for project communications.
- e. Tracking of project communication statuses in real time, including timestamped response log.
- f. Procedures for viewing PDFs or similar file formats, allowing markups by each entity. Provide security features to lock markups against changes once submitted.
- g. Processing and tracking of payment applications.
- h. Processing and tracking of contract modifications.
- i. Creation and distribution of meeting minutes.
- j. Document management for drawings, specifications, and coordination drawings, including revision control.
- k. Management of construction progress photographs.
- I. Mobile device compatibility.
- m. Creation of data analytics reports.
- n. Creation and export of editable logs for software functions. Provide Owner, Architect, and Architect's consultants with rights and ability to download logs when requested.
- 2. Provide up to 20 user licenses for use by Owner, Architect, Architect's consultants, and other entities involved in the project.
- 3. Comply with the software service's current published licensing agreements.
- 4. Training: Provide one-hour, web-based training session for users of software service. Further training is the responsibility of the user.
 - a. Representatives of Owner are scheduled and included in this training.
- 5. Project Closeout: Architect determines when to terminate the software service for the project and is responsible for obtaining archive copies of files for Owner.
- 6. Web-Based Project Software Services: The selected service is:

3.02 PRECONSTRUCTION MEETING

- A. Architect will schedule a meeting after Notice of Award.
- B. Attendance Required:
 - 1. Owner.
 - 2. Architect.
 - Contractor.
 - 4. Contractor's Superintendent.

C. Agenda:

- 1. Execution of Owner-Contractor Agreement.
- 2. Submission of executed bonds and insurance certificates.
- 3. Distribution of Contract Documents.
- 4. Submission of list of subcontractors, list of products, schedule of values, and progress schedule.
- 5. Submission of initial Submittal schedule.
- 6. Designation of personnel representing the parties to Contract, _____ and Architect
- 7. Procedures and processing of field decisions, submittals, substitutions, applications for payments, proposal request, Change Orders, and Contract closeout procedures.
- 8. Scheduling.
- D. Record minutes and distribute copies within two days after meeting to participants, with two copies to Architect, Owner, participants, and those affected by decisions made.

3.03 PROGRESS MEETINGS

 Schedule and administer meetings throughout progress of the work at maximum bi-monthly intervals.

- B. Make arrangements for meetings, prepare agenda with copies for participants, preside at meetings.
- C. Attendance Required:
 - Contractor.
 - Owner.
 - Architect.
 - 4. Contractor's superintendent.
 - 5. Major subcontractors.

D. Agenda:

- 1. Review minutes of previous meetings.
- Review of work progress.
- 3. Field observations, problems, and decisions.
- 4. Identification of problems that impede, or will impede, planned progress.
- 5. Review of submittals schedule and status of submittals.
- 6. Review of RFIs log and status of responses.
- 7. Maintenance of progress schedule.
- 8. Corrective measures to regain projected schedules.
- 9. Planned progress during succeeding work period.
- 10. Maintenance of quality and work standards.
- 11. Effect of proposed changes on progress schedule and coordination.
- 12. Other business relating to work.
- E. Record minutes and distribute copies within two days after meeting to participants, with two copies to Architect, Owner, participants, and those affected by decisions made.

3.04 CONSTRUCTION PROGRESS SCHEDULE

- A. Within 10 days after date of the Agreement, submit preliminary schedule defining planned operations for the first 60 days of work, with a general outline for remainder of work.
- B. If preliminary schedule requires revision after review, submit revised schedule within 10 days.
- C. Within 20 days after review of preliminary schedule, submit draft of proposed complete schedule for review.
 - Include written certification that major contractors have reviewed and accepted proposed schedule.
- D. Within 10 days after joint review, submit complete schedule.
- E. Submit updated schedule with each Application for Payment.

3.05 DAILY CONSTRUCTION REPORTS

- A. Include only factual information. Do not include personal remarks or opinions regarding operations and/or personnel.
- B. Prepare a daily construction report recording the following information concerning events at Project site and project progress:
 - 1. Date.
 - 2. High and low temperatures, and general weather conditions.
 - 3. List of subcontractors at Project site.
 - 4. List of separate contractors at Project site.
 - 5. Approximate count of personnel at Project site.
 - 6. Major equipment at Project site.
 - 7. Material deliveries.
 - 8. Safety, environmental, or industrial relations incidents.
 - 9. Meetings and significant decisions.
 - 10. Unusual events (submit a separate special report).

- 11. Stoppages, delays, shortages, and losses. Include comparison between scheduled work activities (in Contractor's most recently updated and published schedule) and actual activities. Explain differences, if any. Note days or periods when no work was in progress and explain the reasons why.
- 12. Testing and/or inspections performed.
- 13. Signature of Contractor's authorized representative.

3.06 PROGRESS PHOTOGRAPHS

- A. Maintain access to daily/weekly electronic photographs at project site for reference.
- B. Take photographs as evidence of existing project conditions as follows:
 - 1. Interior views: As work progresses.
- C. Digital Photographs: 24 bit color, minimum resolution of 1024 by 768, in JPG format; provide files unaltered by photo editing software.
 - 1. Delivery Medium: Via email.
 - 2. File Naming: Include project identification, date and time of view, and view identification.
 - 3. PDF File: Assemble all photos into printable pages in PDF format, with 2 to 3 photos per page, each photo labeled with file name; one PDF file per submittal.

3.07 REQUESTS FOR INTERPRETATION (RFI)

- A. Preparation: Prepare an RFI immediately upon discovery of a need for interpretation of Contract Documents. Failure to submit a RFI in a timely manner is not a legitimate cause for claiming additional costs or delays in execution of the work.
 - 1. Prepare a separate RFI for each specific item.
 - a. Review, coordinate, and comment on requests originating with subcontractors and/or materials suppliers.
 - 2. Prepare in a format and with content acceptable to Owner.
- B. Reason for the RFI: Prior to initiation of an RFI, carefully study all Contract Documents to confirm that information sufficient for their interpretation is definitely not included.
 - 1. Include in each request Contractor's signature attesting to good faith effort to determine from Contract Documents information requiring interpretation.
 - 2. Unacceptable Uses for RFIs: Do not use RFIs to request the following::
 - a. Approval of submittals (use procedures specified elsewhere in this section).
 - b. Approval of substitutions (see Section 01 6000 Product Requirements)
 - c. Changes that entail change in Contract Time and Contract Sum (comply with provisions of the Conditions of the Contract).
 - d. Different methods of performing work than those indicated in the Contract Drawings and Specifications (comply with provisions of the Conditions of the Contract).
 - 3. Improper RFIs: Requests not prepared in compliance with requirements of this section, and/or missing key information required to render an actionable response. They will be returned without a response, with an explanatory notation.
 - 4. Frivolous RFIs: Requests regarding information that is clearly indicated on, or reasonably inferable from, Contract Documents, with no additional input required to clarify the question. They will be returned without a response, with an explanatory notation.
 - a. The Owner reserves the right to assess the Contractor for the costs (on time-and-materials basis) incurred by the Architect, and any of its consultants, due to processing of such RFIs.
- C. Content: Include identifiers necessary for tracking the status of each RFI, and information necessary to provide an actionable response.
 - 1. Official Project name and number, and any additional required identifiers established in Contract Documents.
 - 2. Owner's, Architect's, and Contractor's names.
 - 3. Discrete and consecutive RFI number, and descriptive subject/title.
 - 4. Issue date, and requested reply date.

- 5. Reference to particular Contract Document(s) requiring additional information/interpretation. Identify pertinent drawing and detail number and/or specification section number, title, and paragraph(s).
- 6. Annotations: Field dimensions and/or description of conditions which have engendered the request.
- 7. Contractor's suggested resolution: A written and/or a graphic solution, to scale, is required in cases where clarification of coordination issues is involved, for example; routing, clearances, and/or specific locations of work shown diagrammatically in Contract Documents. If applicable, state the likely impact of the suggested resolution on Contract Time or the Contract Sum.
- D. Attachments: Include sketches, coordination drawings, descriptions, photos, submittals, and other information necessary to substantiate the reason for the request.
- E. RFI Log: Prepare and maintain a tabular log of RFIs for the duration of the project.
 - 1. Indicate current status of every RFI. Update log promptly and on a regular basis.
 - 2. Note dates of when each request is made, and when a response is received.
 - 3. Highlight items requiring priority or expedited response.
 - 4. Highlight items for which a timely response has not been received to date.
- F. Review Time: Architect will respond and return RFIs to Contractor within seven calendar days of receipt. For the purpose of establishing the start of the mandated response period, RFIs received after 12:00 noon will be considered as having been received on the following regular working day.
 - 1. Response period may be shortened or lengthened for specific items, subject to mutual agreement, and recorded in a timely manner in progress meeting minutes.
- G. Responses: Content of answered RFIs will not constitute in any manner a directive or authorization to perform extra work or delay the project. If in Contractor's belief it is likely to lead to a change to Contract Sum or Contract Time, promptly issue a notice to this effect, and follow up with an appropriate Change Order request to Owner.
 - 1. Response may include a request for additional information, in which case the original RFI will be deemed as having been answered, and an amended one is to be issued forthwith. Identify the amended RFI with an R suffix to the original number.
 - 2. Do not extend applicability of a response to specific item to encompass other similar conditions, unless specifically so noted in the response.
 - 3. Upon receipt of a response, promptly review and distribute it to all affected parties, and update the RFI Log.
 - Notify Architect within seven calendar days if an additional or corrected response is required by submitting an amended version of the original RFI, identified as specified above.

3.08 SUBMITTAL SCHEDULE

- A. Submit to Architect for review a schedule for submittals in tabular format.
 - 1. Submit at the same time as the preliminary schedule specified in Section 01 3216 Construction Progress Schedule.
 - 2. Coordinate with Contractor's construction schedule and schedule of values.
 - 3. Arrange information to include scheduled date for initial submittal, specification number and title, submittal category (for review or for information), description of item of work covered, and role and name of subcontractor.
 - 4. Account for time required for preparation, review, manufacturing, fabrication and delivery when establishing submittal delivery and review deadline dates.
 - a. For assemblies, equipment, systems comprised of multiple components and/or requiring detailed coordination with other work, allow for additional time to make corrections or revisions to initial submittals, and time for their review.

3.09 SUBMITTALS FOR REVIEW

A. When the following are specified in individual sections, submit them for review:

WAGNER AVENUE INTERIOR RENOVATION

- 1. Product data.
- 2. Shop drawings.
- 3. Samples for selection.
- 4. Samples for verification.
- B. Submit to Architect for review for the limited purpose of checking for compliance with information given and the design concept expressed in Contract Documents.
- C. Samples will be reviewed for aesthetic, color, or finish selection.
- D. After review, provide copies and distribute in accordance with SUBMITTAL PROCEDURES article below and for record documents purposes described in Section 01 7800 - Closeout Submittals.

3.10 SUBMITTALS FOR INFORMATION

- A. When the following are specified in individual sections, submit them for information:
 - Design data.
 - Certificates.
 - 3. Test reports.
 - 4. Inspection reports.
 - 5. Manufacturer's instructions.
 - 6. Manufacturer's field reports.
 - 7. Other types indicated.
- B. Submit for Architect's knowledge as contract administrator or for Owner.

3.11 SUBMITTALS FOR PROJECT CLOSEOUT

- A. Submit Correction Punch List for Substantial Completion.
- B. Submit Final Correction Punch List for Substantial Completion.
- C. When the following are specified in individual sections, submit them at project closeout in compliance with requirements of Section 01 7800 Closeout Submittals:
 - 1. Project record documents.
 - 2. Operation and maintenance data.
 - 3. Warranties.
 - 4. Bonds.
 - 5. Other types as indicated.
- D. Submit for Owner's benefit during and after project completion.

3.12 NUMBER OF COPIES OF SUBMITTALS

- A. Electronic Documents: Submit one electronic copy in PDF format; an electronically-marked up file will be returned. Create PDFs at native size and right-side up; illegible files will be rejected.
- B. Samples: Submit the number specified in individual specification sections; one of which will be retained by Architect.
 - 1. After review, produce duplicates.
 - 2. Retained samples will not be returned to Contractor unless specifically so stated.

3.13 SUBMITTAL PROCEDURES

- A. General Requirements:
 - 1. Use a separate transmittal for each item.
 - 2. Use a single transmittal for related items.
 - Sequentially identify each item. For revised submittals use original number and a sequential numerical suffix.
 - 4. Identify: Project; Contractor; subcontractor or supplier; pertinent drawing and detail number; and specification section number and article/paragraph, as appropriate on each copy.

- 5. Apply Contractor's stamp, signed or initialed certifying that review, approval, verification of products required, field dimensions, adjacent construction work, and coordination of information is in accordance with the requirements of the work and Contract Documents.
 - Submittals from sources other than the Contractor, or without Contractor's stamp will
 not be acknowledged, reviewed, or returned.
- 6. Deliver each submittal on date noted in submittal schedule, unless an earlier date has been agreed to by all affected parties, and is of the benefit to the project.
 - a. Upload submittals in electronic form to Electronic Document Submittal Service website.
- 7. Schedule submittals to expedite the Project, and coordinate submission of related items.
 - a. For each submittal for review, allow 15 days excluding delivery time to and from the Contractor.
 - b. For sequential reviews involving Architect's consultants, Owner, or another affected party, allow an additional 7 days.
- 8. Identify variations from Contract Documents and product or system limitations that may be detrimental to successful performance of the completed work.
- 9. Provide space for Contractor and Architect review stamps.
- 10. When revised for resubmission, identify all changes made since previous submission.
- 11. Distribute reviewed submittals. Instruct parties to promptly report inability to comply with requirements.
- 12. Incomplete submittals will not be reviewed, unless they are partial submittals for distinct portion(s) of the work, and have received prior approval for their use.

B. Product Data Procedures:

- 1. Submit only information required by individual specification sections.
- 2. Collect required information into a single submittal.
- 3. Submit concurrently with related shop drawing submittal.
- 4. Do not submit (Material) Safety Data Sheets for materials or products.

C. Shop Drawing Procedures:

- 1. Prepare accurate, drawn-to-scale, original shop drawing documentation by interpreting Contract Documents and coordinating related work.
- 2. Do not reproduce Contract Documents to create shop drawings.
- 3. Generic, non-project-specific information submitted as shop drawings do not meet the requirements for shop drawings.

D. Samples Procedures:

- 1. Transmit related items together as single package.
- Identify each item to allow review for applicability in relation to shop drawings showing installation locations.

3.14 SUBMITTAL REVIEW

- A. Submittals for Review: Architect will review each submittal, and approve, or take other appropriate action.
- B. Submittals for Information: Architect will acknowledge receipt and review. See below for actions to be taken.
- C. Architect's actions will be reflected by marking each returned submittal using virtual stamp on electronic submittals.
 - Notations may be made directly on submitted items and/or listed on appended Submittal Review cover sheet.
- D. Architect's and consultants' actions on items submitted for review:
 - 1. Authorizing purchasing, fabrication, delivery, and installation:
 - a. "Reviewed", or language with same legal meaning.
 - b. "Reviewed as Noted", or language with same legal meaning.

- 1) At Contractor's option, submit corrected item, with review notations acknowledged and incorporated.
- c. "Reviewed as Noted, Resubmit for Record", or language with same legal meaning.
 - 1) Resubmit corrected item, with review notations acknowledged and incorporated. Resubmit separately, or as part of project record documents.
- 2. Not Authorizing fabrication, delivery, and installation:
 - a. "Revise and Resubmit".
 - 1) Resubmit revised item, with review notations acknowledged and incorporated.
 - 2) Non-responsive resubmittals may be rejected.
 - b. "Rejected".
 - 1) Submit item complying with requirements of Contract Documents.
- E. Architect's and consultants' actions on items submitted for information:
 - 1. Items for which no action was taken:
 - a. "Received" to notify the Contractor that the submittal has been received for record only.
 - 2. Items for which action was taken:
 - a. "Reviewed" no further action is required from Contractor.

SECTION 01 5000 TEMPORARY FACILITIES AND CONTROLS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Temporary utilities.
- B. Temporary telecommunications services.
- C. Temporary sanitary facilities.
- D. Temporary Controls: Barriers, enclosures, and fencing.
- E. Security requirements.
- F. Vehicular access and parking.
- G. Waste removal facilities and services.
- H. Field offices.

1.02 RELATED REQUIREMENTS

- A. Section 01 5100 Temporary Utilities.
- B. Section 01 5213 Field Offices and Sheds.
- C. Section 01 5500 Vehicular Access and Parking.

1.03 TEMPORARY UTILITIES - SEE SECTION 01 5100

- A. Owner will provide the following:
 - Electrical power. Contractor responsable for connection to existing facilities and distribution.
 - 2. Water supply. Contractor responsible for connection to existing facilities and distribution.

1.04 TELECOMMUNICATIONS SERVICES

- Provide, maintain, and pay for telecommunications services to field office at time of project mobilization.
- B. Telecommunications services shall include:
 - 1. Internet Connections: Minimum of one; DSL modem or faster.
 - 2. Email: Account/address reserved for project use.
 - 3. Project web site.

1.05 TEMPORARY SANITARY FACILITIES

- A. Provide and maintain required facilities and enclosures. Provide at time of project mobilization.
- B. Maintain daily in clean and sanitary condition.

1.06 BARRIERS

- A. Provide barriers to prevent unauthorized entry to construction areas, to prevent access to areas that could be hazardous to workers or the public, to allow for owner's use of site and to protect existing facilities and adjacent properties from damage from construction operations and demolition.
- B. Provide barricades and covered walkways required by governing authorities for public rights-of-way and for public access to existing building.
- C. Protect non-owned vehicular traffic, stored materials, site, and structures from damage.
- D. Traffic Controls: Comply with requirements of authorities having jurisdiction..

1.07 FENCING

A. Contractor's option to provide 6 foot high fence around outside staging area for dumpster and equipment. Provide gates with locks.

1.08 INTERIOR ENCLOSURES

- A. Provide temporary partitions and ceilings as indicated to separate work areas from Owner-occupied areas, to prevent penetration of dust and moisture into Owner-occupied areas, and to prevent damage to existing materials and equipment.
- B. Construction: Framing and reinforced polyethylene sheet materials with closed joints and sealed edges at intersections with existing surfaces:

1.09 SECURITY - SEE SECTION 01 3553

A. Provide security and facilities to protect Work, existing facilities, and Owner's operations from unauthorized entry, vandalism, or theft.

1.10 VEHICULAR ACCESS AND PARKING - SEE SECTION 01 5500

- A. Comply with regulations relating to use of streets and sidewalks, access to emergency facilities, and access for emergency vehicles.
- B. Coordinate access and haul routes with governing authorities and Owner.
- C. Provide and maintain access to fire hydrants, free of obstructions.
- D. Existing parking spaces behind the building are available to accommodate construction personnel. When back of building space is not adequate spaces at the street end of the front parking lot can be used.
- E. Maintain access for staff and County vehicles at the back of the building.

1.11 WASTE REMOVAL

- A. Provide waste removal facilities and services as required to maintain the site in clean and orderly condition.
- B. Provide containers with lids. Remove trash from site periodically.
- C. If materials to be recycled or re-used on the project must be stored on-site, provide suitable non-combustible containers; locate containers in a safe and secure location protected from the weather.
- D. Open free-fall chutes are not permitted. Terminate closed chutes into appropriate containers with lids.

1.12 FIELD OFFICES - SEE SECTION 01 5213

- A. Owner will provide (1) room in the area of work for Contractor's field office.
- B. Contractor shall provide furniture for field office, inclusive of table and chairs for project meetings.

1.13 REMOVAL OF UTILITIES, FACILITIES, AND CONTROLS

- A. Remove temporary utilities, equipment, facilities, materials, prior to Date of Substantial Completion inspection.
- B. Remove underground installations to a minimum depth of 2 feet. Grade site as indicated.
- C. Clean and repair damage caused by installation or use of temporary work.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

SECTION 01 6000 PRODUCT REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. General product requirements.
- B. Re-use of existing products.
- C. Transportation, handling, storage and protection.
- D. Product option requirements.
- E. Substitution limitations.
- F. Procedures for Owner-supplied products.
- G. Maintenance materials, including extra materials, spare parts, tools, and software.

1.02 RELATED REQUIREMENTS

- A. Section 01 1000 Summary: Identification of Owner-supplied products.
- B. Section 01 2500 Substitution Procedures: Substitutions made during procurement and/or construction phases.

1.03 DEFINITIONS

- A. Products: Items obtained for incorporating into the Work, whether purschased for Project or taken from previously purchased stock. The term "product: includes the terms "material," "equipment," "system," and terms of similar intent.
- B. BASIS-OF-DESIGN PRODUCT SPECIFICATION: A SPECIFICATION IN WHICH A SINGLE MANUFACTURER'S PRODUCT IS NAMED AND ACCOMPLANITED BY THE WORDS "BASIS-OF-DESIGN PRODUCT," INCLUDING MAKE OR MODEL NUMBER OR OTHER DESIGNATION. PUBLISHED ATTRIBUTES AND CHARACTERISTICS OF BASIS-OF-DESIGN PRODUCT ESTABLISH SALIENT CHARACTERISTICS OF PRODUCTS.

1.04 SUBMITTALS

- A. Product Data Submittals: Submit manufacturer's standard published data. Mark each copy to identify applicable products, models, options, and other data. Supplement manufacturers' standard data to provide information specific to this Project.
- B. Shop Drawing Submittals: Prepared specifically for this Project; indicate utility and electrical characteristics, utility connection requirements, and location of utility outlets for service for functional equipment and appliances.
- C. Sample Submittals: Illustrate functional and aesthetic characteristics of the product, with integral parts and attachment devices. Coordinate sample submittals for interfacing work.
 - 1. For selection from standard finishes, submit samples of the full range of the manufacturer's standard colors, textures, and patterns.

PART 2 PRODUCTS

2.01 EXISTING PRODUCTS

- A. Specific Products to be Reused: The reuse of certain materials and equipment already existing on the project site is required.
 - 1. See Section 01 1000 for list of items required to be salvaged for reuse and relocation.

2.02 NEW PRODUCTS

- A. Provide new products unless specifically required or permitted by Contract Documents.
- B. Use of products having any of the following characteristics is not permitted:
 - Made using or containing CFC's or HCFC's.
 - 2. Made of wood from newly cut old growth timber.

2.03 PRODUCT OPTIONS

- Products Specified by Reference Standards or by Description Only: Use any product meeting those standards or description.
- B. Products Specified by Naming One or More Manufacturers: Use a product of one of the manufacturers named and meeting specifications, no options or substitutions allowed.
- C. Products Specified by Naming One or More Manufacturers with a Provision for Substitutions: Submit a request for substitution for any manufacturer not named.
- D. Products Specified as Basis-of-Design: Submit substitution requests for unnamed products to Architect for evaluation.

PART 3 EXECUTION

3.01 SUBSTITUTION LIMITATIONS

A. See Section 01 2500 - Substitution Procedures.

3.02 OWNER-SUPPLIED PRODUCTS

- A. See Section 01 1000 Summary for identification of Owner-supplied products.
- B. Owner's Responsibilities:
 - 1. Arrange for and deliver Owner supplied products to the job site.
- C. Contractor's Responsibilities:
 - 1. Review Owner supplied products with the Owner prior to arrival on job site.

3.03 TRANSPORTATION AND HANDLING

- A. Coordinate schedule of product delivery to designated prepared areas in order to minimize site storage time and potential damage to stored materials.
- B. Transport and handle products in accordance with manufacturer's instructions.
- C. Promptly inspect shipments to ensure that products comply with requirements, quantities are correct, and products are undamaged.
- D. Provide equipment and personnel to handle products by methods to prevent soiling, disfigurement, or damage, and to minimize handling.
- E. Arrange for the return of packing materials, such as wood pallets, where economically feasible.

3.04 STORAGE AND PROTECTION

- A. Provide protection of stored materials and products against theft, casualty, or deterioration.
- B. Designate receiving/storage areas for incoming products so that they are delivered according to installation schedule and placed convenient to work area in order to minimize waste due to excessive materials handling and misapplication. See Section 01 7419.
- C. Store and protect products in accordance with manufacturers' instructions.
- D. Store with seals and labels intact and legible.
- E. Arrange storage of materials and products to allow for visual inspection for the purpose of determination of quantities, amounts, and unit counts.
- F. Store sensitive products in weathertight, climate-controlled enclosures in an environment favorable to product.
- G. For exterior storage of fabricated products, place on sloped supports above ground.
- H. Protect products from damage or deterioration due to construction operations, weather, precipitation, humidity, temperature, sunlight and ultraviolet light, dirt, dust, and other contaminants.
- I. Comply with manufacturer's warranty conditions, if any.
- J. Do not store products directly on the ground.

- K. Cover products subject to deterioration with impervious sheet covering. Provide ventilation to prevent condensation and degradation of products.
- L. Prevent contact with material that may cause corrosion, discoloration, or staining.
- M. Provide equipment and personnel to store products by methods to prevent soiling, disfigurement, or damage.
- N. Arrange storage of products to permit access for inspection. Periodically inspect to verify products are undamaged and are maintained in acceptable condition.



SECTION 01 7000 EXECUTION AND CLOSEOUT REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Examination, preparation, and general installation procedures.
- B. Requirements for alterations work, including selective demolition, _____.
- C. Cutting and patching.
- D. Cleaning and protection.
- E. Closeout procedures, including Contractor's Correction Punch List, except payment procedures.

1.02 RELATED REQUIREMENTS

- A. Section 01 1000 Summary: Limitations on working in existing building; continued occupancy; work sequence; identification of salvaged and relocated materials.
- B. Section 01 3000 Administrative Requirements: Submittals procedures, Electronic document submittal service.
- C. Section 01 5000 Temporary Facilities and Controls: Temporary exterior enclosures.
- D. Section 01 5000 Temporary Facilities and Controls: Temporary interior partitions.
- E. Section 01 5100 Temporary Utilities: Temporary heating, cooling, and ventilating facilities.
- F. Section 01 7800 Closeout Submittals: Project record documents, operation and maintenance data, warranties, and bonds.

1.03 SUBMITTALS

- A. See Section 01 3000 Administrative Requirements, for submittal procedures.
- B. Cutting and Patching: Submit written request in advance of cutting or alteration that affects:
 - Structural integrity of any element of Project.
 - 2. Integrity of weather exposed or moisture resistant element.
 - 3. Visual qualities of sight exposed elements.
 - 4. Work of Owner or separate Contractor.
 - 5. Include in request:
 - a. Identification of Project.
 - b. Location and description of affected work.
 - c. Necessity for cutting or alteration.
 - d. Description of proposed work and products to be used.
 - e. Effect on work of Owner or separate Contractor.
 - f. Written permission of affected separate Contractor.
 - g. Date and time work will be executed.

1.04 PROJECT CONDITIONS

- A. Ventilate enclosed areas to assist cure of materials, to dissipate humidity, and to prevent accumulation of dust, fumes, vapors, or gases.
- B. Dust Control: Execute work by methods to minimize raising dust from construction operations. Provide positive means to prevent air-borne dust from dispersing into atmosphere and over adjacent property.
 - 1. Provide dust-proof barriers between construction areas and areas continuing to be occupied by Owner.
- C. Noise Control: Provide methods, means, and facilities to minimize noise produced by construction operations.
 - 1. Indoors: Limit conduct of especially noisy interior work to the hours of 6 pm to 7 am.

1.05 COORDINATION

- A. Coordinate scheduling, submittals, and work of the various sections of the Project Manual to ensure efficient and orderly sequence of installation of interdependent construction elements, with provisions for accommodating items installed later.
- B. Notify affected utility companies and comply with their requirements.
- C. Verify that utility requirements and characteristics of new operating equipment are compatible with building utilities. Coordinate work of various sections having interdependent responsibilities for installing, connecting to, and placing in service, such equipment.
- D. Coordinate space requirements, supports, and installation of mechanical and electrical work that are indicated diagrammatically on drawings. Follow routing indicated for pipes, ducts, and conduit, as closely as practicable; place runs parallel with lines of building. Utilize spaces efficiently to maximize accessibility for other installations, for maintenance, and for repairs.
- E. In finished areas except as otherwise indicated, conceal pipes, ducts, and wiring within the construction. Coordinate locations of fixtures and outlets with finish elements.
- F. Coordinate completion and clean-up of work of separate sections.
- G. After Owner occupancy of premises, coordinate access to site for correction of defective work and work not in accordance with Contract Documents, to minimize disruption of Owner's activities.

PART 2 PRODUCTS

2.01 PATCHING MATERIALS

- A. New Materials: As specified in product sections; match existing products and work for patching and extending work.
- B. Type and Quality of Existing Products: Determine by inspecting and testing products where necessary, referring to existing work as a standard.
- C. Product Substitution: For any proposed change in materials, submit request for substitution described in Section 01 6000 Product Requirements.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that existing site conditions and substrate surfaces are acceptable for subsequent work. Start of work means acceptance of existing conditions.
- B. Verify that existing substrate is capable of structural support or attachment of new work being applied or attached.
- C. Examine and verify specific conditions described in individual specification sections.
- D. Take field measurements before confirming product orders or beginning fabrication, to minimize waste due to over-ordering or misfabrication.
- E. Verify that utility services are available, of the correct characteristics, and in the correct locations.
- F. Prior to Cutting: Examine existing conditions prior to commencing work, including elements subject to damage or movement during cutting and patching. After uncovering existing work, assess conditions affecting performance of work. Beginning of cutting or patching means acceptance of existing conditions.

3.02 PREPARATION

- A. Clean substrate surfaces prior to applying next material or substance.
- B. Seal cracks or openings of substrate prior to applying next material or substance.
- C. Apply manufacturer required or recommended substrate primer, sealer, or conditioner prior to applying any new material or substance in contact or bond.

3.03 GENERAL INSTALLATION REQUIREMENTS

- A. In addition to compliance with regulatory requirements, conduct construction operations in compliance with NFPA 241, including applicable recommendations in Appendix A.
- B. Install products as specified in individual sections, in accordance with manufacturer's instructions and recommendations, and so as to avoid waste due to necessity for replacement.
- C. Make vertical elements plumb and horizontal elements level, unless otherwise indicated.
- Install equipment and fittings plumb and level, neatly aligned with adjacent vertical and horizontal lines, unless otherwise indicated.
- E. Make consistent texture on surfaces, with seamless transitions, unless otherwise indicated.
- F. Make neat transitions between different surfaces, maintaining texture and appearance.

3.04 ALTERATIONS

- A. Drawings showing existing construction and utilities are based on casual field observation and existing record documents only.
 - 1. Verify that construction and utility arrangements are as indicated.
 - 2. Report discrepancies to Architect before disturbing existing installation.
 - 3. Beginning of alterations work constitutes acceptance of existing conditions.
- B. Keep areas in which alterations are being conducted separated from other areas that are still occupied.
 - 1. Provide, erect, and maintain temporary dustproof partitions of construction specified in Section 01 5000 in locations indicated on drawings.
- C. Remove existing work as indicated and as required to accomplish new work.
 - 1. Remove items indicated on drawings.
 - 2. Relocate items indicated on drawings.
 - Where new surface finishes are to be applied to existing work, perform removals, patch, and prepare existing surfaces as required to receive new finish; remove existing finish if necessary for successful application of new finish.
 - 4. Where new surface finishes are not specified or indicated, patch holes and damaged surfaces to match adjacent finished surfaces as closely as possible.
- D. Services (Including but not limited to HVAC, Plumbing, Fire Protection, Electrical, Telecommunications, and ______): Remove, relocate, and extend existing systems to accommodate new construction.
 - 1. Maintain existing active systems that are to remain in operation; maintain access to equipment and operational components; if necessary, modify installation to allow access or provide access panel.
 - 2. Where existing systems or equipment are not active and Contract Documents require reactivation, put back into operational condition; repair supply, distribution, and equipment as required.
 - Where existing active systems serve occupied facilities but are to be replaced with new services, maintain existing systems in service until new systems are complete and ready for service.
 - Disable existing systems only to make switchovers and connections; minimize duration of outages.
 - b. Provide temporary connections as required to maintain existing systems in service.
 - 4. Verify that abandoned services serve only abandoned facilities.
 - 5. Remove abandoned pipe, ducts, conduits, and equipment, including those above accessible ceilings; remove back to source of supply where possible, otherwise cap stub and tag with identification; patch holes left by removal using materials specified for new construction.
- E. Protect existing work to remain.
 - 1. Prevent movement of structure; provide shoring and bracing if necessary.

- Perform cutting to accomplish removals neatly and as specified for cutting new work.
- 3. Repair adjacent construction and finishes damaged during removal work.
- F. Adapt existing work to fit new work: Make as neat and smooth transition as possible.
 - 1. Where removal of partitions or walls results in adjacent spaces becoming one, rework floors, walls, and ceilings to a smooth plane without breaks, steps, or bulkheads.
- G. Patching: Where the existing surface is not indicated to be refinished, patch to match the surface finish that existed prior to cutting. Where the surface is indicated to be refinished, patch so that the substrate is ready for the new finish.
- H. Refinish existing surfaces as indicated:
 - Where rooms or spaces are indicated to be refinished, refinish all visible existing surfaces
 to remain to the specified condition for each material, with a neat transition to adjacent
 finishes.
 - 2. If mechanical or electrical work is exposed accidentally during the work, re-cover and refinish to match.
- I. Clean existing systems and equipment.
- J. Remove demolition debris and abandoned items from alterations areas and dispose of off-site; do not burn or bury.
- Do not begin new construction in alterations areas before demolition is complete. UNO
- L. Comply with all other applicable requirements of this section.

3.05 CUTTING AND PATCHING

- A. Perform whatever cutting and patching is necessary to:
 - 1. Complete the work.
 - 2. Fit products together to integrate with other work.
 - 3. Provide openings for penetration of mechanical, electrical, and other services.
 - 4. Match work that has been cut to adjacent work.
 - 5. Repair areas adjacent to cuts to required condition.
 - 6. Repair new work damaged by subsequent work.
 - 7. Remove samples of installed work for testing when requested.
 - 8. Remove and replace defective and non-complying work.
- B. Execute work by methods that avoid damage to other work and that will provide appropriate surfaces to receive patching and finishing. In existing work, minimize damage and restore to original condition.
- C. Restore work with new products in accordance with requirements of Contract Documents.
- D. Fit work air tight to pipes, sleeves, ducts, conduit, and other penetrations through surfaces.
- E. At penetrations of fire rated walls, partitions, ceiling, or floor construction, completely seal voids with fire rated material in accordance with Section 07 8400, to full thickness of the penetrated element.
- F. Patching:
 - Finish patched surfaces to match finish that existed prior to patching. On continuous surfaces, refinish to nearest intersection or natural break. For an assembly, refinish entire unit.
 - 2. Match color, texture, and appearance.
 - 3. Repair patched surfaces that are damaged, lifted, discolored, or showing other imperfections due to patching work. If defects are due to condition of substrate, repair substrate prior to repairing finish.

3.06 PROGRESS CLEANING

A. Maintain areas free of waste materials, debris, and rubbish. Maintain site in a clean and orderly condition.

- B. Remove debris and rubbish from pipe chases, plenums, attics, crawl spaces, and other closed or remote spaces, prior to enclosing the space.
- C. Broom and vacuum clean interior areas prior to start of surface finishing, and continue cleaning to eliminate dust.
- D. Collect and remove waste materials, debris, and trash/rubbish from site periodically and dispose off-site; do not burn or bury.

3.07 PROTECTION OF INSTALLED WORK

- A. Protect installed work from damage by construction operations.
- B. Provide special protection where specified in individual specification sections.
- C. Provide temporary and removable protection for installed products. Control activity in immediate work area to prevent damage.
- D. Provide protective coverings at walls, projections, jambs, sills, and soffits of openings.
- E. Protect finished floors, stairs, and other surfaces from traffic, dirt, wear, damage, or movement of heavy objects, by protecting with durable sheet materials.
- F. Remove protective coverings when no longer needed; reuse or recycle coverings if possible.

3.08 FINAL CLEANING

- A. Execute final cleaning prior to final project assessment.
 - 1. Clean areas to be occupied by Owner prior to final completion before Owner occupancy.
- B. Use cleaning materials that are nonhazardous.
- C. Clean interior and exterior glass, surfaces exposed to view; remove temporary labels, stains and foreign substances, polish transparent and glossy surfaces, vacuum carpeted and soft surfaces.
- D. Remove all labels that are not permanent. Do not paint or otherwise cover fire test labels or nameplates on mechanical and electrical equipment.
- E. Clean equipment and fixtures to a sanitary condition with cleaning materials appropriate to the surface and material being cleaned.
- F. Clean filters of operating equipment.
- G. Remove waste, surplus materials, trash/rubbish, and construction facilities from the site; dispose of in legal manner; do not burn or bury.

3.09 CLOSEOUT PROCEDURES

- A. Make submittals that are required by governing or other authorities.
- B. Notify Architect when work is considered ready for Architect's Substantial Completion inspection.
- C. Conduct Substantial Completion inspection and create Final Correction Punch List containing Architect's and Contractor's comprehensive list of items identified to be completed or corrected and submit to Architect.
- Correct items of work listed in Final Correction Punch List and comply with requirements for access to Owner-occupied areas.
- E. Notify Architect when work is considered finally complete and ready for Architect's Substantial Completion final inspection.
- F. Complete items of work determined by Architect listed in executed Certificate of Substantial Completion.



SECTION 01 7800 CLOSEOUT SUBMITTALS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Project record documents.
- B. Operation and maintenance data.
- C. Warranties and bonds.

1.02 RELATED REQUIREMENTS

- A. Section 00 7200 General Conditions and 00 7300 Supplementary Conditions: Performance bond and labor and material payment bonds, warranty, and correction of work.
- B. Section 01 3000 Administrative Requirements: Submittals procedures, shop drawings, product data, and samples.
- C. Section 01 7000 Execution and Closeout Requirements: Contract closeout procedures.
- D. Individual Product Sections: Specific requirements for operation and maintenance data.
- E. Individual Product Sections: Warranties required for specific products or Work.

1.03 SUBMITTALS

- A. Project Record Documents: Submit documents to Architect with claim for final Application for Payment.
- B. Operation and Maintenance Data:
 - 1. For equipment, or component parts of equipment put into service during construction and operated by Owner, submit completed documents within ten days after acceptance.
 - 2. Submit one copy of completed documents 15 days prior to final inspection. This copy will be reviewed and returned after final inspection, with Architect comments. Revise content of all document sets as required prior to final submission.
 - 3. Submit two sets of revised final documents in final form within 10 days after final inspection.

C. Warranties and Bonds:

- 1. For equipment or component parts of equipment put into service during construction with Owner's permission, submit documents within 10 days after acceptance.
- 2. Make other submittals within 10 days after Date of Substantial Completion, prior to final Application for Payment.
- For items of Work for which acceptance is delayed beyond Date of Substantial
 Completion, submit within 10 days after acceptance, listing the date of acceptance as the
 beginning of the warranty period.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 PROJECT RECORD DOCUMENTS

- A. Maintain on site one set of the following record documents; record actual revisions to the Work:
 - 1. Drawings.
 - 2. Addenda.
 - 3. Change Orders and other modifications to the Contract.
 - 4. Reviewed shop drawings, product data, and samples.
 - 5. Manufacturer's instruction for assembly, installation, and adjusting.
- B. Ensure entries are complete and accurate, enabling future reference by Owner.
- C. Store record documents separate from documents used for construction.
- D. Record information concurrent with construction progress.

- E. Record Drawings and Shop Drawings: Legibly mark each item to record actual construction including:
 - 1. Field changes of dimension and detail.
 - 2. Details not on original Contract drawings.

3.02 OPERATION AND MAINTENANCE DATA

- A. Source Data: For each product or system, list names, addresses and telephone numbers of Subcontractors and suppliers, including local source of supplies and replacement parts.
- B. Product Data: Mark each sheet to clearly identify specific products and component parts, and data applicable to installation. Delete inapplicable information.
- C. Drawings: Supplement product data to illustrate relations of component parts of equipment and systems, to show control and flow diagrams. Do not use Project Record Documents as maintenance drawings.
- D. Typed Text: As required to supplement product data. Provide logical sequence of instructions for each procedure, incorporating manufacturer's instructions.

3.03 OPERATION AND MAINTENANCE DATA FOR MATERIALS AND FINISHES

A. Instructions for Care and Maintenance: Manufacturer's recommendations for cleaning agents and methods, precautions against detrimental cleaning agents and methods, and recommended schedule for cleaning and maintenance.

3.04 OPERATION AND MAINTENANCE DATA FOR EQUIPMENT AND SYSTEMS

- A. For Each Item of Equipment and Each System:
 - 1. Description of unit or system, and component parts.
 - 2. Identify function, normal operating characteristics, and limiting conditions.
 - 3. Include performance curves, with engineering data and tests.
 - 4. Complete nomenclature and model number of replaceable parts.
- B. Operating Procedures: Include start-up, break-in, and routine normal operating instructions and sequences. Include regulation, control, stopping, shut-down, and emergency instructions. Include summer, winter, and any special operating instructions.
- C. Maintenance Requirements: Include routine procedures and guide for preventative maintenance and trouble shooting; disassembly, repair, and reassembly instructions; and alignment, adjusting, balancing, and checking instructions.

3.05 ASSEMBLY OF OPERATION AND MAINTENANCE MANUALS

A. Assemble digital operation and maintenance data into durable manuals for Owner's personnel use, with data arranged in the same sequence as, and identified by, the specification sections.

3.06 WARRANTIES AND BONDS

- A. Obtain warranties and bonds, executed in duplicate by responsible Subcontractors, suppliers, and manufacturers, within 10 days after completion of the applicable item of work. Except for items put into use with Owner's permission, leave date of beginning of time of warranty until Date of Substantial completion is determined.
- B. Verify that documents are in proper form, contain full information, and are notarized.
- C. Co-execute submittals when required.
- D. Retain warranties and bonds until time specified for submittal.

SECTION 02 4100 DEMOLITION

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Selective demolition of building elements for alteration purposes.

1.02 RELATED REQUIREMENTS

- A. Section 01 1000 Summary: Limitations on Contractor's use of site and premises.
- B. Section 01 5000 Temporary Facilities and Controls: Site fences, security, protective barriers, and waste removal.
- C. Section 01 7000 Execution and Closeout Requirements: Project conditions; protection of bench marks, survey control points, and existing construction to remain; reinstallation of removed products; temporary bracing and shoring.

1.03 DEFINITIONS

- A. Demolish: Dismantle, raze, destroy, or wreck any building or structure or any part thereof.
- B. Remove: Detach or dismantle items from existing construction and dispose of them off site, unless items are indicated to be salvaged or reinstalled.
- C. Remove and Salvage: Detach or dismantle items from existing construction in a manner to prevent damage. Clean, package, label and deliver salvaged items to Owner in ready-for-reuse condition.
- D. Remove and Reinstall: Detach or dismantle items from existing construction in a manner to prevent damage. Clean and prepare for reuse and reinstall where indicated.
- E. Existing to Remain: Designation for existing items that are not to be removed and that are not otherwise indicated to be salvaged or reinstalled.

PART 3 EXECUTION

2.01 GENERAL PROCEDURES AND PROJECT CONDITIONS

- A. Comply with applicable codes and regulations for demolition operations and safety of adjacent structures and the public.
 - 1. Obtain required permits.
 - Take precautions to prevent catastrophic or uncontrolled collapse of structures to be removed; do not allow worker or public access within range of potential collapse of unstable structures.
 - 3. Provide, erect, and maintain temporary barriers and security devices.
 - 4. Conduct operations to minimize effects on and interference with adjacent structures and occupants.
 - Do not close or obstruct roadways or sidewalks without permits from authority having iurisdiction.
 - 6. Conduct operations to minimize obstruction of public and private entrances and exits. Do not obstruct required exits at any time. Protect persons using entrances and exits from removal operations.
- B. Do not begin removal until built elements to be salvaged or relocated have been removed.
- C. Protect existing structures and other elements to remain in place and not removed.
- D. Minimize production of dust due to demolition operations. Do not use water if that will result in ice, flooding, sedimentation of public waterways or storm sewers, or other pollution.
- E. Hazardous Materials: It is not expected that hazardous materials will be encountered in teh Work
 - If hazardous materials are discovered during removal operations, stop work and notify Architect and Owner; hazardous materials include regulated asbestos containing materials, lead, PCBs, and mercury.

2.02 EXISTING UTILITIES

- A. Coordinate work with utility companies. Notify utilities before starting work, comply with their requirements, and obtain required permits.
- B. Protect existing utilities to remain from damage.
- C. Do not disrupt public utilities without permit from authority having jurisdiction.
- D. Do not close, shut off, or disrupt existing life safety systems that are in use without at least 7 days prior written notification to Owner.
- E. Do not close, shut off, or disrupt existing utility branches or take-offs that are in use without at least 3 days prior written notification to Owner.
- F. Remove exposed piping, valves, meters, equipment, supports, and foundations of disconnected and abandoned utilities.

2.03 SELECTIVE DEMOLITION FOR ALTERATIONS

- A. Existing construction and utilities indicated on drawings are based on casual field observation and existing record documents only.
 - 1. Verify construction and utility arrangements are as indicated.
 - 2. Report discrepancies to Architect before disturbing existing installation.
 - 3. Beginning of demolition work constitutes acceptance of existing conditions that would be apparent upon examination prior to starting demolition.
- B. Separate areas in which demolition is being conducted from areas that remain occupied.
 - 1. Provide, erect, and maintain temporary dustproof partitions of construction specified in Section 01 5000 in locations indicated on drawings.
- C. Remove existing work as indicated and required to accomplish new work.
 - Remove items indicated on drawings.
- D. Services including, but not limited to, HVAC, Plumbing, Fire Protection, Electrical, and Telecommunications: Remove existing systems and equipment as indicated.
 - 1. Maintain existing active systems to remain in operation, and maintain access to equipment and operational components.
 - 2. Where existing active systems serve occupied facilities but are to be replaced with new services, maintain existing systems in service until new systems are complete and ready for service.
 - 3. See Section 01 1000 Summary for limitations on outages and required notifications.
 - 4. Verify that abandoned services serve only abandoned facilities before removal.
 - 5. Remove abandoned pipe, ducts, conduits, and equipment, including those above accessible ceilings. Remove back to source of supply where possible, otherwise cap stub and tag with identification.
- E. Protect existing work to remain.
 - 1. Prevent movement of structure. Provide shoring and bracing as required.
 - 2. Perform cutting to accomplish removal work neatly and as specified for cutting new work.
 - 3. Repair adjacent construction and finishes damaged during removal work.
 - 4. Patch to match new work.

2.04 DEBRIS AND WASTE REMOVAL

- A. Remove debris, junk, and trash from site.
- B. Leave site in clean condition, ready for subsequent work.
- C. Clean up spillage and wind-blown debris from public and private lands.

DIVISION 23 HEATING, VENTILATING AND AIR-CONDITIONING (HVAC)

23 0000	General Requirements for HVAC Systems
23 0001	Basic HVAC Requirements
23 0002	HVAC Work in Existing Buildings
23 0500	Common Work Results for HVAC
23 0529	Pipe Hangers and Supports
23 0553	Identification for HVAC Systems
23 0700	HVAC Insulation
22 0712	Deat Level of an
23 0713	Duct Insulation
23 0719	Pipe Insulation
23 0900	Instrumentation and Control for HVAC
23 0913	Instruments and Control Devices
	Instruments and Control Devices
23 0914	Control Wiring and Cabling
23 0923	Direct Digital Control System
23 2000	HVAC Piping and Pumps
23 2113	Hydronic Piping
23 3000	HVAC Air Distribution
22 2112	Destar la
23 3113	Ductwork
23 3300	Air Duct Accessories
23 3600	Air Terminal Units
23 3713	Diffusers, Registers and Grilles

SECTION 23 0001 – BASIC HVAC REQUIREMENTS

PART 1 - GENERAL

1.1 SUMMARY

A. This Section Includes the following:

- 1. General Requirements
- 2. Definitions
- 3. Scope of Work
- 4. Drawings and Specifications
- 5. Reference Standards
- 6. Site Visit
- 7. Permits, Regulations and Inspections
- 8. Project Management and Coordination
- 9. Temporary Utilities
- 10. Workmanship
- 11. Protection
- 12. Painting
- 13. Cleaning
- 14. Equipment Selection
- 15. Shop Drawings
- 16. Final Inspection and Punch List
- 17. Operation and Maintenance Manuals
- 18. Record Drawings
- 19. Warranties
- 20. Project Closeout
- 21. Operation and Adjustment of Equipment
- 22. Operating Demonstration and Instruction

1.2 GENERAL REQUIREMENTS

- A. All provisions of Division 00 Front End Documents and Division 01 General Requirements apply to work specified in this Division.
- B. Specification provisions of other relevant Divisions shall apply where applicable work is required to be performed under this HVAC work.
- C. A complete and functional HVAC system installation shall be provided under this Division. Should overlap of work among the trades become evident, this shall be called to the attention of the Architect. In such event, none of the trades or their suppliers shall assume that he is relieved of the work which is specified under his branch until instructions in writing are received from the Architect.
- D. The Mechanical drawings and specifications assign work (labor and/or materials to be provided by the General, Plumbing, Fire Suppression, HVAC or Electrical Contractor or their sub-

contractors. Understanding that the contractors for mechanical work are sub-contractors to the (General) Contractor, such assignments are not intended to restrict the Contractor in assignment of work among the sub-contractor to accommodate trade agreements and practices or the normal conduct of the construction work.

1.3 DEFINITIONS

- A. Finished Spaces: Spaces other than mechanical and electrical equipment rooms, furred spaces, pipe and duct chases, unheated spaces immediately below roof, spaces above ceilings, unexcavated spaces, crawlspaces, and tunnels.
- B. Exposed, Interior Installations: Exposed to view indoors. Examples include finished occupied spaces and mechanical equipment rooms.
- C. Exposed, Exterior Installations: Exposed to view outdoors or subject to outdoor ambient temperatures and weather conditions. Examples include rooftop locations.
- D. Concealed, Interior Installations: Concealed from view and protected from physical contact by building occupants. Examples include above ceilings and chases.
- E. Concealed, Exterior Installations: Concealed from view and protected from weather conditions and physical contact by building occupants but subject to outdoor ambient temperatures. Examples include installations within unheated shelters.

1.4 SCOPE OF WORK

A. The scope of the HVAC work includes furnishing, installing, testing and warranty of all HVAC work shown on the HVAC drawings and specified herein, including Division 00, Division 01, Division 23 and applicable provisions of other relevant Divisions.

1.5 DRAWINGS AND SPECIFICATIONS

- A. The drawings indicate the general arrangement of the work and are to be followed insofar as possible. The word "proved," as used, shall mean "furnish and install." If significant deviations from the layout are necessitated by field conditions, detailed layouts of the proposed departures shall be submitted to the Architect for approval before proceeding with the work.
- B. Make all necessary field measurements to insure correct fitting. Coordinate work with all other trades in such a manner as to cause a minimum of conflict or delay.
- C. The drawings and specifications shall be carefully studied during the course of bidding and construction. Any errors, omissions or discrepancies encountered shall be referred immediately to the Architect for interpretation or correction, so that misunderstandings at a later date may be avoided. The contract drawings are not intended to show every vertical or horizontal offset which may be necessary to complete the systems. Having ductwork, pipe and fittings fabricated and delivered in advance of making actual measurements shall bet be sufficiently in advance as to not cause extra work, or unduly delay the work. Coordinate work in advance with all other trades and report immediately any difficulties which can be anticipated.

- D. The Architect/Engineer shall reserve the right to make minor adjustment in locations of system runs and components where he considers such adjustments desirable in the interest of concealing work or presenting a better appearance where exposed. Any such changes shall be anticipated and requested sufficiently in advance as to not cause extra work, or unduly delay the work. Coordinate work in advance with all other trades and report immediately any difficulties.
- E. Equipment, ductwork or piping shall not be installed or run above electrical switchgear or panelboards, nor in or above the access space in the immediate vicinity of the electrical switchgear/panelboards, in accordance with NEC Article 384.
- F. Where any system runs and components are so placed as to cause or contribute to a conflict, it shall be readjusted at the expense of the contractor causing such conflict. The Architect's decision shall be final in regard to the arrangement of ductwork, piping, etc., where conflict arises.
- G. Provides offsets in system runs, additional fittings, necessary drains and minor valves, traps, dampers and devices required to complete the installation, or for the proper operation of the system. Each Contractor shall exercise due and particular caution to determine that all parts of the work are made quickly and easily accessible.
- H. Should overlap of work among the trades become evident, this shall be called to the attention of the Architect. In such event, none of the trades or their suppliers shall assume that he is relieved of the work which is specified under his branch until instructions in writing are received from the Architect.

1.6 REFERENCE STANDARDS

A. Where standards (NFPA, NEC, ADTM, UL, etc.) are referenced in the specifications or on the drawings, the latest edition is to be used except, however, where the authority having jurisdiction has not yet adopted the latest edition, the edition so recognized shall be used.

1.7 SITE VISIT

A. Each bidder shall visit the project site to understand the existing conditions and compare the conditions with information shown on the drawings. Report immediately to the Architect any issues or discrepancies which are discovered that affect the bid. Changes to contract price will not be considered for site condition issues that are readily apparent from a thorough site review.

1.8 PERMITS, REGULATIONS AND INSPECTION

- A. Work must conform to applicable local, state and federal laws, ordinances and regulations. Where drawings or specifications exceed code requirements, the drawing and specifications shall govern. Install no work contrary to minimum legal standards.
- B. Except where the permit application is made by the Architect or the Engineer, the HVAC contractor shall be responsible to file for and obtain all required permits from the governing inspection agencies for the HVAC work. Where the Architect or Engineer is the Architect or

Engineer of record, they will furnish sealed and signed drawings and specifications required by the permit authorities.

- C. Include payment of all permit and inspection fees applicable to the work in this Division.
- D. All work shall be subject to inspection and approval of Federal, State and local agencies as may be appropriate as well as the Architect and Engineer.
- E. Furnish for the Owner certificates of approval from the governing inspection agencies as a condition for final payment.

1.9 PROJECT MANAGEMENT AND COORDINATION

A. Refer to Section 013100 Project Management and Coordination.

1.10 TEMPORARY UTILITIES

- A. The use of the permanent HVAC system for temporary heating and ventilation during the latter stages of construction shall be allowed. Expedite completion of system as practicable to this end. Maintain the system during this period. Provide and maintain temporary air filters to protect coils and ducts. Replace temporary filters with the specified filters (clean) when the systems are placed on permanent duty. Air filters specified for the systems and units, including specified spare filters, are not to be used for temporary service.
- B. Cover all return duct openings with temporary filter media when recirculating air. Stop fans during heavy dust generating operations. Before turning the system over to the Owner, the Contractor shall clean duct interiors and interior surfaces and components with the air handling equipment if dirt, dust and debris have accumulated on these surfaces.
- C. Warranty periods on equipment, materials and system shall commence upon Owner acceptance of the building or system. Temporary heat use shall not jeopardize or alter the warranty requirements.

1.11 WORKMANSHIP

- A. Materials and equipment shall be installed and supported in a first-class and workmanlike manner by mechanics skilled in their particular trades. Workmanship shall be first-class in all respects, and the Architect shall have the right to stop the work if highest quality workmanship is not maintained.
- B. HVAC work shall be performed by licensed HVAC Contractors in accordance with requirements of the jurisdiction.

1.12 PROTECTION

A. Each Contractor shall be entirely responsible for all material and equipment furnished in connection with his work. Special care shall be taken to properly protect all parts thereof from

- theft, damage or deterioration during the entire construction period in such a manner as may be necessary, or as directed by the Architect.
- B. The Owner's property and the property of other contractors shall be scrupulously respected at all times. Provide plastic sheeting, drop cloths or similar barriers where dust and debris is generated, to protect adjacent areas.
- C. Contractor shall protect all equipment and materials from detrimental effects of weather or construction activity. All items shall be stored and secured in a protected location away from the daily work area. Equipment or materials shall be placed on raised skids to protect from surface moisture. Where appropriate, provide plastic sheeting or similar vapor barrier underneath the stored products to reduce the effects of ground moisture or curing concrete on the local humidity levels. Where unfinished ferrous products or finished ferrous products with raw edges are stored, provide local, dry heat to maintain ambient relative humidity levels below 65% RH to prevent rust.
- D. All equipment shall retain the original packaging until required to be removed for installation or operation. Open ends of ducts, piping, conduit, etc. shall be capped or sealed and ventilation openings into equipment shall be wrapped and sealed in plastic sheeting to prevent dust or dirt entry both when stored and after installation but still open to the effects of construction activity. Stored items as well as installed equipment shall be covered with plastic sheeting at all times until placed in service or until dust generating activity in the area has ceased.

1.13 PAINTING

- A. In addition to any painting specified for various individual items of equipment, the following painting shall be included in Division 23:
 - 1. Ferrous metal which is not factory or shop painted or galvanized and which remains exposed to view in the finished areas of the building / building including finished areas, mechanical rooms, storage rooms, and other unfinished areas shall be given a prime coat of paint.
 - 2. Ferrous metal installed outside the building which is not factory or shop painted or galvanized shall be given a prime coat of paint.
 - 3. Equipment and materials which have been factory or shop coated (prime or finished painted or galvanized), on which the finish has been damaged or has deteriorated, shall be cleaned and refinished equal to its original condition. The entire surface shall be repainted if a uniform appearance cannot be accomplished by touch-up.
 - 4. Inside of ducts, behind grilles and registers, shall be painted flat black to eliminate the viewing of shiny surfaces.
- B. Paint, surface preparation and application shall conform to applicable portions of the Painting section of Division 09 Finishes. All rust must be removed before application of paint.
- C. Finish painting is included in the General Contract except where otherwise required under remodeling work. Refer to the "Cutting and Patching" paragraph in this Section for finishing requirements.

1.14 CLEANING

- A. Debris, dust, dirt, etc shall be removed daily, particular attention shall be paid to areas that the Owner is continuing to occupy or use; any mess created in corridors, stairwells and egress paths that are maintained during construction shall be cleaned immediately.
- B. The Owners dumpsters and trash receptacles shall not be used. If a dumpster is required, it shall be provided by the contractor and located where approved by the Owner. Coordinate dumpster requirements with other contractors.
- C. Before turning an area back over to the Owner, thoroughly clean the space to leave the area in a similar condition before the start of the project where finishes are to remain. The contractor shall also clean duct interiors and interior components of new or existing air handling system equipment if dirt, dust or debris have generated in the course of work have accumulated on these surfaces.
- D. Before placing each system in operation, the equipment shall be thoroughly cleaned; cleaning shall be in accordance with equipment manufacturer's recommendations.
- E. Refer to appropriate Sections for cleaning of other equipment and systems for normal operation.

1.15 EQUIPMENT SELECTION

- A. Materials and equipment furnished under this contract shall be in strict accordance with the specifications and drawings and shall be new and of best grade and quality. When two or more articles of the same material or equipment are required, they shall be of the same manufacturer.
- B. The selection of materials and equipment to be furnished under this contract shall be governed by the following:
 - 1. Where trade names, brands, or manufacturers of equipment or materials are listed in the specifications, the exact equipment listed shall be furnished. Where more than one name is used, the Contractor shall have the option of selecting between any one of the several specified. All products shall be first quality line of manufacturer's listed.
 - 2. Where the words "or approved equal: appear after a manufacturer's name, specific approval must be obtained from the Architect <u>during the bidding period</u> in sufficient time to be included in an addendum. The same shall apply for equipment and materials not named in the specifications, where approval is sought.
 - 3. Where the words "equal to" appear, followed by a manufacturer's name and sometimes a model or series designation, such designation is intended to establish a model or series designation, such designation is intended to establish quality level and standard features. Equal equipment by other manufacturers will be acceptable, subject to the Engineer's approval.
- C. Substitute equipment of equal quality and capacity will be considered when the listing of such is included as a separate item of the bid. State the deduction or addition in cost to that of the specified product.

- D. Before bidding equipment, and again in the preparation of shop drawings the Contractor and his supplier shall verify that adequate space is available for entry and installation of the item of equipment, including associated piping and accessories. Also verify that adequate space is available for servicing of the equipment.
- E. If extensive changes in pipe, duct or equipment layout or electrical wiring and equipment are brought about by the use of equipment which is not compatible with the layout shown on the drawings, necessary changes shall be deemed to be included in the contract.

1.16 SHOP DRAWINGS

- A. One set of shop drawings, in electronic format (.pdf), with descriptive information shall be assembled by each Contractor of equipment and materials furnished in his contract, and submitted to the Architect and/or Engineer for review as stated in Division 01. These shall be submitted as soon as practicable and before special equipment is manufactured and before installation.
- B. Shop drawings for equipment fixtures, devices and materials shall be labeled and identified same as on the Contract Documents. Failure to do so may be cause for rejection of shop drawings.
- C. The review of shop drawings by the Architect or Engineer shall not relieve the Contactor from responsibility for errors in the shop drawings. Deviations from specifications and drawing requirements shall be called to the Engineer's attention in a separate clearly stated notification at the time of submittal for the Engineer's review.
- D. Shop drawings for the following HVAC equipment and materials shall be submitted:
 - 1. Pipe, fittings and joining methods for the various systems.
 - 2.
 - 3. Pipe Hangers and Supports.
 - 4. Valves.
 - 5. Pipe Insulation.
 - 6. Ductwork Insulation.
 - 7. Ductwork and Sealing Systems.
 - 8. Air Duct Accessories.
 - 9. Refrigerant piping schematic and components.
 - 10. Split System Air Conditioning Units
 - 11. Air Control Terminal Units.
 - 12. Temperature Control System.
 - 13. Diffusers, Registers and Grilles.

1.17 FINAL INSPECION AND PUNCH LIST

A. As the time of work completion approaches, the Contractor shall survey and inspect his work and develop his own punch list to confirm that it is complete and finished. He shall then notify the Architect and request that a final inspection be made. It shall not be considered the Architect's or Engineer's obligation to perform a final inspection until the Contractor has inspected the work and so states at the time of the request for the final inspection.

- B. Requests to the Architect, Engineer or Owner for final inspection may be accompanied by a limited list of known deficiencies in completion, with appropriate explanation and schedule for completing these; this is in the interest of expediting acceptance for beneficial occupancy.
- C. The Architect and/or Engineer will inspect the work and prepare a punch list of items requiring correction, completing or verification. Corrective action shall be taken by the Contractor to the satisfaction of Architect and Engineer within 30 days of receipt of the Architect/Engineer's punch list.

1.18 OPERATION AND MAINTENANCE MANUALS

- A. One electronic copy of operating and maintenance manuals shall be assembled for the HVAC work by the Contractors.
- B. All shop drawing and installation, maintenance and operating instruction pamphlets or brochures, wiring diagrams, parts list and other information, along with warranties, shall be obtained from each manufacturer of the principal items of equipment. Air and water balance reports shall also be included. In addition, the Contractor shall prepare a chart listing all items of equipment which are furnished under his contract and indicating the nature of maintenance required, the recommended frequency of checking these points and the type of lubricating media or replacement material required.
- C. These shall be assembled into three-ring loose lead binders or other appropriate binding and also combined into a single electronic file in .PDF format. An index and tabbed sheets to separate the sections shall be included. These shall be submitted to the Architect or Engineer for review. Upon approval, manuals shall be turned over to the Owner.

1.19 RECORD DRAWINGS

A. Each Contractor shall maintain a separate set of prints of the contract documents and shall show all changes or variations, in a manner to be clearly discernible, which are made during construction. Upon completion of the work, these drawing shall be turned over to the Architect.

1.20 WARRANTIES

- A. This Contractor shall warrant all workmanship, equipment and material entering into this contact for a period of one year of date of final acceptance or date of beneficial use, as agreed to between Contractor and Architect. Any materials or equipment proving to be defective during this warranty period shall be made good by this Contractor without expense to the Owner.
- B. This provision is intended specifically to cover deficiencies in contract completion or performance which are discovered after systems are placed in operation. Also included shall be supplementary assistance in balancing, adjusting or providing operating instructions as the need develops, and replacing overload heater elements in starters where necessary to keep systems in operation. Heater element sizes shall not exceed the motor manufacturer's recommendations.

- C. This provision shall not be construed to include maintenance items such as replacing filters, retightening or repacking glands, greasing, oiling belt tightening and cleaning strainers after these have been done for final close-out.
- D. Provisions of this warranty shall be considered supplementary to warranty provisions under General Conditions.
- E. Extended warranties shall be provided where indicated in the equipment specification sections.

1.21 PROJECT CLOSEOUT

- A. The following schedule summarizes actions to be taken or submittals to be completed by Contractor prior to issuance of the Contract Completion Certificates. Refer to applicable paragraphs of the Division 23 Sections and other applicable trade Divisions for additional requirements. This information should be submitted at least thirty days in advance of request for final inspection. Where possible, the information shall be bound in 8 ½ x 11" hard back binders.
 - 1. Material / Suppliers List
 - 2. Record Drawings
 - 3. Certificate of Inspection
 - 4. Tests and Adjustments
 - 5. Operating Instructions and Maintenance Manuals
 - 6. Equipment and Piping Identification
 - 7. Receipt of spare pump seals
 - 8. Receipt of spare filters
 - 9. Completed Punchlist
 - 10. Waiver of Liens
 - 11. Affidavit of Wage Compliance
 - 12. Change Orders and Allowance Adjustments

1.22 OPERATION AND ADJUSTMENT OF EQUIPMENT

- A. As each piping system and air distribution system is put into operation, all items of equipment included therein shall be adjusted to proper working order. This shall include balancing air and water systems, adjusting fan speeds, belts, pulleys, tightening packing glands, and adjusting all operating equipment.
- B. Caution: Verify that all bearings are lubricated, all motors are operating in the right direction, and correct overload heater elements are provided on all motors. Do not depend wholly on the electrician's judgment in these matters. Follow specific instructions in regard to lubrication. Do not oil or grease presealed ball bearings unless upon manufacturer's specific instructions.
- C. Test relief valves, air vents and regulating valves to insure proper operation.

1.23 OPERATING DEMONSTRATION AND INSTRUCTIONS

- A. The Contractor shall set the various systems into operation and demonstrate to the Owner and Architect that the systems function properly and that the requirements of the Contract are fulfilled.
- B. The Contractor shall provide the Owner's representatives with detailed explanations of operation and maintenance of equipment and systems. A thorough review of the operating and maintenance manuals shall be included in these instructional meetings.
- C. A minimum of 4 hours shall be allowed for instructions to personnel selected by the Owner. Instructions shall include not less than the following:
 - 1. Show locations of items of equipment and their purpose.
 - 2. Review binder containing instructions and equipment and systems data.
 - 3. Coordinate written and verbal instructions so that personnel understand each.
 - 4. Separate instructions shall be given by manufacturer's representatives for the temperature control systems.

PART 2 - PRODUCTS - NOT APPLICABLE

PART 3 - EXECUTION - NOT APPLICABLE

END OF SECTION 23 0001

WAGNER AVENUE INTERIOR RENOVATION 2025

SECTION 23 0002 – HVAC WORK IN EXISTING BUILDINGS

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section Includes the following:
 - 1. General Requirements for Renovation Work
 - 2. Inspection of Existing Building
 - 3. Asbestos Material
 - 4. Work Hours
 - Tobacco Products
 - 6. Barriers and Signage
 - 7. Storage of Tools and Materials
 - 8. Protection of Existing Building and Equipment
 - 9. Confined Spaces
 - 10. Noise, Fumes, and Dust Control
 - 11. Soldering, Welding, and Cutting
 - 12. Removals, Disposal, and Reuse
 - 13. Draining, Flush, and Refill of Piping Systems
 - 14. Continuity of Systems

1.2 GENERAL REQUIREMENTS FOR RENOVATION WORK

- A. Refer to Article 1 Specification requirements and notes on the drawings where provided for requirements related to renovation work.
- B. Meet with the Owner, Architect and Engineer before demolition or construction begins to establish procedures for work effort in the existing building. Provide names and phone numbers and establish emergency contact information where work is performed. Provide security information requested by the Owner for all personnel who will be working on site. Educate all construction personnel in regard to the project requirements and procedures.
- C. Coordinate effort with other contractors involved in the renovation project to minimize the disruption, phasing of work, share cleaning responsibilities, etc.

1.3 INSPECTION OF EXISTING BUILDING

A. Each bidder shall inspect the existing building in the early time frame of the bidding period. Conditions shall be compared with information shown on the drawings. Report to the Architect/Engineer any significant discrepancies which may be discovered in a timely fashion so that direction may be provided in an addendum. After the contract is signed, no allowance

WAGNER AVENUE INTERIOR RENOVATION 2025

will be made for failure to have made a thorough inspection.

1.4 ASBESTOS MATERIAL

- A. Abatement, removal or encapsulation of existing materials containing asbestos is <u>not</u> included in the Contract. Necessary work of this nature will be arranged by the Owner to be done outside of this construction and remodeling project buy a company regularly engaged in asbestos abatement. Such work will be scheduled and performed in advance of work in the construction and remodeling project.
- B. If, in the performance of the mechanical work, materials are observed which are suspected to contain asbestos, the Contractor shall immediately inform the Architect / Engineer who in turn will notify the Owner. Work that would expose workers to the inhalation of asbestos particles shall be terminated. Work may be resumed only after a determination has been made and unsafe materials have been removed or encapsulated and the area declared safe.

1.5 WORK HOURS

- A. Work hours for construction shall be as defined in Section 01150 Project Phasing or other specification sections or drawing notes.
- B. Where allowed, contractors may work normal hours except after hours is required for operations that are noisy, generate obnoxious fumes or dust, require shut down of ventilation systems, etc. The Owner reserves the right to stop normal hour work where the Owner deems the effort to be disruptive to their ongoing operations.
- C. Any work that creates hazards in or requires closure of corridors, exit pathways or stairwells work in corridors must be performed after hours when the building is not occupied.
- D. All occupied areas, corridors exit pathways and stairwells must be left clean, lighted (including emergency egress and exit signage) usable and safe at the end of each work shift.
- E. Access to the work area shall be coordinated with the Owner; follow all security protocols for parking, sign in, key control, etc. established by the Owner.

1.6 TOBACCO PRODUCTS

A. Smoking or chewing tobacco products are expressly prohibited to be used within the building and on the premises except where specifically permitted by the Owner or in construction company trailers or vehicles where permitted by the construction company.

WAGNER AVENUE INTERIOR RENOVATION 2025

PART 2 - PRODUCTS- NOT APPLICABLE

PART 3 - EXECUTION

3.1 BARRIERS AND SIGNAGE

- A. Barriers and signage shall be provided as appropriate to identify work areas and to prevent unauthorized entry by non-construction personnel.
- B. All barriers and signs should be high visibility type and be maintained at all times.

3.2 STORAGE OF TOOLS AND MATERIALS

- A. Store all site material and tools in the active job site area or on-site areas, to be coordinated with Owner. Specific storage areas are not provided except where otherwise noted for material and tools.
- B. Storage is specifically prohibited in means of egress paths and stairwells.
- C. The contractor is responsible for the security of tools, equipment, and materials.
- D. On-site storage areas should be in locked trailers.

3.3 PROTECTION OF EXISTING BUILDING AND EQUIPMENT

- A. The Owners' property and the property of other contractors shall be respected at all times. Provide drop clothes, visqueen plastic sheeting or other suitable barriers where dust and debris is generated. Tape or zipper ends of barriers for sealing purposes.
- B. Provide 55-gallon drums or smaller buckets as appropriate and use funnels when draining liquid systems.
- C. Provide plywood sheets for heavy duty for protection of walls, floors or Owner equipment or systems that are remaining in place near demolition or new installation work where there is possible damage from heavy material or equipment.
- D. Provide ram board floor protection in occupied areas adjacent to construction areas.

3.4 CONFINED SPACES

- A. Notify the Owner when performing work in confined spaces. Provide a written procedure for approval and obtain approval from the Owner when so requested.
- B. All work in confined spaces shall be done in accordance with OSHA regulations.

3.5 NOISE, FUME, AND DUST CONTROL

- A. Provide barriers and ventilation as required to limit the effect from construction generated noise fume and dust control on spaces that continue to be occupied by the Owner. Refer to protection of building and equipment paragraph above. In addition to the basic protection, provide additional visqueen barriers to limit airborne migration of dust and fumes. Provide supplemental portable fans to exhaust air to the outside of the building where appropriate. Use of the Owners' ventilation systems to induce positive or negative pressure is prohibited unless authorized by the Owner. Shut off ventilation systems serving the area where use of these systems can induce fumes or dust into return or exhaust ducts. Where systems need to remain operational for occupied areas, arrange to temporarily shutoff portions of the system in the work area. Provide taped visqueen covers on HVAC air supply and exhaust devices to limit migration. Coordinate all efforts requiring modification or shutdown of ventilation systems with the Owner. Contractor shut down of these systems is prohibited without Owner permission.
- B. Fire Alarm System Coordination Arrange with the Owner when required to shut off fire alarm system devices and/or smoke detectors to perform work. With the Owners' prior approval. Cover smoke detectors where needed to prevent false alarms due to dust or fumes generated. Minimize outages and coordinate efforts to limit the effect due to false alarms.
- C. Ventilation Where significant dust or fume generating work, welding, or cutting operations are required for removal or new work, provide fume removal equipment with telescoping arms to locally capture the fumes. Fume exhaust shall be directed outside or adequately filtered and recirculated.
- D. Daily Ventilation Areas shall be thoroughly ventilated after completion of the work daily to remove residual odors and fumes before occupancy occurs the next day.
- E. Cleaning Provide walk off sticky construction pads at entrances to construction site and vacuum cleaners and other equipment to clean and restore conditions.

3.6 SOLDERING, WELDING, AND CUTTING

- A. For soldering, welding, or cutting operations, provide insulated, fire rated curtains or barriers and blankets to isolate cover and protect remaining systems and materials, furniture, furnishings, floors, walls, ceilings, etc.
- B. Refer to noise, fumes, and dust control provisions in the previous paragraph.
- C. Obtain burn approval from the Owner before commencing any soldering or welding effort. Coordinate outages of fire alarm systems as noted in the previous paragraph.
- D. Provide a Fire Watch at each welding location. Fire Watch personnel shall be dedicated for the sole purpose of fire prevention during welding operations. All Fire Watch personnel shall be properly trained and equipped, including fire extinguisher, fire blanket and communication equipment for assistance request.
- E. Provide a fire extinguisher at every soldering or welding location.

WAGNER AVENUE INTERIOR RENOVATION 2025

3.7 REMOVALS, DISPOSAL, AND REUSE

- A. Refer to the drawings for the scope of remodeling in the existing building.
- B. Cooperate with the General Contractor regarding all removal and remodeling work. Each Contractor shall remove existing work which is associated with his trade, and which will be superfluous when the new work is installed and made operational.
- C. Where piping, ductwork, equipment, and other materials are noted to be removed the removal shall include all hangers and supports for these items.
- D. Extraneous ductwork and piping which is or becomes accessible shall be removed and stubs shall be capped at the first active duct or pipe encountered. Piping that is and remains inaccessible shall be abandoned. Ends of abandoned pipe shall be capped so as to be concealed by finished surfaces. Upon completion of the work, no abandoned pipe, valve, or stub shall extend through finished floors, walls, or ceilings.
- E. When it is necessary to reroute a section of active piping, the rerouted section shall be installed before removing the existing in order to minimize system down time. Rerouted sections shall be insulated as required for new work. Patch insulation on existing piping which has been damaged or removed in this work.
- F. Materials and equipment which are removed shall not be reused within the scope of this project unless specifically noted to be relocated or reused. Turn over to the Owner and place where directed on the premises all removed material and equipment so designated by the Owner. All material and equipment which the Owner does not wish to retain shall become the property of the Contractor responsible for removal and shall be removed from the premises and properly disposed.
- G. Disposal of materials regulated by EPA shall be done in strict accordance with latest requirements. Provide documentation to the Owner that disposal was properly executed.
- H. Remove, store and reinstall lay-in ceiling tile and grid as needed to perform work in areas where such removal and re-installation is not to be done by the General Contractor. Damaged tile and/or grid shall be replaced with new matching tile and/or grid.
- I. In areas of minor work where the space is not completely vacated, temporarily move portable equipment and furnishings within the space as required to complete the work. Coordinate this activity with Owner. Protect the Owner's property by providing dust covers and temporary plastic film barriers to contain dust. Remove barriers and return equipment and furniture upon completion of the work.
- J. Openings left where existing equipment, ductwork, piping and supports are to be removed in existing walls and ceilings shall be patched using materials to match the existing construction, which may include fire stopping of rated walls and ceilings.

3.8 DRAINING, FLUSHING, AND REFILL OF PIPING SYSTEMS

A. Existing liquid systems shall be drained as required before removal or connection of new piping

WAGNER AVENUE INTERIOR RENOVATION 2025

extensions.

- B. Draining of the system shall be the responsibility of the contractor. Provide threaded connections, etc. to direct fluids to drainage points. Water systems may be drained to sanitary systems or where permitted, to storm systems. Verify any chemical treatment, inhibitors or freeze protection additives in the existing systems and obtain a permit from the local sewer authority before disposing.
- C. Provide drums or containers to accept other than water drainage and remove from the premises and properly dispose. Provide visqueen to protect Owners' property when opening pipes, even where piping has been drained to prevent damage from residual liquid that remains in the pipe.
- D. After new piping is connected and tested, flush and clean all existing piping that has been drained and new piping as specified in Section 23 0001, Basic HVAC Requirements. Provide full port, 0.75" ball valves with hose connectors as described to facilitate flushing operations.
- E. Inspect and clean any new or existing strainers at coils, heat exchangers, etc. that may become clogged due to debris that may dislodge from interior pipe surfaces due to the draining, flushing and detergent cleaning operations.
- F. During refilling and startup operations, vent all air from the system at high points. This air venting effort shall extend beyond the refill and initial startup where flow blockage due to air binding occurs.

3.9 CONTINUITY OF SYSTEMS

A. Coordination –

- 1. Work shall be so planned and executed as to provide reasonably continuous services of existing systems throughout the construction period. Where necessary to disrupt services for short periods of time for connection, alteration, or switch-over, the Owner shall be notified in advance and outages scheduled at the Owner's reasonable convenience.
- B. Sequence of Operations Submit, on request, a written step-by-step sequence of operations proposed to accomplish the work. The outline shall include tentative dates, times of day for disruption, downtime, and restoration services. Submit the outline sufficiently in advance of the proposed work to allow the Architect or Engineer to review the information with the Owner. Upon approval, final planning and the work shall be done in close coordination with the Owner.
- C. Shutdown of systems and work undertaken during shutdown shall be bid as being done <u>outside</u> of normal working hours.

END OF SECTION 23 0002

SECTION 23 0529 - PIPE HANGERS AND SUPPORTS

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes the following:
 - 1. Steel pipe hangers and supports.
 - 2. Trapeze pipe hangers.
 - 3. Hanger Rods and Attachments.
- B. See Division 23 Section "Metal Ducts" for duct hangers and supports.

1.2 DEFINITIONS

A. Terminology: As defined in MSS SP-90, "Guidelines on Terminology for Pipe Hangers and Supports."

1.3 PERFORMANCE REQUIREMENTS

- A. Design supports for multiple pipes capable of supporting combined weight of supported systems, system contents, and test water.
- B. Design seismic-restraint hangers and supports for piping and obtain approval from authorities having jurisdiction.

1.4 SUBMITTALS

- A. Product Data: For the following:
 - 1. Steel pipe hangers and supports.

1.5 QUALITY ASSURANCE

A. Welding: Qualify procedures and personnel according to ASME Boiler and Pressure Vessel Code: Section IX.

PART 2 - PRODUCTS

2.1 STEEL PIPE HANGERS

A. Hangers and supports for piping shall be equal to the Anvil catalog numbers as follows:

- 1. General Service clevis type Anvil Fig. 260.
- 2. Uninsulated Copper Tubing copper plated clevis type Anvil Fig. CT-65 (or plastic coated clevis).
- 3. Where the length of the hanger rod between the top of the hanger and the attachment is 3" or less, clevis type hangers with rollers, Anvil Fig. 181, shall be used to allow for expansion travel
- B. Hangers on insulated horizontal piping shall be oversized to surround the pipe insulation. To protect the insulation from damage or inordinate compression due to concentrated weight, the following shall be provided at each hanger:
 - 1. Pipe 2" and smaller Anvil Fig. 168 18 ga. sheet metal rib-lock shield with belled ends, 12" long.
 - 2. Pipe 2-1/2" and larger Factory fabricated assembly equal to Pipe Shields, Inc. A1000.

2.2 TRAPEZE HANGERS

A. Trapeze hangers for numerous pipes run in parallel may be utilized. Horizontal support members shall be unistrut type section with pipe rollers (to allow for expansion travel) and spring and nut connectors, suspended with hanger rods and attachments similar to individual pipe hanger suspension.

2.3 HANGER RODS AND ATTACHMENTS

- A. Hanger rods shall be solid steel, threaded-end or all-thread rod, of diameter listed below. A hanger attachment device (for attachment to the structure) and locking nuts at the hanger attachment shall be provided on each hanger. Locking nuts shall be provided at each clevis hanger.
- B. Pipe Hanger Rod Size Schedule

Min. Rod Dia.
1/4"
3/8"
1/2"
5/8"
3/4"
7/8"
1"
1-1/4"

- C. Hanger rod attachment devices for attachment to the structure shall be:
 - 1. After-set steel expansion type concrete inserts.

2. Beam clamps for steel construction equal to Anvil Fig. 92, 93, or 94. Utilize swivel type in sloped steel construction to provide vertical support of pipe without bending hanger rods.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Spacing of hangers shall be as follows:
 - 1. Steel pipe Horizontal:
 - a. 2" and smaller -8 ft. intervals
 - b. 2-1/2" thru 6" 10 ft. intervals
 - c. 8" and larger -12 ft. intervals.
 - 2. Copper Tubing Horizontal
 - a. 1-1/4" and smaller 6 ft. intervals
 - b. 1-1/2" 2" 8 ft. intervals
 - c. 2-1/2" and larger -10 ft. intervals
- B. Attachment of pipe hangers to the structure shall be with:
 - 1. After-set concrete inserts, in 4" minimum depth concrete, set in drilled holes. Powder actuated driven fasteners are not permitted.
 - 2. Provide anchoring where steel beam clamps are attached to sloping surfaces of beam flanges and where otherwise required to insure permanent attachment.
 - 3. Attachment to steel deck is prohibited. Span from steel structural members with supplementary steel shapes where direct attachment to structural members is not practical. This does not apply to steel deck with concrete slab poured deck. Refer to notes 1 and 2 above.
- C. Pipe hangers shall be adjusted to proper elevation and all hanger rods set in a vertical position before pipe insulation is installed.
- D. Hanger assemblies which will remain exposed on completion of the project shall be painted before installation.

END OF SECTION 23 0529

This page left blank intentionally

SECTION 23 0553 - IDENTIFICATION FOR HVAC SYSTEMS

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Equipment Labels.
 - 2. Pipe Labels.
 - 3. Controls Equipment Labels.

1.2 SUBMITTAL

A. Product Data: For each type of product indicated.

1.3 QUALITY ASSURANCE

A. Labels, tags and markers shall comply with ANSI A13.1 for lettering size, colors and length of color field.

PART 2 - PRODUCTS

2.1 PIPE LABELS

- A. Pipe markings shall be applied to all piping.
- B. Labeling shall be:
 - 1. Plastic semi-rigid snap-on type, manufacturer's standard pre-printed color coded pipe markers extending fully around the pipe and insulation or pressure-sensitive vinyl pipe markers similar to above.
 - 2. On piping and insulation 6" and greater diameter, full band as specified above or striptype markers fastened to the pipe or insulation with laminated or bonded application or by color-coded plastic tape not less than 1-1/2" wide, full circle at both ends of the marker.
- C. Identification markings shall include service (e.g. hot, chilled, steam) and arrows indicating direction of fluid flow provided integral with the pipe marker or separate at each marker.

2.2 DUCT LABELS

A. Duct markings shall be applied to all ductwork.

- B. Identification markings shall include service (e.g. supply, return, exhaust, outside air) and direction of air flow provided integral with duct marker or separate at each marker.
- C. Duct markings shall be laminated plastic color-coded pressure sensitive vinyl tape, 2-1/2" width, 3 mil minimum thickness.

2.3 CONTROLS EQUIPMENT LABELS

- A. Each controls device or major controls equipment shall be labeled to match controls drawings. This shall include thermostats, switches, sensors, controllers, panels and other similar equipment.
 - 1. Equipment labels Self-Adhesive, Engraved, Laminated Phenolic Label: Adhesive backed, with black letters on a white background. Minimum letter height shall be 3/8 inch
 - 2. Device labels Marker Tape: Self-laminating, clear polyester, 3/8" high tape with black lettering.

2.4 ACCEPTABLE MANUFACTURERS

- A. Labels, markings and tags shall be manufactured by:
 - 1. W.H. Brady
 - 2. Seton
 - 3. Allen
 - 4. Industrial Safety Supply

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Identification marking and tagging shall be applied after insulation and painting has been completed.
- B. Coordinate names, abbreviations and other designations used in mechanical identification work, with corresponding designations shown, specified or scheduled on drawings.
- C. Pipe markers shall be placed at 25 ft. centers in mechanical rooms and concealed spaces and at 50 ft. centers in other exposed locations.

END OF SECTION 23 0553

SECTION 23 0713 - DUCT INSULATION

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Insulation Materials:
 - a. Fiberglass.

1.2 SUBMITTALS

- A. Product Data:
 - 1. For each type of product indicated.
 - 2. Thickness and covering table.

1.3 QUALITY ASSURANCE

- A. Fire-Test-Response Characteristics: Insulation and related materials shall have fire-test-response characteristics indicated, as determined by testing identical products per ASTM E 84, by a testing and inspecting agency acceptable to authorities having jurisdiction. Factory label insulation and jacket materials and adhesive, mastic, tapes, and cement material containers, with appropriate markings of applicable testing and inspecting agency.
 - 1. Insulation Installed Indoors: Flame-spread index of 25 or less, and smoke-developed index of 50 or less.
 - 2. Insulation Installed Outdoors: Flame-spread index of 75 or less, and smoke-developed index of 150 or less.

PART 2 - PRODUCTS

2.1 GENERAL

- A. Comply with requirements in Part 3 schedule articles for where insulating materials shall be applied.
- B. Products shall not contain asbestos, lead, mercury, or mercury compounds.

DUCT INSULATION 23 0713 - 1

2.2 INSULATION MATERIALS

A. Refer to 'Ductwork Insulation Schedule'.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Installation shall be done by tradesmen specializing in insulation work in strict accordance with manufacturer's recommendations.
- B. Ductwork shall be sealed prior to installation of insulation.
- C. Insulation shall be marked with manufacturer, "R-Value", and flame spread and smoke development.
- D. Blanket insulation shall be wrapped tight to the duct. Insulation shall be secured to ducts 20" wide and greater with weld pins and fasteners, 18" on center maximum. Adhesive shall be applied to the duct as an aid to installation and adhesion. Vapor barrier jacket shall be lapped, stapled and sealed with adhesive and 3" wide FSK pressure sensitive tape.
- E. Equipment and devices in supply ductwork which could potentially condense moisture shall be insulated.
- F. Reinsulate existing ductwork where existing insulation has been damaged or removed in the performance of work in this project.

END OF SECTION 23 0719

DUCT INSULATION 23 0713 - 2

SECTION 23 0719 - PIPE INSULATION

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Insulation Materials:
 - a. Fiberglass.

1.2 SUBMITTALS

- A. Product Data:
 - 1. For each type of product indicated.
 - 2. Thickness and covering table.

1.3 QUALITY ASSURANCE

- A. Fire-Test-Response Characteristics: Insulation and related materials shall have fire-test-response characteristics indicated, as determined by testing identical products per ASTM E84, by a testing and inspecting agency acceptable to authorities having jurisdiction. Factory label insulation and jacket materials and adhesive, mastic, tapes, and cement material containers, with appropriate markings of applicable testing and inspecting agency.
 - 1. Insulation Installed Indoors: Flame-spread index of 25 or less, and smoke-developed index of 50 or less.
 - 2. Insulation Installed Outdoors: Flame-spread index of 75 or less, and smoke-developed index of 150 or less.

PART 2 - PRODUCTS

2.1 INSULATION GENERAL

- A. Products shall not contain asbestos, lead, mercury, or mercury compounds.
- B. Foam insulation materials shall not use CFC or HCFC blowing agents in the manufacturing process.
- C. Stainless Steel Pipe Insulation Products
 - 1. Products that come in contact with stainless steel shall have a leachable chloride content of less than 50 ppm when tested according to ASTM C871.

- 2. Insulation materials for use on austenitic stainless steel shall be qualified as acceptable according to ASTM C795.
- D. Refer to "Pipe Hanger Detail" on drawings for required hanger components.

2.2 INSULATION MATERIALS AND THICKNESSES

A. Refer to 'Pipe Insulation Schedule' on drawings.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Installation shall be done by tradesmen specializing in insulation work in strict accordance with manufacturer's recommendations.
- B. Overlap and seal all longitudinal joints. Staples and adhesive may be used as stated above. Tape and seal cross joints. Vapor barrier shall be continuous on insulation of all cold services. Vapor barrier type mastic shall be used w here needed to maintain a vapor seal.
- C. Where insulation is terminated, insulation shall be beveled at 45° and the beveled surface sealed with vapor barrier mastic. PVC caps over straight cut ends which have been vapor sealed may be used in lieu of beveling.
- D. Mechanical joint fittings and couplings shall be considered as a part of the pipe line and shall be insulated. Bidders on the insulation work are cautioned to verify during the bidding period the extent of this work.
- E. Insulation shall be run continuous through wall penetrations. Insulation on cold service piping shall be run through floor and wall sleeves to maintain vapor barrier continuity. Insulation on other services may likewise be run continuous when sleeve size permits. Refer to the Piping Material and Methods Section for special considerations which must be given at fire-rated wall and floor penetrations. Refer to Section 230529 Pipe Hangers and Supports for non-compressible insulation or blocking material and sheet metal saddles required at pipe hangers. Coordinate with the piping contractor on the furnishing, installation and detailed requirements of these. Provide insulation and vapor barrier on and around supports for pipe risers of services which require vapor seal so as to prevent sweating.
- F. Re-insulate piping where existing insulation has been damaged or removed in the performance of work in this project.
- G. Verify that piping has been tested before applying insulation materials and that piping surfaces are clean and dry, with foreign material removed.
- H. Fittings, valves, flanges and other devices, both exposed and concealed, requiring insulation shall be covered same thickness as pipe insulation with:
 - 1. Factory molded fitting insulation cover with PVC one-piece fitting cover.

- 2. Miter-cut segments of pipe insulation, held in place with adhesive and/or wire, filled with insulating cement smoothed to shape and covered with PVC one-piece fitting cover.
- 3. Fiberglass blanket insulation, held in place and covered with PVC one-piece fitting cover.
- 4. Oversized pipe insulation, where applicable, finished same as straight run pipe insulation.

I. Insulation is to be omitted on:

1. Hot water valves, devices, specialties and related items, 2" size and smaller.

END OF SECTION 23 0719

This page left blank intentionally

SECTION 23 0913 - INSTRUMENTS AND CONTROL DEVICES

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes instruments and control devices for HVAC Direct Digital Control (DDC) systems and components.
 - 1. Electronic Sensors
 - a. Thermistor Temperature Sensors & Transmitters
 - 2. Actuators
 - 3. Control Valves
- B. Related Sections:
 - 1. Section 23 0914 Control Wiring and Cabling
 - 2. Section 23 0923 Direct Digital Control System

1.2 SUBMITTALS

- A. Product Data: For each control component indicated.
- B. Shop Drawings:
 - 1. Each component shall be labeled for proposed usage and its corresponding item tag per the control drawing, diagram and sequence of operation submittal.
 - 2. Damper schedule.
 - 3. Valve schedule.
- C. Operation and maintenance data.

1.3 QUALITY ASSURANCE

A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

A. Where a list of manufacturers is not provided, products offered by the controls system contractor or their preferred vendor may be incorporated, subject to compliance with the specification.

B. Where a list of manufacturers is provided under components below, the product shall be selected only from the list of manufacturers provided.

2.2 CONTROL SYSTEM COMPONENTS

- A. Refer to Section 23 0923 "Direct Digital Control System" for manufacturers and specifications for the DDC system, including operator workstation, distributed controllers, network requirements, accessories, control software and graphic requirements.
- B. Refer to Section 23 0914 "Control Wiring and Cabling" for power wiring, control cabling, transformers, fusing power distribution cabinets and power line filtering for the DDC system.
- C. Control system components specified in this Section include sensors, detection equipment, indicators, thermostats, humidistats, air flow measuring stations, meters, actuators, control valves and dampers.

2.3 SENSORS AND TRANSMITTERS

A. Temperature Sensors

1. General

- a. Temperature sensors shall be thermistors or Resistance Temperature Device (RTD) and be suitable for the application. Where feasible, provide the same sensor type throughout the project. Avoid using transmitters unless necessary and approved by the engineer.
- b. Precision thermistors may be used in applications below 200 deg F. Sensor accuracy over the application range shall be 0.36 Deg F or less between 32 to 150 Deg F.
- c. Provide RTD sensors with platinum elements compatible with the digital controllers. Encapsulate sensors in epoxy, series 300 stainless steel, anodized aluminum, or copper. Temperature sensor accuracy shall be 0.1 percent (1 ohm) of expected ohms (1000 ohms) at 32 degress F. Temperature sensor stability error over five years shall not exceed 0.25 degree F cumulative. Direct connection of RTD's to digital controllers without transmitters is preferred. When RTDs are connected directly, lead resistance error shall be less than 0.25 degrees F. The total error for a RTD circuit shall not exceed 0.5 degrees F.
- d. Provide matched temperature sensors for differential temperature measurement.

2. Duct Sensors

- a. Duct sensors shall be single point or averaging as shown. Averaging sensors shall be a minimum of 1.5m (5 feet) in length per 1m (10 sq ft) of duct cross section.
- b. Mixed air and Discharge air sensors shall be averaging type.

3. Space Sensors

a. Space sensors shall be equipped with a setpoint adjustment, occupancy mode override switch, display, and communication port. Sensor cover shall be rectangular high impact ABS plastic in a neutral color.

B. Relays

- 1. Control relays shall be UL Listed plug-in type with dust cover and LED "energized" indicator. Contact rating, configuration, and coil voltage shall be suitable for the application.
- 2. Time delay relays shall be UL listed solid-state plug-in type with adjustable time delay. Dalay shall be adjustable +/- 200% (minimum) from setpoint shown on plans. Contact rating, configuration, and coil voltage shall be suitable for the application. Provide NEMA enclosure suitable for location when not installed in local control panel.

C. Current Transformers

- 1. AC current transformers shall be UL/CSA recognized and completely encased (except for terminals) in approved plastic material.
- 2. Transformers shall be available in various current ratios and shall be selected for +/- 1% accuracy at 5 A full scale output.
- 3. Transformers shall be split-core type for installation on new or existing wiring.

D. Voltage Transmitters

- 1. AC voltage transmitter shall be self-powered single loop (two-wire) type, 4 to 20 mA output with zero and span adjustment.
- 2. Ranges shall include 100 to 130 VAC, 200 to 250 VAC, 250 to 300 VAC, and 400 to 600 VAC full-scale, adjustable, with 1% +/- full-scale accuracy with 500 ohm maximum burden.
- 3. Transmitters shall be UL/CSA recognized at 600 VAC rating and meet or exceed ANSI/ISA S50.1 requirements.

E. Voltage Transformers

- 1. AC voltage transformers shall be UL/CSA recognized, 600 VAC rated, complete with built-in fuse protection.
- 2. Transformers shall be suitable for ambient temperatures of 40 to 130 degrees F, and shall provide +/- 0.5% accuracy at 24 VAC and a 5VA load.

3. Windings (except for terminals) shall be completely enclosed with metal or plastic material.

F. Surge and Transient Protection

1. Provide each digital controller with surge and transient power protection. Surge and transient protection shall consist of the following devices, installed externally to the controllers.

2. Telephone and Communications Line Surge Protection

- a. Provide surge and transient protection for DDC controllers and DDC network related devices connected to phone and network communication lines, in accordance with the following:
 - 1) The device shall provide continuous, non-interrupting protection, and shall automatically reset after safely eliminating transient surges.
 - 2) The protection shall react within 5 nanoseconds using only solid-state silicon avalanche technology.
 - 3) The device shall be installed at the distance recommended by its manufacturer.

3. Controller Input/Output Protection

Provide controller inputs and outputs with surge protection via optical isolation, metal oxide varistors (MOV), or silicon avalanche devices. Fuses are not permitted for surge protection.

G. Current Switches

1. Current-operated switches shall be self-powered, solid-state with adjustable trip current. The switches shall be selected to match the current of the application and output requirements of the DDC system.

2.4 ACTUATORS

- A. Electronic Actuators: Direct-coupled type designed for minimum 60,000 full-stroke cycles at rated torque.
 - 1. Manufacturers: Belimo Aircontrols (USA), Inc.
 - 2. Listing: Actuators shall have ISO 9001 quality certification and be UL listed under standard 873.
 - 3. Characteristics: Actuators shall be fully modulating/proportional, pulse width, floating/tristate or two-position as required and be factory or field selectable. Each actuator shall have visual position indicators. Proportional actuators shall accept a 0-10VDC or 0-20mA input signal with 2-10VDC and 4-20mA operating range, respectively. Actuators shall be capable of operating on 24, 120 or 230VAC or 24VDC

and Class 2 wiring as required by the application. Power consumption shall not exceed 10VA for 120V actuators and 8 watts for DC actuators. Actuators shall be capable of being mechanically and electrically parallel to increase torque if required

- 4. Fail-Safe Operation: Mechanical, spring-return mechanism shall be provided on all dampers and valves except where noted otherwise. Provide external, manual gear release on non-spring return actuators.
- 5. Valves: Size for torque required for valve close off at maximum pump differential pressure plus 25% safety factor.
- 6. Overload Protection: Electronic overload or digital rotation-sensing circuitry.
- 7. Run Time: 12 seconds open, 5 seconds closed.

2.5 CONTROL VALVES

- A. Control Valves: Factory fabricated, of type, body material, and pressure class based on fluid system, maximum pressure and temperature rating of piping system, unless otherwise indicated.
- B. Valves shall be equipped with a manual positioner to allow positioning of the valve in the absence of power.
- C. Sizing Hydronic system control valves shall be sized as follows:
 - 1. Two-Position: Line Size
 - 2. Two or Three Way Modulating: 10 ft.hd. water pressure drop or as otherwise noted on the plans.
- D. Ball Valves 2" and smaller
 - 1. Body:
 - a. Cast Bronze or Brass
 - b. ANSI B16.5 Class 150
 - c. Threaded or soldered pipe connection
 - 2. Trim:
 - a. Stem: Stainless Steel
 - b. Ball: Stainless with an equal percentage flow characteristic or modified equal percentage flow characteristic for 2-way, linear for 3-way.
 - 3. Bonnet
 - a. Brass
 - b. Packing: Reinforced Teflon or carbon filled Teflon and EPDM O-Ring.
 - c. Seat: Reinforced Teflon or carbon filled Teflon.
- E. Close-off Pressure Rating: Valve actuator and trim shall be furnished to provide the following minimum close-off pressure ratings.
 - 1. Water Valves:
 - a. Two-Way: 150% of total system pump head.

b. Three -Way: 300% of pressure differential between ports A and B at design flow rate or 100% of total system pump head.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Verify location of wall mounted sensors with drawings and room details before installation. Install devices to match rough in height of light switches provided by the Electrical Contractor, Coordinate location and placement with other wall mounted devices, cabinets, etc.
- B. Room temperature sensors shall be installed on concealed metal junction boxes properly supported by the wall framing.
- C. Local control panels shall be provided for the equipment being controlled. The panel shall be mounted in the mechanical room with the equipment it serves. Mount panels on wall or independent support structure. Do not mount on equipment.
- D. Identification of Hardware And Wiring
 - a. All wiring and cabling, including that within factory-fabricated panels, shall be labeled at each end within 2" of termination, with the DDC address or termination number.
 - b. Permanently label or code each point/object of field terminal strips to show the instrument or item served.
 - c. Identify control panels with minimum ½" letters on laminated plastic nameplates.
 - d. Identify all other control components with permanent labels. All plug-in components shall be labeled such that removal of the component does not remove the label.
 - e. Identify room sensors relating to terminal units or valves with adhesive stickers.
 - f. All identifiers shall match the naming convention on the drawings and within the DDC graphics.

END OF SECTION 23 0913

SECTION 23 0914 - CONTROL WIRING AND CABLING

PART 1 - GENERAL

1.1 SUMMARY

A. This Section includes control wiring, both line and low voltage, transformers, power distribution, fusing and panels, power filtering and communication cabling which is required to perform the automatic control functions described.

B. Related Sections:

- 1. 23 0913 Instruments and Control Devices
- 2. 23 0923 Direct Digital Control System

1.2 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- B. Wiring, both line and low voltage, shall comply with NEC and shall be subject to approval by the local code enforcing authorities.
- C. Wire, conduit and installation methods shall conform to applicable provisions of Division 26 Electrical except that wiring smaller than No. 12 and conduit smaller than 3/4" are permitted as appropriate for the application.
- D. Communication cabling shall conform to applicable provisions of Division 27- Section "Communications Horizontal Cabling".
- E. All wiring and cabling insulation in air return plenums shall not exceed maximum flame spread rating of 25 and smoke development rating of 50 as established by NFPA 255 test methods.

PART 2 - PRODUCTS

- A. Power Supplies: Transformers with Class 2 current-limiting type or overcurrent protection; limit connected loads to 80 percent of rated capacity. DC power supply shall match output current and voltage requirements and be full-wave rectifier type with the following:
 - 1. Output ripple of 5.0 mV maximum peak to peak.
 - 2. Combined 1 percent line and load regulation with 100-mic.sec. response time for 50 percent load changes.
 - 3. Built-in overvoltage and overcurrent protection and be able to withstand 150 percent overload for at least 3 seconds without failure.

- B. Power Line Filtering: Provide internal or external transient voltage and surge suppression for workstations or controllers with the following:
 - 1. Minimum dielectric strength of 1000 V.
 - 2. Maximum response time of 10 nanoseconds.
 - 3. Minimum transverse-mode noise attenuation of 65 dB.
 - 4. Minimum common-mode noise attenuation of 150 dB at 40 to 100 Hz.

C. Power distribution, fusing and panels:

1. Power distribution transformers, fuses, termination strips etc. shall be organized in NEMA 1 enclosure panels. Panels shall be 16 gauge steel construction, with removable front cover and various size removable knockouts, arranged for surface mounting and polyester powder coat finish inside and outside, UL listed. Arrange and bundle wiring inside of panels neatly with cable ties. Panel and internal devices shall be permanently marked to correspond to power wiring diagram shop drawings provided in the operating and maintenance manual.

D. Cabling:

- 1. Provide CAT 5E Ethernet fiber optic cabling to interconnect major controllers and work station computer or Web server to establish the primary network configuration as determined by the direct digital control system architecture. Provide excess cabling at each connection for servicing by looping cable near the panel.
- 2. Secondary LON or BacNet MS/TP bus wiring to secondary controllers such as unitary controllers serving VAV boxes shall be as required by the communication protocol.
- 3. All cabling insulation shall be approved and labeled for use in air plenums where installed in these locations.

PART 3 - EXECUTION

3.1 ELECTRICAL POWER SUPPLIES

- A. The Electrical Contractor will provide a power source to motors through his starters only. Where power sources are required beyond these starters, or beyond sources explicitly shown on the electrical drawings, these shall be provided by the Controls Contractor. Where auxiliary contacts are required on starters to perform the required functions, these too shall be provided by the Controls Contractor, where not provided under the Electrical Contract. Auxiliary relays maybe provided in lieu of auxiliary contacts.
- B. Circuits serving control panels, transformers for low voltage service, and other control equipment and devices shall be independent and used for no other purpose. These shall originate from the nearest appropriate electrical panel. Circuit wiring from the electrical panel shall be included in this contract. These circuits shall be clearly identified at the panels.

3.2 ELECTRICAL WIRING AND CONNECTION INSTALLATION

- A. Install all work in accordance with the following:
 - 1. All wiring to be ran in a neat, workmanlike manner. All wiring to be tie wrapped or in conduit as per specifications. Wiring or conduit to be ran parallel or at right angles to building structure. Install all wiring free of sags. Bundle wiring together that follows a common path.
 - 2. All conduit, plenum wiring, and panels shall be supported directly from the building structure with beam clamps and bridle ring. Do not support from pipe, pipe hangers, threaded rod, ductwork, ductwork strapping or other conduit.
 - 3. Do not lay conduit or plenum wiring on acoustic ceiling tiles, grid members or uninsulated water piping. Conduit and wiring should be installed in such a way as to not interfere with removing ceiling tiles for above ceiling access.
 - 4. All line voltage wiring must be kept separate from low voltage wiring. Line and low voltage wiring may not be run in the same conduit. Line and low voltage wiring must be kept separate in control panels.
 - 5. Label all wire jackets at control panel/controller and at device with tag as shown on wiring details and flow diagrams.
 - 6. Observe proper polarity as shown on wiring diagrams when connecting 24VAC power and ground controllers and other devices. Note that all transformer secondary grounds must be tied to chassis ground as shown in wiring diagrams unless otherwise noted.
 - 7. Coordinate with General Contractor and all trades to perform rough-ins for temperature control sensors and devices.
 - 8. Coordinate with General Contractor and all trades to confirm mounting locations for temperature control panels.
 - 9. Completely seal all duct, unit and wall penetrations. Avoid ceiling penetrations if at all possible. Completely seal any ceiling penetrations that are absolutely necessary.
 - 10. All network communication wires shall be labeled at each controller with the designation or the controller that the communication wire originates from and terminates to
 - 11. Verify network communications and correct any issues.
 - 12. Clean all construction debris from inside temperature control panels before operation.
- B. Install raceways, boxes, and cabinets according to Division 26 Section "Raceway and Boxes for Electrical Systems."
- C. Install building wire and cable according to Division 26 Section "Low-Voltage Electrical Power Conductors and Cables." All line voltage wiring and low voltage wiring (except as stated below) shall be run in conduit.
 - 1. Low voltage wiring concealed above accessible ceilings may be run without conduit. Cabling shall be plenum rated.
 - 2. Open wiring dropping into walls shall be run in conduit. Thermostats shall be installed on a single gang box and conduit shall be installed to extend into the plenum. Open wiring shall be bundled and supported at 3 ft. maximum intervals with a system of J-hooks or equivalent means. Open wiring in air plenums shall be rated for such use and so labeled.

END OF SECTION 23 0914

This page left blank intentionally

SECTION 23 0923 - DIRECT DIGITAL CONTROL SYSTEM

PART 1 - GENERAL

1.1 SUMMARY

- A. A complete system of computer based, direct digital automatic temperature controls shall be installed under this contract as required to accomplish the sequence of control for existing and one new VAV terminal units.
- B. This Section includes Direct Digital Control (DDC) components, including operator work station, controller/server, equipment specific and generic controllers, I/O interface, software and graphics.
- C. See Sections 23 0913 "Instruments and Control Devices", Section 23 0914 "Control Wiring and Cabling" for requirements that relate to this Section.

1.2 SUBMITTALS

- A. Product Data: For all hardware and software.
- B. Shop Drawings:
 - 1. Schematic air flow control diagrams.
 - 2. Sequence of operations descriptions and points list.
 - 3. Power, wiring diagrams.
 - 4. DDC System Hardware components, including controllers, actuators, sensors, valves, dampers, cabinet enclosures, wiring, misc. controls devices, etc.
 - 5. Control System Software
 - 6. Graphics Screen examples specific to the project for:
 - a. VAV Air Terminal Units
- C. Software and firmware operational documentation.
- D. Operation and maintenance data.

1.3 QUALITY ASSURANCE

- A. Each control subcontractor must be an authorized temperature control contractor in the business of installing and servicing direct digital temperature control systems for over five (5) years. The bidder must have installed and successfully completed at least ten (10) DDC systems of similar size using the same hardware that is proposed.
- B. Subcontractor installation and service office must be located within 75 miles (90 minute travel time maximum) of the building site.

- C. Design and installation of the digital control system shall be performed by employees trained and certified by the equipment supplier. Electrical power work other than low voltage shall be performed by licensed electricians.
- D. The temperature controls subcontractor shall provide all necessary engineering support for a complete and functional system, including but not limited to engineering, programming, installation, supervision, commissioning and troubleshooting.
- E. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.

PART 2 - PRODUCTS

2.1 CONTROL SYSTEM

A. Contractors:

- 1. Alerton by Automated Solutions Group
- 2. BuildingLogiX by Waibel Energy Systems Inc.
- B. Complete DDC system shall consist of operator workstation, sensors, indicators, actuators, final control elements, interface equipment, wiring, cabling, power supplies and power distribution, other apparatus, accessories, software and graphics connected to distributed controllers operating in multiuser, multitasking environment on token-passing network and programmed to control mechanical systems as specified here and in related Division 23 Sections.

2.2 LICENSING AGREEMENT AND OPEN PROTOCOL

- A. A true Open Licensing Agreement shall be provided and executed with the Owner to permit total and open access to the system for servicing and software revisions by other qualified servicing contractors.
- B. The supplied system must incorporate open protocol with the ability to access all data using Java base Web enabled browsers without requiring proprietary operator interface and configuration programs.
- C. An Open DataBase Connectivity (ODBC) or Structured Query Language (SQL) compliant server database is required for all system database parameter storage. This data shall reside on a server. Proprietary database and user interface programs are not acceptable (except for unitary controllers as noted below).
- D. The supplied computer software shall employ object-oriented technology (OOT) for representation of all data and control devices within the system. In addition, adherence to industry standards including ANSI / ASHRAETM Standard 135, BACnet to assure interoperability between all present and future system components is required.

E. Proprietary programming shall not be utilized. In addition, all required programming software and graphics shall be embedded in the server or controllers without the need for external software to execute queries or revisions. All graphics shall reside in the server. Remote access via LAN or Web shall not require external software to provide complete access to all data, graphics, alarms, programming, etc.

2.3 DDC ARCHITECTURE

- A. DDC system shall be complete with an Operators Workstation/Server, Configurable Controllers, Unitary Controllers, required I/O modules for controller expansion, communication cards in controlled devices such as chillers, variable frequency drives (furnished with the equipment, coordinate card requirements), arranged for a completely integrated building automation system network.
- B. Physical connection of BACnet network controllers shall be via Ethernet/Ethernet IP using the Owner's Local Area Network (LAN).
- C. Where data drops are not shown for the Configurable Controllers or Operator Station/Server, the temperature control subcontractor shall be responsible to provide the IP data drop to each network controller location for controller connectivity. Installation shall be subcontracted to the division 27 technology contractor; coordinate connection requirements. In addition, provide an additional IP data drop to each controller, or group of controllers to provide local access to data acquisition for the HVAC service technician.
- D. All components and controllers supplied under this contract shall be true "peer-to-peer" communicating devices. Components or controllers requiring "polling" by a host to pass data shall not be acceptable.
- E. A hierarchical topology is required to assure reasonable system response times and to manage the flow and sharing of data without unduly burdening the customer's internal Intranet network. Maximum acceptable response time from any alarm occurrence (at the point of origin) to the point of annunciation shall not exceed 5 seconds for network connected user interfaces. Maximum acceptable response time from any alarm occurrence (at the point of origin) to the point of annunciation shall not exceed 60 seconds for remote or dial-up connected user interfaces.
- F. DDC system accessibility over the LAN or the Internet shall be user name and password protected. Provide separate user name/password for multiple level hierarchy to restrict access to appropriate personnel at the different levels (view, programming, etc.). The system must be set up to have at least 3 access levels: guest, user and administrator. Guest privileges shall be limited to view only. Users shall be able to make setpoint and schedule changes. Administrators shall have all privileges as users in addition to being able to assign passwords.

2.4 OPERATOR WORKSTATION/SERVER

A. An operator workstation/server shall be provided to effectively program, manage and access DDC information from all of the controllers. Interface shall utilize dynamic color graphics of

each mechanical system, building floor plan, and control device depicted by point-and-click graphics.

- B. All DDC information shall be accessible through the server over the LAN as well as over the Internet via Ethernet IP.
- C. Operator Workstation/Server Computer: Equal to Dell Studio XPS 630.
- D. Minimum Requirements (or equivalent):
 - 1. Processor: Intel Core 2 Duo.
 - 2. Ports/Jacks: (6) USB 2.0, (2) IEEE 1394a, headphone, microphone, 19-1 media reader, (1) RJ-45, 2.1 audio, S video in/out, S/PDIF optical
 - 3. Random-Access Memory: 2GB Dual Channel DDR2 SDRAM.
 - 4. Monitor: 20" wide screen, WSXGA resolution, 5ms pixel display rate, 720p high definition display flat panel.
 - 5. Graphics: Intel GMA 3100
 - 6. Hard-Disk Drive: 160 GB.
 - 7. 48X combo optical drive.
 - 8. Communications: Integrated Gigabit Ethernet (10/100/1000Base-T), internal WiFi 802.1 a/b/g/n Draft 2.0
 - 9. 10W Stereo Speakers
 - 10. Operating System: Microsoft Windows
 - 11. Keyboard.
 - 12. Mouse: Three button, optical.
 - 13. Six outlet surge protector.
 - 14. Printer: Laser jet type, B&W, 8Mb RAM equal to HP LaserJet 1022
 - 15. Workstation desk and chair will be provided with loose furnishings by others.
- E. The server shall provide integrated control, supervision, data logging, alarming, scheduling and network management functions. The controller/server provides the Internet connectivity and Web serving capabilities, presenting real time information in Web based, rich graphical displays for the system. Application control programs to provide: Calendar functions, Scheduling, Trending, Alarm monitoring and routing, and Time synchronization.
- F. Proprietary programming shall not be utilized. In addition, all required programming software shall be embedded in the server or controllers without the need for external software to execute queries or revisions. All graphics shall reside in the server. Remote access via LAN or Web shall not require external software to provide complete access to all data, graphics, alarms, programming, etc.
- G. The server shall support standard Web browser access via the Intranet/Internet.
- H. Provide and maintain an Audit Log that tracks defined activities on the system. Provide the ability to specify a buffer size for the log and the ability to archive log based on time or when the log has reached a user-defined buffer size. Archive the log locally. For each log entry, provide the following data: Time and date, User ID, Change or activity: i.e., Change setpoint, add or delete objects, commands, etc.
- I. The controller/server shall have the ability to automatically backup its database. The database shall be backed up based on a user-defined time interval. Copies of the current database and the

most recently saved database shall be stored in the server. The age of the most recently saved database is dependent on the user-defined database save interval. The controller/server database shall be formatted to allow for user viewing and editing, if desired.

2.5 CONFIGURABLE CONTROLLERS/SERVERS

- A. An individual configurable controllers (Tritium JACE 9000) shall be provided. Air control box terminals may utilize local, unit specific controllers, and be connected to the JACE controller/server.
- B. Controllers shall be capable of functioning in either a standalone capacity or integrated into the building network.
- C. Controllers shall be fully configurable type with both control and server capabilities including integrated control and management of external devices, supervision, data logging, alarming, scheduling, network management functions, Internet connectivity, web serving. The controller shall include software technology capable of integrating a variety of devices, interoperable networks and protocols such, BACnet, ModBus, etc into a seamless operating platform.
- D. The controllers shall be expandable by the use of input/output I/O modules to provide additional points beyond resident points provided on the controller module.
- E. Each configurable controller shall be a Tritium Niagara JACE 9000 and include the following minimum hardware features. Where required for functionality provide additional communication cards, memory cards or I/O modules: Two (2) Ethernet Port -10/100 Mbps, One (1) RS-232 port, One (1) RS-485 ports (BACnet MS/TP), LON Tunnel service, BACnet driver (Ethernet and Ethernet IP), Power Supply 24V power supply module, Battery Backup, 64 Mb flash memory for long term data backup and 64 Mb RAM.
- F. I/O modules shall connect to the controller with a single multi pin plug, powered through the controller with a minimum of eight (8) universal inputs, four (4) analog outputs and four (4) relay outputs, Form A contacts. Do not exceed maximum I/O modules recommended by the manufacturer.
- G. The controller/server must be capable of operation over a temperature range of 0 to 50°C and storage temperatures of between 0 and 70°C. The controller/server must be capable of operation over a humidity range of 5 to 95% RH, non-condensing.
- H. The controller/server shall support standard Web browser access via the Intranet/Internet.
- I. Where acting as a server, provide and maintain an Audit Log that tracks all activities performed on the controller/server. Provide the ability to specify a buffer size for the log and the ability to archive log based on time or when the log has reached it's user-defined buffer size. Provide the ability to archive the log locally (to the controller/server), to another controller/server on the network, or to a server. For each log entry, provide the following data: Time and date, User ID, Change or activity: i.e., Change setpoint, add or delete objects, commands, etc.
- J. The controller/server shall have the ability to automatically backup its database. The database shall be backed up based on a user-defined time interval. Copies of the current database and, at

the most recently saved database shall be stored in the controller/server. The age of the most recently saved database is dependent on the user-defined database save interval. The controller/server database shall be stored, at a minimum, in XML format to allow for user viewing and editing, if desired. Other formats are acceptable as well, as long as XML format is supported.

- K. Controllers shall be fully programmable with "drag and drop" graphic representations of control algorithms and easy to use "wizards" that automate controller configurations.
- L. Controllers shall be "Native" BACnet devices with interoperable native BACnet, IP, LON and MS/TP communication support.
- M. Each controller with I/O modules shall include input/output capabilities with, as a minimum, sufficient universal inputs, digital inputs, universal outputs and digital outputs to perform the required function and include an additional spare two (2) universal inputs, (2) analog outputs and two (2) relay outputs for future upgrade capability (spare points are not required for unitary controllers).

2.6 UNITARY CONTROLLERS

- A. Controller designed specifically for VAV reheat air terminal units, fan coil, unit heater, etc., shall be used for each distributed HVAC equipment item. Local controllers shall be capable of functioning in a standalone capacity but shall be integrated into the building network.
- B. Use of a dedicated network with a proprietary communication protocol that is compatible for integration into the configurable controllers is acceptable provided the unitary controllers use true peer to peer communication for all devices, the communication network uses simple non polarity sensitive twisted pair wiring and the network provides for interoperability between devices and controllers such as Echelon LonWorks is acceptable.
- C. For VAV reheat air terminal units:
 - 1. The controller shall include, where required, a digital communication to:
 - 2. The remote, space temperature and/or humidity wall sensor,
 - a. The remote wall sensor shall include a communication jack for connecting a laptop to the terminal unit controller for air/water balance purposes.
 - 3. Velocity pressure pneumatic input via polyethylene tubing for supply air flow reading,
 - 4. Supply air flow sensor,
 - 5. Flow balancing software (damper adjustment, set point monitoring and adjustment, flow validation and calibration, sequence/calibration/control set point logs)
 - a. Terminal unit supply air temperature sensor
 - 6. Damper actuator shall be separate from the VAV reheat box controller; integrated controller/actuator devices are not acceptable.
 - 7. Integral controller/damper actuator is acceptable.
- D. Controllers used for remote temperature and humidity sensing, adjustment and override such as VAV air terminal unit controllers and fan coil units shall include S-link communication via two wire, unshielded cable (non polarity sensitive) to provide power and communication interface for remote sensors.

2.7 CONTROLLER ENCLOSURE AND LISTING

- A. Controllers shall be placed within enclosures that conform to NEMA-1 construction and shall further meet UL 94-5V flammability ratings for plenum application use.
- B. Each controller shall be UL-916 listed and meet FCC Part 15 Class A.

2.8 GUI DISPLAY FRAMES

- A. System Access The system must be set up to have at least 3 access levels: guest, user and administrator. Guest privileges shall be limited to view only. Users shall be able to make setpoint and schedule changes. Administrators shall have all privileges as users in addition to being able to assign passwords.
- B. Each VAV air terminal unit shall have a graphics screen and a text screen.
- C. Systems that won't permit creating these customized screens as described herein will not be acceptable. Systems that use controllers that won't permit overrides of inputs and outputs from a browser based graphic screen will not be acceptable.

D. Animations

- 1. All shapes shall be 3-D with a common perspective.
- 2. All dampers shall have a minimum of 4 animation levels to show partially open, half open, mostly open, fully open, and closed position of dampers.
- 3. All analog inputs shall show the actual value and engineering units on the graphic screen.
- 4. Binary inputs shall be linked to flashing animated displays.
- 5. Safety alarms will flash when in alarm.
- 6. Filter status shall be indicated when value indicates that they are dirty.
- 7. To prevent clutter on the graphic displays, symbols will only be shown for equipment that is controlled or monitored by the DDC system.
- 8. Normal status for safeties will not be indicated, and normal status for safeties will be indicated by an image of a clean filter.
- 9. Pumps and fans shall rotate when flow is proven by a monitoring device. Coils shall change color when valves are open to permit water flow through the coils.
- E. Color Schema Graphics shall use common color schemes to make the overall system easy to understand. All overall backgrounds shall be white or other neutral color. All text shall be black. Any value that is in alarm shall be red or have a red background. Any value that is overridden shall have a blue background. All like sensors shall be the same color. For example, all temperature devices shall be yellow, all pressure devices shall be purple, all humidity devices shall be teal, all fire alarm devices shall be red, and all CO2 devices shall be green.
- F. Current setpoints and occupancy status shall be shown at the bottom of each graphic screen.
- G. Floor Plans Overall floor plan drawings shall be provided, and permit access to each zone's individual floor plan sections.
 - 1. On the individual floor plan sections, room numbers and room temperature and setpoint shall be displayed. Values that are out of the acceptable range shall appear in a different background color and/or flash.

- 2. Each VAV air terminal unit shall have its own graphic screen that contains the points from within its controller including the box flow setpoint, room temperature setpoint, maximum cooling flow setpoint, minimum cooling flow setpoint, and minimum heating flow setpoint, plus the discharge air temperature from the AHU supplying the unit. The VAV text screen shall have the same information as the graphic screen plus high and low flow calibration values, damper rotation adjustment (CW or CCW), and air balance set-up features.
- 3. GUI shall permit operator the ability to enable, set or disable high and low occupied and unoccupied limits for each room temperature reading.
- H. Text Screens shall be available for all levels of access. Setpoint and output values are changeable from the text screen for users with appropriate access privileges and administrators, but not guests. When a value can be overridden or edited, a red box shall appear around it when the cursor is position on it. A single click of the mouse shall bring up pop up menu that provide options to make a permanent override, change setpoint, or release a previous override of an output point. Analog inputs shall have pop up menus that allow setting high and low alarm limits and the ability to enable and disable alarm limits as appropriate for the sensing device. Pop up menus must be customized to include a description of the point that is being modified. Generic override menus are not permitted because they would not describe to an operator what is about to be modified. The Control Contractor shall set up all initial alarms as indicated in the point matrix.
- I. Text screens shall include schedule information including current state and date and time of next scheduled event. Positioning the mouse over the current state shall permit single click access to the schedule. The schedule screen shall allow the operator to edit a yearly, weekly, daily, holiday or special event schedule for the system being viewed. Temperature values and setpoints shall be displayed below the schedule information, and shall have a minimum of 1 decimal place. Heating, cooling and damper ouputs shall be displayed next. The OA temperature for economizer switchover shall be displayed and adjustable from the text screen. Air flow readings shall be shown with setpoint and actual readings. Fan information shall be shown next, followed by static pressure readings and setpoints, which shall have a minimum of 2 decimal places. Miscellaneous setpoints including night setback cooling and heating, average zone temperature, return air warm-up and cool-down, dehumidification, and unoccupied mixed air temperature setpoints shall all be shown and adjustable. All safeties shall be shown, followed by coil pump control information.
- J. Each system shall have its own specific alarm screen available to all operators but only editable by operators with user and administration access privileges. From the alarm screen, users and administrators shall be able to enable and disable alarms. Points that are in alarm shall have an alarm symbol highlighted in red. Points that are not in alarm shall be shown in gray. Alarms that are disabled shall have a way to indicate this on the alarm screen graphic.
- K. Loop tuning screens shall be available through the web browser interface to save the owner the cost and time associated with using vendor specific software for tuning loops. Access to these screens shall not be provided to guests. Air handling units shall have dedicated screens for discharge air temperature, static pressure, and outside air control loops. Loop tuning screen for discharge air temperature shall include the discharge air temperature, discharge air temperature setpoint, cooling loop throttling range, I-gain and ramp time, heating loop throttling range, I-gain and ramp time, economizer loop throttling range, I-gain and ramp time, unoccupied heating loop throttling range, I-gain and ramp time, cooling valve output, heating valve output, and

- damper control output. Screens shall also have graphs that show 5 minutes of live data for the discharge air temperature, setpoint, cooling valve, heating valve and mixed air dampers. Each loop tuning screen shall include the appropriate throttling range, I-gain and ramp time.
- L. Each non-unitary controller shall have an override screen. These screens shall be available on-site for use during point-to-point check-out and commissioning. The override screen shall show the inputs and outputs for each controller with the points in their wired location. Unused points shall be shown as spares. Points that are in alarm shall have a red background, and points that are overridden shall have a blue background just as on other screens. These screens shall show the actual values that come back from the controller, not the values that may have been typed in for override at the GUI if the controller software is not accepting the override value. The override screen shall also permit timed overrides.
- M. Each air handling unit shall also have an overview screen listing every VAV terminals data in a text format that includes occupancy mode, room temperature, room setpoint, box flow, flow setpoint, temperature leaving VAV terminal, % cooling and % heating. Also, each VAV AHU shall have an air balance screen that will permit balancing the system through a computer connected to the Ethernet or directly to the appropriate BC without vendor specific software. The air balancing screens shall permit at least 8 manual override commands: normal, position (%), flow value, flow percent, open, close, min flow, and max flow.
- N. Heating systems and cooling systems with multiple pieces of equipment such as pumps with lead-lag control shall display which device is lead and when the other device will become lead on the text screen.
- O. Although only one outside air temperature sensor is needed per building, the GUI shall use independent outside air temperature points, so that during check-out and commissioning, the outside air temperature for a system can be changed without changing the outside air temperature for the whole building. The GUI shall also have a global outside air temperature point that can be overridden from the screen for the controller where the point is physically connected. Overriding this outside air temperature value will change it for all systems, except when outside air temperature has been overridden for an individual system.
- P. The system shall allow for the easy development and editing of dynamic graphics. Wizards shall be utilized to assist the operator with their manipulation of the graphic system. The operator shall be able to, through a single mouse function, select between the dynamic display mode and the graphic edit mode for the currently viewed graphic frame, assuming appropriate access level is provided to the operator. Systems requiring multiple mouse or operator keyboard commands to enter the graphic edit mode are not desirable and require thorough definition of steps involved to accomplish function.
- Q. Animation of system data shall be provided via graphic elements on the display frames. Standard graphic element library shall be provided to assist the operator with their implementation. The ability to define and add new animated graphic elements shall be provided. As a minimum, the ability to move, size, draw, arrange, align, layer, space, rotate, invert, duplicate, cut, copy, paste, erase any animated element shall be provided. System parameters and setpoints shall be assignable and modifiable by the animated graphic elements, relieving the need for keyboard commands for system manipulation.

- R. The ability to simultaneously display a dynamic X/Y chart of selected points, shall be provided. The chart shall be an element of the graphic display and shall automatically update with the display data. The chart shall allow for dynamic manipulation to modify the range, rate, and timeframe of view, in both a real-time as well as historical configuration. A minimum of 4 values shall be included on any chart display element. There shall not be a limit to the quantity of chart elements displayed on a graphic frame. Trace colors and X values shall be User configurable. Systems not providing this capability are required to provide an equivalent charting package with the GUI offering.
- S. The ability to provide graphically displayed global scheduling and editing functions shall be provided. The ability to link these functions to the associated equipment or zone frames shall be a standard feature. A calendar shall be provided for display and modification of the SDC time clock functions. The User shall be able to view a daily, weekly, monthly, annual, special or holiday schedule from a defined display frame. A list of served areas shall be displayed on the same screen, this list shall be displayed at all times, pull down menus or other means of accessing these areas shall not be acceptable. The system shall have a master override screen that will allow an operator to change the schedule for every piece of equipment in every building by changing the master schedule.
- T. All analog values shall be trended every 15 minutes. The trend samples shall be saved in the BC for at least 36 hours. Access to trended data shall be available by the single click of a mouse on the analog value. Systems that open other windows and require a selection of the desired data are not acceptable.

2.9 GUI ALARMING

- A. The GUI shall provide, as standard, alarm annunciation of system data. On every display frame, the ability to view, acknowledge, delete and manipulate real-time and historical alarms shall be provided. The ability to provide a unique and custom alarm display for every display frame shall be provided. The ability to continuously or upon request, view the alarm display, shall be provided.
- B. Alarm conditions shall be capable of invoking, as a minimum; a display frame, an email message, a text message sent to a pager or cellular phone.
- C. Alarm logging shall be provided in a user definable configuration. All alarms shall be displayed and/or routed as follows, as a minimum; GUI display frame, local printer, server printer, client printer, logged to file, and archived in standard format for information management. Alarm groupings shall be hierarchical in nature allowing up to 8 alarm groups and 16 sub-groups. The GUI shall not possess any limits on the quantity of alarms that can be logged, including historical data archiving. Systems possessing limits must define the restrictions and may not be acceptable.
- D. Provide up to 999 alarm priorities with up to 5 alarm color changes, per priority, according to alarm status.

2.10 GUI TRENDING

- A. The GUI shall automatically perform time based, user defined, periodic collection of real time point data. The data shall be presented as an X/Y chart in the display frame. The data shall be stored and archived in a file format that allows for the manipulation and utilization of the data by third party applications.
- B. A dynamic trend shall be defined as a group of at least 4 data points, with a circular buffer of 2000 data points. A historical trend shall be defined as a group of at least 8 data points, with the sampled points limited only by archival disk space. Sampling rates shall be user selectable from instantaneous (one per second) to once a week. Collection of data shall be user selectable to start and stop on a specific time and date. There shall be no limit to the number of X/Y charts within a display frame.
- C. X/Y charting and column and row reporting shall be an integral part of the system. All points shall be chartable or reportable. Analytical data shall be displayed for any of the selected points in a clearly displayed X/Y chart. This analytical data shall consist of at least the following: Average Mean, Standard Deviation, Simple Average, Current Value, Cycle Length, Cycle High and Cycle Low.
- D. X/Y charting shall provide for the following chart manipulation: display, zoom, scroll, centering, pen legend and export to Excel, Text via Dynamic Data Exchange.

PART 3 - EXECUTION

- 3.1 Furnish a complete set of shop drawings showing the kind of control equipment for each of the various systems and their functions, along with indication on the drawing of all original setpoints and calibration values and set up parameters, and sequence of operation and also that of the automation system. These drawings shall be submitted for approval to the Engineer, together with a complete brochure describing the equipment and their function and operation.
- 3.2 The control equipment supplier shall submit a detailed outline of the owner training material for review and comment by the Engineer during the shop drawing phase. The control system training program shall be customized to reflect the systems installed under this contract and shall cover, as a minimum: software navigation (via custom graphics and Windows based icons), system architecture, pass wording and system security features, input/output control functions, alarm functions/acknowledgement, trending/long term reporting, and control component operation.
- 3.3 Upon completion of the project, furnish and turn over to the Owner and Architect (3) complete sets of brochures describing the various items of equipment, their functions and directions for operation and maintenance.
- 3.4 Upon completion of the control system, the Control Contractor shall adjust all components of the system. ATC Contractor shall make all adjustments in the control system required and as directed by the air balance contractor to achieve the desired air balance quantities. All instruments shall be carefully calibrated and each control function shall be demonstrated to function properly, to the satisfaction of the Engineer and the Owner. Provide a complete instruction manual covering the function and operation of all components. At the time of demonstration, each function shall be simulated to insure that controls respond properly to all signals, and the Owner shall be instructed in the proper operation of the system.
- 3.5 In addition to the adjustments and fine tuning, the Contractor shall include as a part of this contract an additional 40 hours of service technician time for work as directed or authorized by the Engineer to make software changes or field adjustments to hardware.
- During the first year of operation, after acceptance by the Owner, the Control Contractor shall provide complete service to adjust or assist the Owner in adjusting the equipment to obtain optimum performance form the control equipment and from the heating and air conditioning systems in general. This shall be done without additional expense to the Owner. This work shall include revisions to DDC software programs and controller programs, and all PC front end software upgrades. All software shall be provided to the Owner in disk form, including back-ups of final field programs.
- 3.7 The control equipment manufacturer shall provide instruction and training of the Owner's personnel regarding the hardware and software of the system. Software training shall include

programs, methods of programming, control loops, scheduling and reports. Training covering hardware shall include operation information, functional use, wiring diagrams and schematic diagrams necessary to troubleshoot the operating system. Training shall include "hands on" instructions to completely familiarize Owner's personnel with the equipment and system. Training of Owner's personnel shall be equal in scope and detail to that provided by the manufacturer to its service technicians.

3.8 TRAINING

The control equipment supplier shall provide 16 hours of instruction at the job site to familiarize the Owner's personnel in the application and details of the installed system. Site training classes shall not be scheduled for longer than 4 hours duration except at the discretion of the Owner.

3.9 FIELD QUALITY CONTROL

- A. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect, test, and adjust field-assembled components and equipment installation, including connections, and to assist in field testing. Report results in writing.
- B. Perform the following field tests and inspections and prepare test reports:
 - 1. Operational Test: After electrical circuitry has been energized, start units to confirm proper unit operation. Remove and replace malfunctioning units and retest.
 - 2. Test and adjust controls and safeties.
 - 3. Test calibration of controllers by disconnecting input sensors and stimulating operation with compatible signal generator.
 - 4. Test each point through its full operating range to verify that safety and operating control set points are as required.
 - 5. Test each control loop to verify stable mode of operation and compliance with sequence of operation. Adjust PID actions.
 - 6. Test each system for compliance with sequence of operation.
 - 7. Test software and hardware interlocks.

C. DDC Verification:

- 1. Verify that instruments are installed before calibration, testing, and loop or leak checks.
- 2. Check instruments for proper location and accessibility.
- 3. Check instrument installation for direction of flow, elevation, orientation, insertion depth, and other applicable considerations.
- 4. Check instrument tubing for proper fittings, slope, material, and support.
- 5. Check pressure instruments, piping slope, installation of valve manifold, and self-contained pressure regulators.
- 6. Check temperature instruments and material and length of sensing elements.
- 7. Check control valves. Verify that they are in correct direction.
- 8. Check dampers. Verify that proper blade alignment, either parallel or opposed, has been provided.
- 9. Check DDC system as follows:

- a. Verify that DDC controller power supply is from emergency power supply, if applicable.
- b. Verify that wires at control panels are tagged with their service designation and approved tagging system.
- c. Verify that spare I/O capacity has been provided.
- d. Verify that DDC controllers are protected from power supply surges.
- D. Replace damaged or malfunctioning controls and equipment and repeat testing procedures.

END OF SECTION 23 0923

DARKE COUNTY WAGNER AVENUE INTERIOR RENOVATION2025

SECTION 23 2113 - HYDRONIC PIPING

PART 1 - GENERAL

1.1 SUMMARY

A. This Section includes:

- 1. Pipe, Fittings and Joining Methods.
- 2. Unions and flanges
- 3. Dielectric Connectors
- 4. Installation methods of piping
- 5. Testing

B. Related Sections

1. 23 0529 Hangers and Supports.

1.2 SUBMITTALS

- A. Product Data: For each type of the following:
 - 1. Pipe and fittings for each type utilized.

1.3 QUALITY ASSURANCE

- A. ASME Compliance: Comply with ASME B31.9, "Building Services Piping," for materials, products, and installation. Safety valves and pressure vessels shall bear the appropriate ASME label. Fabricate and stamp air separators and expansion tanks to comply with ASME Boiler and Pressure Vessel Code: Section VIII, Division 1.
- B. Welders shall be qualified and fully certified in accordance with ASME Boiler and Pressure Vessel Code, Section IX, Welding and Brazing Qualifications.
- C. Welding procedures and testing shall comply with ANSI Standard B31.1.0 Standard Code for Pressure Piping, Power piping and The American Welding Society Welding Handbook.
- D. Piping between the power boiler (steam boiler above 15 psig) and the valve to valves required in ASME Code, Section 1 shall be in conformance with ANSI B31.1 Power Piping. Welding shall be performed under PP certification and so stamped.
- E. Safety valves and all pressure vessels shall bear the appropriate ASME label.

DARKE COUNTY WAGNER AVENUE INTERIOR RENOVATION2025

PART 2 - PRODUCTS

2.1 STEEL PIPING PRODUCTS

- A. Refer to 'Piping Systems Schedule' on drawings.
- B. Reinforced forged welding outlets equal to Bonney Forge "Weldolet®" and "Thredolet®" shall be used where branch is two sizes smaller than the main. Unreinforced nipples and fish-mouthed connections are not acceptable.

2.2 COPPER TUBING (ASTM B88-86) PRODUCTS

- A. Refer to 'Piping Systems Schedule' on drawings.
- B. Mechanically formed tee fittings and couplings in copper tubing, such as T-Drill, are not permitted.

2.3 UNIONS AND FLANGES

- A. Unions on copper tubing, all bronze construction 150 lb., solder ends.
- B. Unions on steel pipe 2" and smaller, malleable iron with ground seat, bronze to steel, 300 lbs., screwed ends.

2.4 DIELECTRIC CONNECTORS

- A. A dielectric connector shall be incorporated at each connection between ferrous and copper piping. Connectors shall be:
 - 1. Dielectric coupling with non-conductive polymer liner, Lochinvar Corp. "V-line" Dielectric fitting on services 180 degrees and less.
 - 2. Dielectric flange with non-metallic bolt hole grommets and gasket.
 - 3. Brass adaptor, for HVAC application only.

PART 3 - EXECUTION

3.1 PIPING

A. Pipe and tubing shall be cut and fabricated to field measurements and run parallel to normal building lines. Pipe ends shall be cut square and ends reamed to remove burrs. The pipe interior shall be cleaned of foreign matter before erection of the pipe.

- B. Annular space around piping through all walls shall be sealed off. Non-fire rated walls shall be sealed with pliable caulking or approved patching sealant. Fire rated wall penetrations shall be sealed per 23 0004 Fire Stoping for HVAC Systems.
- C. Mechanically formed tee fittings and couplings of the T-Drill type on copper tubing shall be formed in a continuous operation using equipment specifically designed for the application in strict adherence to the manufacturer's instructions. Cutting debris shall be removed from the piping completion. Joints shall be brazed.
- D. Piping shall be pitched for drainage. The low points shall be fitted with a 3/4" drain valve (with hose thread adapter if not piped to a floor drain) except that on piping 1-1/4" and smaller where a drain valve is not shown, a drain plug is acceptable. Hose thread adapters on drain valves of potable water piping shall be fitted with a non-removable vacuum breaker.
- E. Piping shall be installed consistent with good piping practice and run concealed wherever possible. Coordinate with other trades to attain a workmanlike installation.
- F. Piping shall be supported as specified in Section 230529 Pipe Hangers. Pipe alignment in both the horizontal and vertical must be tightly maintained. Misalignment must be corrected to the satisfaction of the Engineer before insulation is applied and the system accepted.
- G. Internals of sweat end valves shall be removed when damage or warping could occur due to applied heat of soldering. Where silver brazing is specified, solder connection of valves shall be used to reduce the danger of damage.
- H. Piping within 2 ft. of the coil connections to small heating and/or cooling units, reheat box coils and duct coils may be Type "L" soft copper to facilitate connection in a confined space. Joints shall be brazed or soldered consistent with the piping system or flared-tubing fittings may be used where appropriate
- I. Close open ends of piping during installation to keep interior of the pipe clean.
- J. Piping shall <u>not</u> be run above electrical switchgear or panelboards, nor above the access space in the immediate vicinity of the equipment, in accordance with N.E.C. Article 384.
- K. Automatic control valves shall be furnished by the Controls sub-contractor for installation by the HVAC piping contractor. Flare fittings for flare end valves shall be provided by the HVAC piping contractor.
- L. Drawings (plans, schematics and diagrams) indicate the general location and arrangement of piping systems. Locations and arrangements of piping take into consideration pipe sizing and friction loss, pipe expansion, pump sizing and other design considerations; therefore, it is imperative that piping be installed as indicated.
- M. Air vents shall be installed at high points of piping and system, on each heating coil and cooling coil and at other locations subject to air binding. Air vents shall be installed in locations accessible for servicing. A shutoff valve or cock on the inlet and drain tubing extending to a drain is required for each large capacity automatic vent. The drain tube shall be extended to a

DARKE COUNTY

WAGNER AVENUE INTERIOR RENOVATION2025

drain location (floor drain, janitor sink, etc.) or, in mechanical rooms, turned down over a clear area of the floor to afford notice by maintenance personnel.

- N. Install strainers as indicated on the drawings. Provide a nipple and ball valve in the blow down connection of each strainer 2" and larger.
- O. Piping shall be cleaned per specification 23 2500 HVAC Water Treatment.
- P. Exposed pipe insulation shall be painted to match base material colors.

3.2 UNIONS AND FLANGES

A. Unions and flanges shall be installed at pipe connections to fixtures and equipment and as required for erection purposed. A union shall be installed at each threaded shut-off valve on the side of the valve for which shutoff service is intended.

3.3 TESTING

- A. Piping shall be air tested at 50% higher than maximum system operating pressure for eight (8) hours before flushing.
 - 1. Contractor shall provide all necessary valves to allow for testing of new piping systems that are connected to existing systems such that only the new work is tested.

END OF SECTION 23 2113

SECTION 23 3113 - DUCTWORK

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

- 1. Duct materials.
- 2. Rectangular ductwork.
- 3. Round ductwork.
- 4. Duct connectors.
- 5. Sealants and gaskets.
- 6. Hangers and supports.

B. Related Sections:

- 1. Division 23 Section "Testing, Adjusting, and Balancing" for testing, adjusting, and balancing requirements for metal ducts.
- 2. Division 23 Section "Air Duct Accessories" for dampers, sound-control devices, duct-mounting access doors and panels, turning vanes, and flexible ducts.

1.2 PERFORMANCE REQUIREMENTS

- A. Delegated Duct Design: Duct construction, including sheet metal thicknesses, seam and joint construction, reinforcements, and hangers and supports, shall comply with SMACNA's "HVAC Duct Construction Standards Metal and Flexible" and performance requirements and design criteria indicated in "Duct Schedule" Article.
- B. Structural Performance: Duct hangers and supports shall withstand the effects of gravity loads and stresses within limits and under conditions described in SMACNA's "HVAC Duct Construction Standards Metal and Flexible".
- C. Airstream Surfaces: Surfaces in contact with the airstream shall comply with requirements in ASHRAE 62.1.

1.3 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings:
 - 1. Fabrication, assembly, and installation techniques.
 - 2. Factory- and shop-fabricated ducts and fittings.
 - 3. Reinforcement and spacing.
 - 4. Seam and joint construction.
 - 5. Duct Connectors

WAGNER AVENUE INTERIOR RENOVATION 2025

- 6. Duct Sealants and Gaskets
- 7. Hangers and supports, including methods for duct and building attachment and vibration isolation.

1.4 QUALITY ASSURANCE

- A. ASHRAE Compliance: Applicable requirements in ASHRAE 62.1, Section 5 "Systems and Equipment" and Section 7 "Construction and System Start-Up."
- B. ASHRAE/IESNA Compliance: Applicable requirements in ASHRAE/IESNA 90.1, Section 6.4.4 "HVAC System Construction and Insulation."

PART 2 - PRODUCTS

2.1 DUCT MATERIALS

A. Refer to 'Ductwork Systems Schedule' on drawings.

2.2 RECTANGULAR DUCTWORK

- A. Construction
 - 1. Single wall factory- or shop-formed continuous helical (spiral) lock seam.
- B. Fittings/Transitions Shall conform to SMACNA Figure 2-7.
 - 1. Transition angles shall be limited to 30 degrees on converging transitions and 20 degrees on diverging transitions.
 - 2. Elbows shall have an inside radius equal to the duct width. 90 degree elbows shall be square with double wall turning vanes. Elbows less than 90 degrees shall be radiused. Non-radiused elbows less than 90 degrees, with or without turning vanes are not permitted.
 - 3. Branch take-offs, where not detailed otherwise, shall be with a static boot (45 degree clinch collar) per SMACNA Figure 2-6 or conical spin-in fitting. Straight tap take-offs are not permitted.
 - 4. Square throat, radius heel 90-degree elbows are not permitted.
 - 5. Radiused, Angled (15° Max.), or Mitered (15° Max.) offsets.
 - 6. Concentric Transitions, $\theta = 45^{\circ}$ Max.
 - 7. Eccentric Transitions, $\theta = 30^{\circ}$ Max.

2.3 SINGLE WALL ROUND AND FLAT OVAL DUCTWORK

- A. Low pressure applications (1" S.P. or less).
 - 1. Construction
 - a. Single wall factory- or shop-formed continuous helical (spiral) lockseam.
 - 2. Joints/Seams
 - a. Slip connections or gasketed flanges.

WAGNER AVENUE INTERIOR RENOVATION 2025

- b. Round Ductwork: Longitudinal seams may be utilized for 1" and less (positive and negative) static pressure construction class at final air devices.
- 3. Fittings/Transitions Shall be compatible with duct system.
 - a. Factory- or shop-formed and welded.
 - b. Elbows shall be long radius type.
 - c. Elbows for longitudinal seam round ductwork shall be factory- or shop-formed segmented standing seam or pleated. Other fittings shall be comparable to the elbows.
 - d. Round Ductwork Additional Provisions:
 - 1) Standard tees allowed.
 - 2) Segmented elbows allowed.

2.4 DUCT CONNECTORS

- A. Rectangular Duct Connectors
 - 1. Shall be equal to Ductmate Industries "25 and "35" may be used on rectangular ductwork except where welding or brazing is specifically required. Adhere strictly to manufacturers instructions.
- B. Round duct branch connection to rectangular sheet metal duct
 - 1. Shall be equal to Flexmaster Series FL, straight side with or without manual damper, as described on the drawings. Connectors installed on interior lined rectangular duct shall have an integral insulation guard sleeve.
- C. Rectangular tap-to-round branch connection with static boot configuration
 - 1. Shall be equal to Flexmaster USA Type STO. Buckley "Air-Tite" Bellmouth BM and BM-D fittings with neoprene gasket and adhesive facing may be used for duct taps to rectangular sheet metal duct which is not internally lined.

2.5 SEALANT AND GASKETS

- A. Duct sealant materials shall be:
 - 1. Water based synthetic latex emulsion duct sealant equal to Ducmate PROSeal.
 - a. No V.O.C.'s
 - b. UL 181B-M Listed, UL 723 classified
 - c. For applications up to 15" w.g.
 - d. Gray Color
- B. Flange Gaskets: Butyl rubber, neoprene, or EPDM polymer with polyisobutylene plasticizer.

2.6 HANGERS AND SUPPORTS

A. Strap and Rod Sizes: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Table 4-1, "Rectangular Duct Hangers Minimum Size," and Table 4-2, "Minimum Hanger Sizes for Round Duct."

B. Hanger Rods

- 1. Noncorrosive Environments: Cadmium-plated steel rods and nuts.
- 2. Corrosive Environments: Electrogalvanized, all-thread rods or galvanized rods with threads painted with zinc-chromate primer after installation.

C. Steel Cables

- 1. Galvanized-Steel Ducts: Galvanized steel complying with ASTM A603.
- 2. Stainless-Steel Ducts: Stainless steel complying with ASTM A492.
- D. Steel Cable End Connections: Cadmium-plated steel assemblies with brackets, swivel, and bolts designed for duct hanger service; with an automatic-locking and clamping device.
- E. Duct Attachments: Sheet metal screws, blind rivets, or self-tapping metal screws; compatible with duct materials.

F. Trapeze and Riser Supports:

- 1. Supports for Galvanized-Steel Ducts: Galvanized-steel shapes and plates.
- 2. Supports for Stainless-Steel Ducts: Stainless-steel shapes and plates.
- 3. Supports for Aluminum Ducts: Aluminum or galvanized steel coated with zinc chromate.

PART 3 - EXECUTION

3.1 INSTALLATION

A. General

- 1. Drawing plans, schematics, and diagrams indicate general location and arrangement of duct system. Indicated duct locations, configurations, and arrangements were used to size ducts and calculate friction loss for air-handling equipment sizing and for other design considerations. Install duct systems as indicated unless deviations to layout are approved on Shop Drawings and Coordination Drawings.
- 2. Install ducts according to SMACNA's "HVAC Duct Construction Standards Metal and Flexible" unless otherwise indicated.

B. Ductwork Coordination

 General Coordination – Coordinate duct layout carefully with other trades to avoid conflict with structural elements, lighting and plumbing- heating piping. Flattening of ductwork and offsets to fit ductwork in available space is generally shown. In the absence of such, the Contractor shall arrange the ductwork to maintain concealment and allow ceilings and lights to be installed as intended. Do not hang ductwork until possible interferences with electrical and mechanical trades have been resolved. Having ductwork

DARKE COUNTY WAGNER AVENUE INTERIOR RENOVATION 2025

fabricated and delivered in advance shall not be justification for interference with other trades.

C. Joints & Seals

- 1. Transverse joints and longitudinal seams shall be assembled with sealant to conform to SMACNA Class B seal. Selection of sealant materials shall be compatible with the application. Sealants shall be applied in accordance with the manufacturer's recommendations.
- 2. Exterior ductwork shall be sealed with mineral impregnated fiber tape. Ductwork shall be supported as noted or detailed on the drawings.
- 3. System Pressure Testing Ductwork systems operating at 3" S.P. or greater (positive or negative) and all exterior ductwork shall require duct pressure testing.
- D. Hangers, Straps & Supports Attachment of hangers, straps, and supports to the structure shall be as follows:
 - 1. Steel Construction Utilize beam clamps in steel beam construction. For steel joists, provide clamps or threaded rod, nuts and washers through the bottom chord. Provide anchoring where clamps are attached to sloping surfaces of beam flanges and where otherwise required to insure permanent attachment.
 - 2. Unistrut Channel Unistrut type channel support systems may be utilized. Channels should be attached to the structure with inserts or clamps. Utilize threaded rod and appropriate attachments with channels as required.
 - 3. Refer to Drawings for additional notes on supports and hangers.

E. Duct Routing and Penetrations

- 1. General Coordination Coordinate openings required for the passage of ductwork through walls, partitions, floors and roofs with the General Contractor.
- 2. Electrical Coordination Route ducts to avoid passing through transformer vaults and electrical equipment rooms and enclosures. Ductwork shall not be run above electrical switchgear or panelboards, nor above the access space in the immediate vicinity of the equipment in accordance with NEC.

3. Wall Penetrations

- a. Non-Fire-Rated Penetrations Where ducts pass through non-fire-rated interior partitions and exterior walls and are exposed to view, cover the opening between the partition and duct or duct insulation with sheet metal flanges of same metal thickness as the duct. Overlap openings on four sides by at least 1-1/2 inches.
- b. Fire-Rated Penetrations Where ducts pass through fire-rated interior partitions and exterior walls, install fire dampers where required or fire seal perimeter of duct when no damper is required. Comply with requirements in Division 23 Section "Air Duct Accessories" for fire and smoke dampers.

F. Painting

1. Where interior duct surfaces are visible through grilles, registers and diffusers, the inside of the duct shall be coated with flat black paint before the device is installed, to eliminate obtrusive appearances.

END OF SECTION 23 3113

DARKE COUNTY WAGNER AVENUE INTERIOR RENOVATION 2025

SECTION 23 3300 - AIR DUCT ACCESSORIES

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

- 1. Air Control Dampers & Accessories
 - a. Manual balancing dampers.
- 2. Flexible ducts.
- 3. Air blenders.
- 4. Sound attenuators:
 - Return Air Canopy

B. Related Sections:

- 1. Division 23 Section "Identification for HVAC Piping and Equipment" for valve tags and schedules.
- 2. Division 23 Section "Ductwork" for ductwork materials, requirements, and schedules.

1.2 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: For duct accessories. Include plans, elevations, sections, details, and attachments to other work.
 - 1. Detail duct accessories fabrication and installation in ducts and other construction. Include dimensions, weights, loads, and required clearances, and method of field assembly into duct systems and other construction. Include the following:
 - Special fittings.
 - b. Manual volume damper installations.
 - c. Fire-damper and smoke-damper installations, including sleeves; and duct-mounted access doors
 - d. Wiring Diagrams: For power, signal, and control wiring.
- C. Operation and maintenance data.

1.3 QUALITY ASSURANCE

- A. Comply with NFPA 90A, "Installation of Air Conditioning and Ventilating Systems," and with NFPA 90B, "Installation of Warm Air Heating and Air Conditioning Systems."
- B. Comply with AMCA 500-D testing for damper rating.

PART 2 - PRODUCTS

2.1 AIR CONTROL DAMPERS & ACCESSORIES

A. MANUAL BALANCING DAMPERS & ACCESSORIES

- 1. Steel Round Dampers
 - a. Construction
 - 1) General Single blade design.
 - 2) Frame 20-ga. galvanized steel.
 - 3) Blades 20-ga. galvanized steel.
 - 4) Control Shaft Square axle shaft.
 - 5) Max Velocity 1500 fpm.
 - b. Manufacturers
 - 1) Ruskin #MDRS25 or approved equal by
 - 2) Greenheck
 - 3) Nailor
 - 4) Pottorff

2. Damper Adjustment Handle

- a. Construction
 - 1) General Locking quadrant positioner with handle
 - 2) Handle Heavy gage steel handle to accept square rod.
- b. Schedule
 - 1) Uninsulated ductwork Ventfabrics "Ventlock" #641
 - 2) Externally insulated ductwork Ventfabrics #644
- c. Manufacturers
 - a) Ventfabrics
 - b) Duro Dyne
 - c) DynAir

2.2 FLEXIBLE DUCTS

- A. Flexible insulated duct shall be constructed of galvanized steel spiral wire mechanically locked to an airtight aluminum or polyester inner core, 1" thick 3/4 lb. density fibrous glass insulation and a polyethylene or reinforced metalized vapor barrier outer jacket equal to Flexmaster Type 5 or 5M. Duct shall be rated at a minimum of 6" positive and 4" negative static pressure and shall be listed as Class 1 Air Duct or Air Duct Connector with 25-50 flame-smoke ratings per UL 181 and comply with NFPA 90A.
- B. Non-insulated flexible duct equal to Flexmaster NI-85 may be used on duct systems not specified to be insulated, with similar restriction stated above.

WAGNER AVENUE INTERIOR RENOVATION 2025

C. Flexible duct shall be used at final connections to air control terminal units and ceiling air diffusers except as limited in Part 3.

2.3 SOUND ATTENUATORS

A. Return Air Canopy

- Performance ASHRAE, SMACNA pressure and velocity classifications and ASTM E477, ASTM E84 25/50 Flame/Smoke Spread
- 2. Construction 20-gauge solid steel casing, absorptive acoustic fiberglass acoustic media. Fiberglass to be shot-free inorganic glass fiber with long, resilient fibers, bonded with thermosetting resin.
- 3. Manufacturer:
 - a. Price Industries
 - b. Titus
 - c. Tuttle & Bailey

PART 3 - EXECUTION

3.1 INSTALLATION

A. GENERAL

- 1. Install duct accessories according to applicable details in SMACNA's "HVAC Duct Construction Standards Metal and Flexible" for metal ducts and in NAIMA AH116, "Fibrous Glass Duct Construction Standards," for fibrous-glass ducts.
- 2. Materials Install duct accessories of materials suited to duct materials use:
 - a. Galvanized-steel accessories in galvanized-steel and fibrous-glass ducts,
 - b. Stainless-steel accessories in stainless-steel ducts,
 - c. Aluminum accessories in aluminum ducts,
 - d. Or as noted above.

B. VOLUME DAMPERS

1. Locations:

- a. Install volume dampers at points on supply, return, and exhaust systems where branches extend from larger ducts.
- b. Install volume damper upstream/downstream of each supply, return or exhaust air device, register or grille.
- c. Volume dampers shall be in accessible locations for testing, balancing, and adjusting purposes. Coordinate with reflected ceiling plans.
- 2. Lined Ductwork Where dampers are installed in ducts having duct liner, install dampers with hat channels of same depth as liner, and terminate liner with nosing at hat channel.
- 3. Install steel volume dampers in steel ducts.
- 4. Install aluminum volume dampers in aluminum ducts.
- 5. Set dampers to fully open position before testing, adjusting, and balancing.

C. PRESSURE DIFFERENTIAL GAUGES

DARKE COUNTY

WAGNER AVENUE INTERIOR RENOVATION 2025

1. Install air filter pressure differential gauges in a readable location on or near the air handling unit, filter housing or as otherwise indicated on the drawings.

D. FLEXIBLE DUCTS

- 1. Connect flexible ducts to metal ducts with Panduit straps or stainless-steel clamps. End of the insulation and jacket shall be sealed to the metal duct with double wrapped duct tape. Maximum length of flexible duct shall be:
 - a. Terminal units to supply ducts -3 ft.
 - b. Air devices to ducts -7 ft.
- 2. Flexible duct installation locations:
 - a. Shall be installed:
 - 1) At final air devices above accessible ceilings.
 - b. Shall *not* be installed:
 - 1) Where ductwork is exposed.
 - 2) Above inaccessible ceilings coordinate with reflected ceiling plan.
 - 3) Through any wall, ceiling, floor, or fire rated assembly.
 - 4) In the immediate vicinity of, and connecting to, air devices in fire rated ceilings where the assembly details require steel ductwork.

E. SOUND ATTENUATORS

1. Return Air Canopy – Install above return air device per manufacturer's recommendations in lieu of shop-fabricated plenum per detail.

END OF SECTION 23 3300

SECTION 23 3600 - AIR TERMINAL UNITS

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes the following:
 - 1. Single-duct air terminal units

1.2 SUBMITTALS

- A. Product Data: For each type of product indicated, include rated capacities, furnished specialties, sound-power ratings, and accessories.
- B. Operation and maintenance data.

1.3 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- B. ASHRAE Compliance: Applicable requirements in ASHRAE 62.1-2004, Section 5 "Systems and Equipment" and Section 7 "Construction and Startup."
- C. NFPA Compliance: Install air terminal units according to NFPA 90A, "Standard for the Installation of Air Conditioning and Ventilating Systems."
- D. Terminal units shall be certified to comply with ARI Standard 880.

PART 2 - PRODUCTS

2.1 GENERAL

- A. Unit sizes (inlet duct dimension) shall conform to those listed on the drawings except where larger size is required (or smaller size is acceptable) to meet noise or operational requirements. Resultant noise level from the control unit, ductwork and diffusers, as a system, shall not exceed a room NC level of 25 from both airborne and radiated noise, based on a 10 db room absorption coefficient, with 1.5" s.p. differential across the unit at maximum cfm setting. Sound performance shall be ARI certified.
- B. Pressure drop thru the terminal unit and hot water coil shall not exceed the maximum drop listed on the drawings. The coil face area shall be upsized if necessary to meet this requirement. The terminal unit casing shall be correspondingly upsized or the larger coil furnished separately.

For a separately furnished coil and intervening duct transition, with internal insulation same as that in the terminal unit casing, shall be provided.

2.2 COMPONENTS AND ACCESSORIES

- A. Casing Construction Unit casing shall be 22-gauge minimum thickness, galvanized or galvannealed sheet metal with beaded round inlet duct connection. Provide galvannealed construction for use in exposed locations for field application of paint.
- B. Casing Liner Casing shall be lined internally with:
 - 1. Material Unit casing liner shall be of the following construction:
 - a. Standard Construction 1" thick, 4 p.c.f. dual density aluminum foil faced rigid fiberglass board.
 - b. Mylar, Tedlar or similar facing materials are not acceptable.
 - 2. Acoustical considerations must be fully addressed.
 - 3. Performance Minimum R-Value = 4.0.
 - 4. Sealing & Enclosure Edges, joints and other exposures shall be additionally coated with approved sealants and/or protected with metal edging.
 - 5. Compliance Insulation and facing lining shall meet:
 - a. UL 181 air erosion/ mold growth & humidity standards.
 - b. UL 723/NFPA 90A for 25/50 fire and smoke requirements.
 - c. ASTM C665 biological and fungi standards.

C. Hot Water Reheat Coil

- 1. Certifications Coil shall have ARI certified ratings and shall be hydrostatically tested at 200 psi.
- 2. Coil Construction Coil shall consist of copper tubes, aluminum fins and galvanized steel casing. Coils shall be provided with appropriate fins per inch to satisfy the required scheduled capacity per the contract drawings.
- 3. Air Vent Provide a manual air vent on the coil.
- 4. Hot water control valve shall be furnished by the Temperature Controls Contractor.
- D. Air Flow Control Damper or Valve Damper or valve shall have linear control characteristics and shall be 16-gauge galvanized steel or extruded aluminum with gasketing and self-lubricating bearings.
- E. Velocity Sensor Multi-point averaging type. The velocity sensor shall be mounted in the inlet air stream and shall amplify the air flow signal to provide accurate control at low, as well as high, inlet static pressure conditions. The required minimum static pressure of the volume regulator shall not exceed 0.25 in. w.g. for proper operation.
- F. Air Flow Taps Taps and differential pressure airflow device shall be provided to enable direct reading of total and static pressures. A conversion chart shall be attached to each unit to convert pressure readings to air flow quantities.
- G. Bottom Access Doors Units with a heating coil section shall be provided with an access door on the upstream side of the coil. Access doors shall be insulated type with edge seals and either snap or quarter-turn sash latches, screws will not be acceptable. Access doors shall be provided at the bottom of the unit unless otherwise noted.

- H. Air Leakage Casing leakage and damper leakage shall each not exceed 2% of maximum air flow cfm at 3.0" s.p. differential across the unit.
- I. Controls Enclosure Units installed in a return air plenum shall have a sheet metal housing to enclose non-plenum-rated control devices and wiring which are mounted on the exterior of the casing.

2.3 MANUFACTURERS

- A. Units shall be manufactured by:
 - 1. Price
 - 2. Titus
 - 3. Trane
 - 4. Tuttle & Bailey
 - 5. Enviro Tech

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Unit Supports Support the units from the building structure with steel shapes, solid steel hanger rods or sheet metal strap hangers. Units shall not be supported by the ceiling suspension system.
- B. Unit Access Coordination
 - 1. Coordinate unit locations with ceiling components, light fixtures, and other equipment, services, elements or obstructions to ensure adequate clearance for access and servicing.
 - 2. Provide ceiling access panels where the ceiling system does not afford ready access.
 - 3. Coordinate right/left hand connections prior to placing order. Units ordered with coil connections and/or control enclosure boxes on inaccessible sides shall be re-ordered, the mounting of units "up-side-down" is not acceptable.
- C. Hot Water Connections Connect supply and return piping to each hot water coil with shut-off valves, balancing valves, and unions. Provide a manual air vent at the coil. Automatic control valves shall be furnished by the Temperature Control Contractor and installed by the HVAC Contractor.
- D. Electrical Connections Coordinate power connections with the E.C. where required.

END OF SECTION 23 3600

This page left blank intentionally

SECTION 23 3713 - DIFFUSERS, REGISTERS, AND GRILLES

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

- 1. Grilles
- 2. Diffusers

B. Related Sections:

- 1. Division 08 Section "Louvers and Vents" for fixed and adjustable louvers and wall vents, whether or not they are connected to ducts.
- 2. Division 23 Section "Air Duct Accessories" for fire and smoke dampers and volume-control dampers not integral to diffusers, registers, grilles, and return air canopies.

1.2 SUBMITTALS

- A. Product Data: For each type of product indicated, include the following:
 - 1. Data Sheet: Indicate materials of construction, finish, and mounting details; and performance data including throw and drop, static pressure drop, and noise ratings.
 - 2. Diffuser, Register, and Grille Schedule: Indicate drawing designation, room location, quantity, model number, size, and accessories furnished.

PART 2 - PRODUCTS

2.1 GRILLES, REGISTERS AND DIFFUSERS

- A. Air outlet and inlet devices shall be equal to those specified by catalog number and description in the schedule on the drawings. Damper operators shall be concealed screw type. An auxiliary mounting frame shall be furnished with each grille and register except those mounted on exposed ducts or in lay-in application.
- B. Linear "T" bar air supply diffusers shall be slotted diffusers with fixed air pattern control complete with a galvanized sheet metal supply plenum having a round or oval duct connection and 1/2" neoprene coated fiberglass insulation on the interior. The unit shall be designed to mount on or alongside the ceiling "T" bar and shall include flanges on both sides of the diffuser to support the ceiling tiles. Additional "T" bars matching those of the ceiling system shall be provided by the HVAC Contractor if the diffuser does not have these flanges. Units shall have a center notch where required to accommodate intervening "T" bars.

C. Manufacturers:

- 1. Price
- 2. Titus
- 3. Tuttle & Bailey
- 4. Krueger

PART 3 - EXECUTION

3.1 INSTALLATION

- A. The Contractor shall be responsible for comparability of ceiling mounted devices with the ceilings and suspension systems (lay-in, concealed spline, plaster, drywall, etc.). Verify with architectural drawings.
- B. Carefully align square and rectangular devices with the vertical and horizontal building lines. Diffusers shall be attached rigidly to the ductwork. Where connected by flexible ducts, special supports shall be provided as required, either from the ceiling suspension system or by independent suspension wires or rods from the building structure.
- C. Inside of ducts behind grilles, registers, and diffusers shall be painted flat black, as needed, to eliminate the sight of shiny surfaces.
- D. Each ducted air device shall be provided with a balancing damper, located either at the run out duct to the final air device for accessible locations or an integral damper at the air device for inaccessible locations. Transfer air devices are not required to have balance dampers, unless noted. Duct mounted air devices shall be provided with standoff frame and integral balance damper or scoop style damper, as noted. Refer to drawings for other specific instances.

END OF SECTION 23 3713

DIVISION 26 ELECTRICAL

26 0000	General Requirements for Electrical Systems
26 0001	Basic Electrical Requirements
	1
26 0500	Common Work Results for Electrical
26 0519	Low-Voltage Electrical Power Conductors and Cables
26 0529	Hangers and Supports for Electrical Systems
26 0533	Raceway and Boxes for Electrical Systems
26 0537	J-Hook Pathways for Electrical Systems
26 0553	Identification for Electrical Systems
<u> 26 0900 </u>	Instrumentation and Control for Electrical
26 0923	Lighting Control Devices
26 2000	Low-Voltage Electrical Distribution
26 2416	Panelboards
26 2726	Wiring Devices
26 5000	Lighting
26.5112	The state of the s
26 5113	Interior Lighting Fixtures
26 7000	Voice and Data Communications
26 7561	Voice and Data Communications Horizontal Cabling
-0 / J O I	Toroc and Data Communications Horizontal Caoming

SECTION 26 0001 - BASIC ELECTRICAL REQUIREMENTS

PART 1 - GENERAL

1.1 SUMMARY

A. This Section Includes the following:

- 1. General Requirements
- 2. Definitions
- 3. Scope of Work
- 4. Drawings and Specifications
- 5. Reference Standards
- 6. Site Visit
- 7. Permits, Regulations and Inspections
- 8. Temporary Electric Services
- 9. Workmanship
- 10. Protection
- 11. Painting
- 12. Cleaning
- 13. Equipment Selection
- 14. Shop Drawings
- 15. Testing
- 16. Final Inspection and Punch List
- 17. Record Drawings
- 18. Warranties
- 19. Operation and Adjustment of Equipment
- 20. Operating Demonstration and Instruction

1.2 GENERAL REQUIREMENTS

- A. All provisions of Division 00 Front End Documents and Division 01 General Requirements apply to work specified in this Division.
- B. Specification provisions of other relevant Divisions shall apply where applicable work is required to be performed under this Electrical work.
- C. A complete and functional Electrical system installation shall be provided under this Division. Should overlap of work among the trades become evident, this shall be called to the attention of the Architect. In such event, none of the trades or their suppliers shall assume that he is relieved of the work which is specified under his branch until instructions in writing are received from the Architect.
- D. The Mechanical and Electrical drawings and specifications assign work (labor and/or materials to be provided by the General, Plumbing, Fire Suppression, HVAC or Electrical Contractor or their sub-contractors. Understanding that the contractors for mechanical and electrical work are sub-contractors to the (General) Contractor, such assignments are not intended to restrict the

Contractor in assignment of work among the sub-contractor to accommodate trade agreements and practices or the normal conduct of the construction work.

1.3 DEFINITIONS

- A. Finished Spaces: Spaces other than mechanical and electrical equipment rooms, furred spaces, pipe and duct chases, unheated spaces immediately below roof, spaces above ceilings, unexcavated spaces, crawlspaces, and tunnels.
- B. Exposed, Interior Installations: Exposed to view indoors. Examples include finished occupied spaces and mechanical equipment rooms.
- C. Exposed, Exterior Installations: Exposed to view outdoors or subject to outdoor ambient temperatures and weather conditions. Examples include rooftop locations.
- D. Concealed, Interior Installations: Concealed from view and protected from physical contact by building occupants. Examples include above ceilings and chases.
- E. Concealed, Exterior Installations: Concealed from view and protected from weather conditions and physical contact by building occupants but subject to outdoor ambient temperatures. Examples include installations within unheated shelters.

1.4 SCOPE OF WORK

A. The scope of the electrical work includes furnishing, installing, testing and warranty of all electrical work and complete electrical systems shown on the electrical drawings and specified herein, including Division 00, Division 01, Division 26 and applicable provisions of other relevant Divisions.

1.5 DRAWINGS AND SPECIFICATIONS

- A. The drawings indicate the general arrangement of the work and are to be followed insofar as possible. The word "provide", as used shall mean "furnish and install". If significant deviations from the layout are necessitated by field conditions, detailed layouts of the proposed departures shall be submitted to the Architect for approval before proceeding with the work.
- B. Make all necessary field measurements to insure correct fitting. Coordinate work with all other trades in such a manner as to cause a minimum of conflict or delay.
- C. The drawings and specifications shall be carefully studied during the course of bidding and construction. Any errors, omissions or discrepancies encountered shall be referred immediately to the Architect for interpretation or correction, so that misunderstandings at a later date may be avoided. The contract drawings are not intended to show every vertical or horizontal offset which may be necessary to complete the systems. Having equipment, wireways and fittings fabricated and delivered in advance of making actual measurements shall not be sufficient cause to avoid making offsets and minor changes as may be necessary to install wireways, fittings and equipment.

- D. The Architect shall reserve the right to make minor adjustment in locations of system runs and components where he considers such adjustments desirable in the interest of concealing work or presenting a better appearance where exposed. Any such changes shall be anticipated and requested sufficiently in advance so as to not cause extra work, or unduly delay the work. Coordinate work in advance with all other trades and report immediately any difficulties which can be anticipated.
- E. Equipment, ductwork and piping shall not be installed in the dedicated electrical space above or in the working space required around electrical switchgear, motor control centers or panelboards as identified by NEC 110.26 Spaces About Electrical Equipment 600 Volts Nominal or Less.For Equipment rated over 600 volts nominal 110.32 Work Space About Equipment 110.33 Entrance and Access to Work Space 110.34 Work Space and Grounding. The Electrical Contractor shall caution other trades to comply with this stipulation.
- F. Where any system runs and components are so placed as to cause or contribute to a conflict, it shall be readjusted at the expense of the Contractor causing such conflict. The Architect's decision shall be final in regard to arrangement of equipment, conduit(s), devices, wireways etc., where conflict arises.
- G. Provide offsets in system runs, additional fittings, necessary conduit, pull boxes, conductors, switches and devices required to complete the installation, or for the proper operation of the system. Each contractor shall exercise due and particular caution to determine that all parts of the work are made quickly and easily accessible.
- H. Should overlap of work among the trades become evident, this shall be called to the attention of the Architect. In such event, none of the trades or their suppliers shall assume that he is relieved from the work which is specified under his branch until instructions in writing are received from the Architect.

1.6 REFERENCE STANDARDS

A. Where standards (NFPA, NEC, ASTM, UL, etc.) are referenced in the specifications or on the drawings, the latest edition is to be used except, however, where the authority having jurisdiction has not yet adopted the latest edition, the edition so recognized shall be used.

1.7 SITE VISIT

- A. Refer to Section 017300 Execution.
- B. Each bidder shall visit the project site to understand the existing conditions and compare the conditions with information shown on the drawings. Report immediately to the Architect any issues or discrepancies which are discovered that affect the bid. Changes to contract price will not be considered for site condition issues that are readily apparent from a thorough site review.

1.8 PERMITS, REGULATIONS AND INSPECTION

- A. Work must conform to applicable local, state and federal laws, ordinances and regulations. Where drawings or specifications exceed code requirements, the drawing and specifications shall govern. Install no work contrary to minimum legal standards.
- B. Except where the permit application is made by the Architect or the Engineer, the Electrical contractor shall be responsible to file for and obtain all required permits from the governing inspection agencies for the Electrical work. Where the Architect or Engineer is the Architect or Engineer of record, they will furnish sealed and signed drawings and specifications required by the permit authorities except fire alarm permit documents shall be prepared and submitted by an approved, licensed fire alarm subcontractor.
- C. Include payment of all permit and inspection fees applicable to the work in this Division.
- D. All work shall be subject to inspection and approval of Federal, State and local agencies as may be appropriate as well as the Architect and Engineer.
- E. Furnish for the Owner certificates of approval from the governing inspection agencies as a condition for final payment.

1.9 TEMPORARY ELECTRIC SERVICES

- A. Refer to Section 015000 Temporary Facilities and Controls for division of responsibilities for temporary utilities.
- B. The temporary service and temporary lighting for construction is provided by the Electrical Contractor.
- C. Lighting fixtures shall be placed every 40 ft. along each corridor or where corridors do not occur, along the long axis of all rooms. Provide a minimum 800 lumen lamp in a commercial grade molded plastic socket and lattice wire guard temporary lighting assembly with extra heavy duty "ST" 3-wire cord. Lamps shall be spaced a minimum of 10 ft. apart.
- D. Contractors requiring extension cords shall provide their own cords and plugs up to capacity of 20 amperes. For services to larger items of equipment and welders, this Contractor shall extend proper feeders as requested at the expense of the Contractors requiring the service.
- E. The Electrical Contractor shall maintain the temporary light and power system for the duration of the work and shall remove it from the site when directed. Temporary wiring and equipment shall remain the property of the Electrical Contractor.
- F. The use of the permanent electrical system for temporary services shall be allowed.
- G. The complete temporary service shall comply with OSHA, and all Code requirements.

1.10 WORKMANSHIP

- A. Materials and equipment shall be installed and supported in a first-class and workmanlike manner by mechanics skilled in their particular trades. Workmanship shall be first-class in all respects, and the Architect shall have the right to stop the work if highest quality workmanship is not maintained.
- B. Electrical work shall be performed by a licensed Electrical Contractor in accordance with requirements of the jurisdiction.

1.11 PROTECTION

- A. Each Contractor shall be entirely responsible for all material and equipment furnished in connection with his work. Special care shall be taken to properly protect all parts thereof from theft, damage or deterioration during the entire construction period in such a manner as may be necessary, or as directed by the Architect.
- B. The Owner's property and the property of other contractors shall be scrupulously respected at all times. Provide plastic sheeting, drop cloths or similar barriers where dust and debris is generated, to protect adjacent areas.
- C. Contractor shall protect all equipment and materials from detrimental effects of weather or construction activity. All items shall be stored and secured in a protected location away from the daily work area. Equipment or materials shall be placed on raised skids to protect from surface moisture. Where appropriate, provide plastic sheeting or similar vapor barrier underneath the stored products to reduce the effects of ground moisture or curing concrete on the local humidity levels. Where unfinished ferrous products or finished ferrous products with raw edges are stored, provide local, dry heat to maintain ambient relative humidity levels below 65% RH to prevent rust.
- D. All equipment shall retain the original packaging until required to be removed for installation or operation. Open ends of ducts, piping, conduit, etc. shall be capped or sealed and ventilation openings into equipment shall be wrapped and sealed in plastic sheeting to prevent dust or dirt entry both when stored and after installation but still open to the effects of construction activity. Stored items as well as installed equipment shall be covered with plastic sheeting at all times until placed in service or until dust generating activity in the area has ceased.

1.12 PAINTING

- A. In addition to any painting specified for various individual items of equipment, the following painting shall be included in the Electrical Contract:
 - 1. All metal which is not factory or shop painted and which remains exposed to view in the building including finished areas, mechanical rooms, storage rooms and other unfinished areas shall be given a prime coat of paint.
 - 2. All metal installed outside the building which is not factory or shop painted shall be given a prime coat of paint.
 - 3. Equipment and materials which have been factory or shop coated (prime or finished painted or galvanized), on which the finish has been damaged or has deteriorated,

- shall be cleaned and refinished equal to its original condition. The entire surface shall be repainted if a uniform appearance cannot be accomplished by touch-up.
- 4. Apply Z.R.C. Cold Galvanizing Compound, or approved equal, for touch-up of previously galvanized surfaces.
- 5. Paint, surface preparation and application shall conform to applicable portions of the Painting section of Division 09 Finishes. All rust must be removed before application of paint.
- B. Finish painting is included in the General Contract. Refer to the Cutting and Patching paragraph in this Section for finishing requirements.

1.13 CLEANING

- A. Debris, dust, dirt, etc shall be removed daily, particular attention shall be paid to areas that the Owner is continuing to occupy or use; any mess created in corridors, stairwells and egress paths that are maintained during construction shall be cleaned immediately.
- B. The Owners dumpsters and trash receptacles shall not be used. If a dumpster is required, it shall be provided by the contractor and located where approved by the Owner. Coordinate dumpster requirements with other contractors.
- C. Before turning an area back over to the Owner, thoroughly clean the space to leave the area in a similar condition before the start of the project where finishes are to remain.
- D. Before placing each system in operation, the equipment shall be thoroughly cleaned; cleaning shall be in accordance with equipment manufacturer's recommendations.
- E. Refer to appropriate Sections for cleaning of other equipment and systems for normal operation.

1.14 EQUIPMENT SELECTION

- A. Materials and equipment furnished under this contract shall be in strict accordance with the specifications and drawings and shall be new and of best grade and quality. When two or more articles of the same material or equipment are required, they shall be of the same manufacturer.
- B. All electrical equipment and wiring shall bear the Underwriters Laboratories, Inc. label where UL label items are available, and shall comply with NEC (NFPA-70) and NFPA requirements.
- C. The selection of materials and equipment to be furnished under this contract shall be governed by the following:
 - 1. Where trade names, brands, or manufacturers of equipment or materials are listed in the specification, the exact equipment listed shall be furnished. Where more than one name is used, the Contractor shall have the option of selecting between any one of the several specified. All products shall be first quality line of manufacturers listed.
 - 2. Where the words "or approved equal" appear after a manufacturer's name, specific written approval must be obtained from the Engineer during the bidding period in

- sufficient time to be included in an addendum. The same shall apply for equipment and materials not named in the specifications, where approval is sought.
- 3. Where the words "equal to" appear, followed by a manufacturer's name and sometimes a model or series designation, such designation is intended to establish quality level and standard features. Equal equipment by other manufacturers will be acceptable, subject to the Engineer's approval during shop drawing submittal.
- D. Substitute equipment of equal quality and capacity will be considered when the listing of such is included as a separate item of the bid. State the deduction or addition in cost to that of the specified product.
- E. Before bidding equipment, and again in the preparation of shop drawings, the Contractor and his supplier shall verify that adequate space is available for entry and installation or the item of equipment, including associated accessories. Also verify that adequate space is available for servicing of the equipment and that required NEC (and other applicable Code's) clearances are met. The Contractor and his supplier shall also verify compatibility of equipment specified with available system/service voltages, etc.
- F. If extensive changes in conduit, equipment layout or electrical wiring and equipment are brought about by the use of equipment or existing site conditions which are not compatible with the layout shown on the drawings, necessary changes shall be deemed to be included in the contract.

1.15 SHOP DRAWINGS

- A. One set of shop drawings, in electronic format (pdf), with descriptive information shall be assembled by each Contractor of equipment and materials furnished in his contract, and submitted to the Architect and/or Engineer for review as stated in Division 01. These shall be submitted as soon as practicable and before special equipment is manufactured and before installation.
- B. Shop drawings for equipment fixtures, devices and materials shall be labeled and identified same as on the Contract Documents. Failure to do so may be cause for rejection of shop drawings.
- C. The review of shop drawings by the Architect or Engineer shall not relieve the Electrical Contractor from responsibility for errors in the shop drawings. Deviations from specifications and drawing requirements shall be called to the Engineer's attention in a separate clearly stated notification at the time of submittal for the Engineer's review.
- D. Shop drawings of the following electrical equipment and materials shall be submitted:
 - 1. Plenum cable.
 - 2. Wiring devices and coverplates.
 - 3. Panelboards.
 - 4. Fuses.
 - 5. Disconnects
 - 6. Lighting Controls including layout plans of Occupancy Sensors.
 - 7. Low voltage switching/lighting control system
 - 8. Lighting fixtures.

9. Fire alarm system with schematic and point to point wiring diagrams.

1.16 TESTING

- A. As each wiring system is completed, it shall be tested for continuity and freedom from grounds.
- B. As each electrically operated system is energized, it shall be tested for function.
- C. The Contractor shall perform megger and resistance tests and special tests on any circuits or equipment when an authorized inspection agency suspects the system's integrity or when requested by the Architect or Engineer.
- D. All signaling and communications systems shall be inspected and tested by a qualified representative of the manufacturer or equipment vendor. Submit four (4) copies of reports indicating results.
- E. Tests shall be witnessed by field representatives of the Architect or Engineer or shall be monitored by a recorder when appropriate. Furnish a written record of each system test indicating date, system, test conditions, duration and results of tests.
- F. Instruments required for tests shall be furnished by the Contractor.

1.17 FINAL INSPECTION AND PUNCH LIST

- A. As the time of work completion approached, the Contractor shall survey and inspect his work and develop his own punch list to confirm it is complete and finished. He shall then notify the Architect and request that a final inspection be made. It shall not be considered the Architect's or Engineer's obligation to perform a final inspection until the Contractor has inspected the work and so states at the time of the request for the final inspection.
- B. The Architect and/or Engineer will inspect the work and prepare a punch list of items requiring correction, completion or verification. Corrective action shall be taken by the Contractor to the satisfaction of Architect and Engineer within 30 days of receipt of the Architect/Engineer's punch list.

1.18 RECORD DRAWINGS

A. The Electrical Contractor shall maintain a separate set of prints of the contract documents and shall show all changes or variations, in a manner to be clearly discernible, which are made during construction. Upon completion of the work, these drawings shall be turned over to the Architect. This shall apply particularly to underground and concealed work, and to other systems where the installation varies to a degree which would justify recording the change.

1.19 WARRANTIES

- A. This Contractor shall warrant all workmanship, equipment and material entering into this contract for a period of one (1) year minimum from date of final acceptance or date of beneficial use, as agreed to between Contractor and Architect. Any materials or equipment proving to be defective during this warranty period shall be made good by this Contractor without expense to the Owner.
- B. This provision is intended specifically to cover deficiencies in contract completion or performance which are not immediately discovered after systems and placed in operation. These items include, but are not limited to, motor controller malfunction, heater element changes required for motor controller, fuse replacement where fuses blow due to abnormal shorts, adjustments and/or replacement of malfunctioning equipment and adjusting special equipment and communication systems to obtain optimum performance.
- C. This provision shall not be construed to include maintenance items such as making normally anticipated adjustments or correcting adjustment errors on the part of the Owner's personnel.
- D. Provisions of this warranty shall be considered supplementary to warranty provisions under General Conditions.
- E. Extended warranties shall be provided where indicated in the equipment specification Sections.

1.20 OPERATION AND ADJUSTMENT OF EQUIPMENT

- A. As each system is put into operation, all items of equipment included therein shall be adjusted to proper working order. This shall include balancing and adjusting voltages and currents and adjusting all operating equipment.
- B. Caution: Verify that all bearings of equipment furnished are lubricated, all motors are operating in the right direction, and correct overload heater elements are provided on all motors. Do not depend wholly on the other trades judgment in these matters. Follow specific instructions in regard to lubrication of equipment furnished under this Contract.

1.21 OPERATING DEMONSTRATION AND INSTRUCTIONS

A. The Contractor shall set the various systems into operation and demonstrate to the Owner and Architect that the systems function properly and that the requirements of the Contract are fulfilled.

PART 2 - EXECUTION - NOT APPLICABLE

END OF SECTION 26 0001

SECTION 26 0519 - LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes the following:
 - 1. Building wires and cables rated 600 VAC and less.
 - 2. Connectors, splices, and terminations rated 600 VAC and less.
 - 3. Photovoltaic wires and cables rated for 1500 VDC or less.

1.2 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Field quality-control test reports.

1.3 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- B. Comply with NFPA 70.

PART 2 - PRODUCTS

2.1 CONDUCTORS AND CABLES

- A. Copper Conductors: Comply with NEMA WC 70.
- B. Conductor Insulation: Comply with NEMA WC 70 for Types THHN-THWN and XHHW.
- C. Multiconductor Cable: Comply with NEMA WC 70 for armored cable, Type AC and metal-clad cable, Type MC with ground wire.
- D. Photovoltaic Wiring: Comply with NEMA WC 70 for PV Wire.

2.2 CONNECTORS AND SPLICES

A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:

WAGNER AVENUE INTERIOR RENOVATION

- B. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. AFC Cable Systems, Inc.
 - 2. Hubbell Power Systems, Inc.
 - 3. O-Z/Gedney; EGS Electrical Group LLC.
 - 4. 3M; Electrical Products Division.
 - 5. Tyco Electronics Corp.
- C. Description: Factory-fabricated connectors and splices of size, ampacity rating, material, type, and class for application and service indicated.

PART 3 - EXECUTION

3.1 CONDUCTOR SIZE

A. Refer to schedule on drawings.

3.2 CONDUCTOR MATERIAL APPLICATIONS

- A. Feeders: Copper. Stranded for No. 8 AWG and larger.
- B. PV Strings: Copper. Stranded for No. 12 AWG and larger.

3.3 CONDUCTOR INSULATION AND MULTICONDUCTOR CABLE APPLICATIONS AND WIRING METHODS

- A. PV Strings: Type PV Wire with MC4 connectors.
- B. Exposed Feeders: Type THHN-THWN, single conductors in raceway.
- C. Feeders Concealed in Ceilings, Walls, Partitions, and Crawlspaces: Type THHN-THWN, single conductors in raceway.
- D. Class 1 Control Circuits: Type THHN-THWN, in raceway.
- E. Class 2 Control Circuits: Power-limited cable, in raceway.
- F. Use conductors such as type FEP with high temperature insulation as identified in the NEC for connections to resistance heating elements or in other areas subject to temperature exceeding the rating of THWN, XHHW or THHN.
- G. In addition to the conduit system, a separate grounding conductor shall be installed with all feeders and branch circuitry.
- H. Equipment grounding conductors shall be green, or completely taped green, at all accessible points.

I. Wire size ampacity shall equal or exceed its overload protective device. Where sizes shown on the drawings are greater than the apparent ampacity requirements, the size shown shall prevail to compensate for voltage drop. In no instance shall conductors be installed that are less than required by the N.E.C. Minimum conductor size shall be No. 12 AWG except No. 14 AWG may be used for control wiring or where otherwise specifically indicated.

3.4 INSTALLATION OF CONDUCTORS AND CABLES

- A. Conceal cables in finished walls, ceilings, and floors, unless otherwise indicated.
- B. Use manufacturer-approved pulling compound or lubricant where necessary; compound used must not deteriorate conductor or insulation. Do not exceed manufacturer's recommended maximum pulling tensions and sidewall pressure values.
- C. Conduit systems shall be clean and clear before pulling wires. Use pulling means, including fish tape, cable, rope, and basket-weave wire/cable grips, that will not damage cables or raceway. Pulling of branch circuit conductors shall be performed by manual means without the use of levers or heavy pulling devices that may compromise the conductor's or insulation integrity.
- D. A maximum of 8 conductors shall be installed in a branch circuit conduit unless specifically noted otherwise on the drawings. Equipment ground conductors are not counted when determining maximum fill.
- E. Install exposed cables parallel and perpendicular to surfaces of exposed structural members, and follow surface contours where possible.
- F. Wiring in vertical raceways shall be supported with strain relief devices; Kellems grips or approved equal.
- G. Support cables according to Division 26 Sections "Hangers and Supports for Electrical Systems."
- H. Identify and color-code conductors and cables according to Division 26 Section "Identification for Electrical Systems."
- I. Tighten electrical connectors and terminals according to manufacturer's published torquetightening values. If manufacturer's torque values are not indicated, use those specified in UL 486A and UL 486B.
- J. Make splices and taps that are compatible with conductor material and that possess equivalent or better mechanical strength and insulation ratings than unspliced conductors.
- K. Wiring at Outlets: Install conductor at each outlet, with at least 6 inches of slack. Refer to additional notes on plans for branch circuitry installation requirements.

3.5 TESTING

A. As each wiring system is completed, it shall be tested for continuity and freedom from grounds.

- B. As each electrically operated system is energized, it shall be tested for function.
- C. On all electric services including change-outs, backfeeds, etc. the Contractor shall verify phase rotation and voltage readings to assure the final installation is proper. Submit to the Engineer in writing a record of voltage readings and current readings taken at no-load and fully loaded conditions.
- D. The Contractor shall perform megger and resistance tests and special tests on any circuits or equipment when an authorized inspection agency suspects the system's integrity or when requested by the Engineer.
- E. Tests shall be witnessed by field representatives of the Engineer or shall be monitored by a recorder. Furnish a written record of each system test indicating date, system, test conditions, duration and results of tests. Copies of all test reports shall be included in the O&M manuals.
- F. Instruments required for tests shall be furnished by the Contractor.

END OF SECTION 26 0519

SECTION 26 0533 - RACEWAY AND BOXES FOR ELECTRICAL SYSTEMS

PART 1 - GENERAL

1.1 SUMMARY

A. This Section includes raceways, fittings, boxes, enclosures, and cabinets for electrical wiring.

1.2 SUBMITTALS

- A. Product Data: For surface raceways, wireways and fittings, floor boxes, hinged-cover enclosures, and cabinets.
- B. Shop Drawings: For custom enclosures and cabinets. Include plans, elevations, sections, details, and attachments to other work.

1.3 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- B. Comply with NFPA 70.

PART 2 - PRODUCTS

2.1 METAL CONDUIT AND TUBING

- A. Rigid Steel Conduit: ANSI C80.1.
- B. IMC: ANSI C80.6.
- C. EMT: ANSI C80.3.
- D. FMC: Zinc-coated steel.
- E. LFMC: Flexible steel conduit with PVC jacket.
- F. Fittings for Conduit (Including all Types and Flexible and Liquidtight), EMT, and Cable: NEMA FB 1; listed for type and size raceway with which used, and for application and environment in which installed.
 - 1. Conduit Fittings for Hazardous (Classified) Locations: Comply with UL 886.
 - 2. Fittings for EMT: Steel only; set-screw or compression type.

2.2 NONMETALLIC CONDUIT AND TUBING

- A. ENT: NEMA TC 13.
- B. RNC: NEMA TC 2, unless otherwise indicated.
- C. LFNC: UL 1660.
- D. Fittings for ENT and RNC: NEMA TC 3; match to conduit or tubing type and material.
- E. Fittings for LFNC: UL 514B.
- F. Trapeze hangers shall be supported by 3/8" (minimum) diameter rods.
- G. Provide means of bonding each joint for absolute grounding of the cable tray.

2.3 SURFACE RACEWAYS

- A. Surface Metal Raceways: Brushed Aluminum with snap-on covers.
 - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. Mono Systems.
 - b. Walker Systems, Inc.; Wiremold Company (The).
 - c. Hubbell Wiring Systems.

2.4 BOXES, ENCLOSURES, AND CABINETS

- A. Sheet Metal Outlet and Device Boxes: NEMA OS 1.
- B. Cast-Metal Outlet and Device Boxes: NEMA FB 1, aluminum, Type FD, with gasketed cover.
- C. Small Sheet Metal Pull and Junction Boxes: NEMA OS 1.
- D. Cast-Metal Access, Pull, and Junction Boxes: NEMA FB 1, cast aluminum with gasketed cover.
- E. Hinged-Cover Enclosures: NEMA 250, Type 1, with continuous-hinge cover with flush latch, unless otherwise indicated.
 - 1. Metal Enclosures: Steel, finished inside and out with manufacturer's standard enamel.

F. Cabinets:

- 1. NEMA 250, Type 1, galvanized-steel box with removable interior panel and removable front, finished inside and out with manufacturer's standard enamel.
- 2. Hinged door in front cover with flush latch and concealed hinge.
- 3. Key latch to match panelboards.

- 4. Metal barriers to separate wiring of different systems and voltage.
- 5. Accessory feet where required for freestanding equipment.

PART 3 - EXECUTION

3.1 RACEWAY APPLICATION

- A. Outdoors: Apply raceway products as specified below, unless otherwise indicated:
 - 1. Exposed Conduit: Rigid steel conduit.
 - 2. Boxes and Enclosures, Aboveground: NEMA 250, Type 3R.
- B. Comply with the following indoor applications, unless otherwise indicated:
 - 1. Exposed, Not Subject to Physical Damage: EMT.
 - 2. Exposed, Not Subject to Severe Physical Damage: EMT.
 - 3. Exposed and Subject to Severe Physical Damage: Rigid steel conduit. Includes raceways in the following locations:
 - a. Mechanical rooms.
 - 4. Concealed in Ceilings and Interior Walls and Partitions: EMT except FMC may be utilized in existing walls.
 - 5. Connection to Vibrating Equipment (Including Transformers and Hydraulic, Pneumatic, Electric Solenoid, or Motor-Driven Equipment): LFMC.
 - 6. Damp or Wet Locations: Rigid steel conduit.
 - 7. Raceways for Optical Fiber or Communications Cable: EMT.
 - 8. Boxes and Enclosures: NEMA 250, Type 1, except use NEMA 250, Type 4, stainless steel in damp or wet locations.
- C. Minimum Raceway Size: 3/4-inch trade size.
- D. Raceway Fittings: Compatible with raceways and suitable for use and location.
 - 1. Rigid and Intermediate Steel Conduit: Use threaded rigid steel conduit fittings, unless otherwise indicated.
 - 2. EMT: Use all steel, compression type or all steel setscrew type, concrete tight.
 - 3. Flexible conduit: Use malleable iron, "squeeze" type, non-insulated. (For lighting fixture whips only: Use all steel or die-cast screw-in connector).
 - 4. Liquid-tight conduit: steel or malleable iron.

3.2 INSTALLATION

A. Comply with NECA 1 for installation requirements applicable to products specified in Part 2 except where requirements on Drawings or in this Article are stricter. Generally run conduit and

conductors as high as practicable against underside of floor slab in concrete construction or immediately below the **top chord** of bar joist construction unless otherwise shown or noted. This high level zone shall be used for running electrical raceways and shall be grouped or racked together wherever feasible. Runs at bottom chord level or ceiling grid level are not acceptable.

- B. Keep raceways at least 6 inches away from parallel runs of flues and steam or hot-water pipes. Install horizontal raceway runs above water and steam piping.
- C. Complete raceway installation before starting conductor installation. Plan raceway routing to minimize the number of offsets and junction boxes.
- D. Support raceways as specified in Division 26 Section "Hangers and Supports for Electrical Systems."
- E. Install no more than the equivalent of three 90-degree bends in any conduit run except for communications conduits, for which fewer bends are allowed.
- F. Conceal conduit and EMT within finished walls, ceilings, and floors, unless otherwise indicated. All conduit shall parallel building lines.
- G. Conduit shall be run overhead and shall not be run below concrete slabs unless specifically indicated on the drawings and in the legend on the drawings.
- H. Conduit crossing building expansion joints shall have expansion provisions with grounding continuity, use special expansion fittings listed for the application. Refer to the Architectural and Structural floor plans and details for locations of expansion joints.
- I. Raceway Terminations at Locations Subject to Moisture or Vibration: Use insulating bushings to protect conductors, including conductors smaller than No. 4 AWG.
- J. Install pull wires in empty raceways. Use polypropylene or monofilament plastic line with not less than 200-lb tensile strength. Leave at least 12 inches of slack at each end of pull wire.
- K. Raceways for Data, Audio Visual and Communications Cable: Install as follows:
 - 1. 1-Inch Trade Size and Smaller: Install raceways in maximum lengths of 75 feet.
 - 2. Install with a maximum of two 90-degree bends or equivalent for each length of raceway unless Drawings show stricter requirements. Separate lengths with pull or junction boxes where necessary to comply with these requirements.
 - 3. Raceway shall be installed continuously from outlet box to above edge of nearest cable tray or J-Hook System above accessible ceiling.
 - 4. Bond raceway to adjacent cable tray with approved grounding bushing, bonding jumper and necessary fittings.
- L. Flexible Conduit Connections: Use maximum of 72 inches of flexible conduit for recessed and semirecessed lighting fixtures, equipment subject to vibration, noise transmission, or movement; and for transformers and motors.

- 1. Use LFMC in all locations except MC may be used for lighting fixture whips.
- M. Recessed Boxes in Masonry Walls: Saw-cut opening for box in center of cell of masonry block, and install box flush with surface of wall.
- N. Do not install wall-mounted boxes back-to-back in opposite sides of wall; in stud walls, boxes shall be on opposite side of studs.
- O. Provide access to all junction and pull boxes.
- P. Set metal floor boxes level and flush with finished floor surface. Provide trim ring compatible with finish floor system.
- Q. Pull mandrel or large swab thru conduit to assure freedom from debris before pulling wires. Use listed pulling lubricants where necessary.
- R. Provide four (4) 1 inch diameter spare conduits for each flush mounted branch circuit panelboard; extend from top of panelboard to above an accessible ceiling for future use.
- S. Contractor shall record carefully on a set of "as-built" prints, the exact location of all feeder conduits (100 amps and larger).
- T. Unless noted otherwise on the drawings, a maximum of 8 conductors shall be installed in a branch circuit conduit. This maximum is a count of all phase and neutral conductors only.

END OF SECTION 26 0533

SECTION 26 0537 – J-HOOK PATHWAYS FOR ELECTRICAL SYSTEMS

PART 1 - GENERAL

1.1 GENERAL

- A. Conduit/Raceway/Pathway: "Conduit", "raceway", "pathway" and similar terms shall be taken to mean "conduit" unless specifically indicated otherwise in project manual documents, or unless specifically directed otherwise in field by Owner or Design Professionals. All such terms shall be considered synonymous for the general purposes of installation means and methods.
- B. Provide J-Hook pathway systems only for the following limited applications: Class 2 ("low voltage") control wiring above accessible finished-ceiling systems.
- C. Coordination Drawing Submittals: Prior to commencing with any related work, submit routing plans, drawn to scale, on which the following items are shown and coordinated with each other, using input from installers of items involved:
 - 1. Routing.
 - 2. Scaled layout and relationships between components and adjacent structural, electrical, and mechanical elements.
 - 3. Vertical and horizontal offsets and transitions.
 - 4. Clearances for access above and to side of pathways.
 - 5. Vertical elevation of pathways above the floor or below bottom of ceiling structure.
 - 6. Structural members in paths of conduit groups with common supports.
 - 7. HVAC and plumbing items and architectural features in paths of conduit groups with common supports.

PART 2 - PRODUCTS

2.1 J-HOOK PATHWAYS

- A. Acceptable Manufacturers: Subject to being equivalent and subject to compliance with requirements, provide product by one of the manufacturers listed below, or equivalent NRTL listed and labeled equivalent.
 - 1. Cooper B-Line (basis of design, model numbers as specified further below).
 - 2. Mono-Systems, Inc.

B. Materials Description:

- 1. Provide J-Hook system components that are plenum-rated (regardless of whether air plenum ceilings exist on the project). Provide J-Hooks, not Cable Fasteners, and not Bridle Rings. Provide open-top hooks, so cables can be laid into J-Hooks rather than threaded through. Provide tool-less cable retainer clips (do not use cable ties). Provide hooks sized for maximum 40% fil (in cross section) based on outside diameter of cables. Accordingly, provide multiple sets of J-Hooks along any given pathway as applicable.
- 2. Provide necessary factory hooks, cable retainers, fasteners, attachment kits, etc. as required for complete installations.

2.2 MATERIALS AND FINISHES

- A. Provide steel units with rolled hook edges to prevent damage to cable jackets and insulation.
- B. Cable hooks for non-corrosive areas shall be pre-galvanized steel, ASTM A653. Where additional strength is required, cable hooks shall be spring steel with a zinc-plated finish, ASTM B633, SC3.
- C. Cable hooks for corrosive areas shall be stainless steel, AISI Type 304.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Provide J-Hook support along "free-air" cable pathway routes. Provide J-Hooks at four-foot intervals and at offsets. Route J-Hooks above ceilings through corridors and similar open areas wherever possible to minimize above-ceiling wall penetrations.
- B. Layout and install all electrical work in strict compliance with Chapter 1, Part B, Section 110.26 of the latest adopted edition of NFPA 70. Locations and routing that may be shown on plans are schematic and diagrammatic in nature. Layout all proposed pathway routing, elevations, installation methods, etc. on coordination drawings and coordinate all proposed routing with all affected trades prior to commencing with work. In addition, review the information with Owner and Design Professionals for all areas where pathways will be visible after completion of construction, to ensure a neatly organized installation occurs. Where exposed in finished areas, install in a manner that minimizes detrimental effects on room aesthetics. Install as out of site as reasonably possible.
- C. Keep pathways at least 24 inches away from parallel runs of flues and steam or hot-water pipes. Install horizontal runs above liquid and steam piping. Level and square runs, and install at proper elevations and heights. Do not begin installation of cables unit J-Hook pathway installations are complete and until installations locations (end to end) are in a weatherproof environment. Install pathways so that they are accessible for cable installation after construction is complete. Install pathways with enough workspace to permit access for installing cables. Strictly adhere to factory load capacities and fill capacity. Provide factory cable retainers, fasteners, attachment kits, and other accessories as required for a complete installation.
- D. Securely anchor (mechanical, not adhesive) J-Hooks directly to structural components of the building. Do not anchor J-Hooks to ductwork, conduit, piping, fixtures, equipment, ceiling supports (rods, wires, T-bars), etc. Comply with requirements in Section 260529 and related sections for hangers and supports. Support using factory-approved methods. Fasten cables on horizontal runs with factory cable clamps, retainers, fasteners, attachment kits or flexible Velcro-secured wraps compliant with to NEMA VE 2. Tighten clamps/wraps only enough to secure the cable, without indenting the cable jacket. Use of synthetic or plastic "tie-wraps", "zip ties", "wire ties" and similar products are not permitted as a permanent means of anchoring, securing, supporting or otherwise installing any cables, conductors, conduits, raceways, devices equipment or other electrical work. Do not use perforated strap.

- E. Coordinate work prior to rough-in with respective equipment and cable installers, and with Owner's Representative. Carefully coordinate proposed routing, including elevations, with affected installers and entities prior to rough-in. Neatly route paths parallel and perpendicular to building architectural lines, plumb on walls, and at a consistent elevation wherever possible. Install paths in a uniform plane/elevation wherever possible. Keep horizontal and vertical offsets to an absolute minimum. Route paths so that a minimum of 24 inches exists between cables and potential EMI sources such as lighting ballasts, motors, power wiring, dimmer circuits, etc.
- F. Provide a minimum of two (2) 4-inch bushed conduit sleeves where pathway is routed above inaccessible ceilings, and at penetrations of floors, masonry walls, fire rated walls, smoke-tight partitions, smoke-related partitions, and similar elements. Provide smoke and fire stopping at such penetrations as applicable in (see Section 260502). Provide EMT conduit for "drops" from paths to outlets and equipment, with sweep bends, insulated throat fittings and 200-pound pull string.

END OF SECTION 26 0537

SECTION 26 0553 - IDENTIFICATION FOR ELECTRICAL SYSTEMS

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes the following:
 - 1. Identification for conductors and communication and control cable.
 - 2. Wiring device circuit identification.
 - 3. Warning labels and signs.
 - 4. Equipment identification labels.

1.2 SUBMITTALS

A. Product Data: For each electrical identification product indicated.

1.3 QUALITY ASSURANCE

A. Comply with ANSI A13.1.

1.4 COORDINATION

A. Coordinate identification names, abbreviations, colors, and other features with requirements in the Contract Documents, Shop Drawings, manufacturer's wiring diagrams, and the Operation and Maintenance Manual, and with those required by codes, standards, and 29 CFR 1910.145. Use consistent designations throughout Project.

PART 2 - PRODUCTS

2.1 CONDUCTOR AND COMMUNICATION- AND CONTROL-CABLE IDENTIFICATION MATERIALS

A. Marker Tape: Vinyl or vinyl -cloth, self-adhesive wraparound type, with circuit identification legend machine printed by thermal transfer or equivalent process.

2.2 WIRING DEVICE CIRCUIT IDENTIFICATION

- A. Marker Tape: Self-laminating, clear polyester, 3/8" high tape with black lettering.
- B. Provide label on every wiring device cover plate, indicating panel and circuit breaker fed from. Utilize 12 pt. font. Mount label on face of device cover plate, centered near the top.

2.3 WARNING LABELS AND SIGNS

- A. Comply with NFPA 70 and 29 CFR 1910.145.
- B. Self-Adhesive Warning Labels: Factory printed, multicolor, pressure-sensitive adhesive labels, configured for display on front cover, door, or other access to equipment, unless otherwise indicated.
- C. Warning label and sign shall include, but are not limited to, the following legends:
 - 1. Workspace Clearance Warning: "WARNING OSHA REGULATION AREA IN FRONT OF ELECTRICAL EQUIPMENT MUST BE KEPT CLEAR FOR 36 INCHES (915 mm)."

2.4 EQUIPMENT IDENTIFICATION LABELS

A. Self-Adhesive, Engraved, Laminated Phenolic Label: Adhesive backed, with black letters on a white background. Minimum letter height shall be 3/8 inch.

PART 3 - EXECUTION

3.1 APPLICATION

- A. Electrical and Auxiliary Systems Box, Conductor and Cable Identification: Use marker tape to identify field-installed branch circuit, alarm, control, signal, sound, intercommunications, voice, and data wiring connections.
 - 1. Identify conductors, cables, and terminals in enclosures and at junctions, terminals, and cable pull points. Identify by system and circuit designation.
 - 2. Identify panel and branch circuit number(s) on all junction box covers permanently clearly printed with bold black indelible marker.
 - 3. Use system of designations that is uniform and consistent with system used by manufacturer for factory-installed connections.

B. Conduit and junction boxes:

1. Color code or label all junction boxes and exposed conduit at 20 ft. intervals. Coding shall be painted or labels of the pre-manufactured type permanently mounted with metal or plastic band.

- 2. Label panelboard and branch circuit number(s) on outside of junction box cover at all junction boxes containing branch circuit wiring. Labelling shall be neatly done utilizing black indelible ink markers.
- 3. Paint all junction boxes and covers for fire alarm wiring red.
- 4. Provide a color identification scheme under heavy plastic cover hanging in the electrical rooms; identification shall be:
 - a) Emergency Orange
 - b) Normal Black
- C. Branch circuit panelboards:
 - 1. Identify panel designation on directory card within the panel.
 - 2. Fill out branch circuit directory indicating circuit number and area served, rooms, group of rooms, lighting, convenience outlets, motors, etc. Card index shall be neatly typed.
 - 3. Replace branch circuit directory in existing panelboards in areas of alteration.
 - 4. Branch circuit phase conductor color format shall be permanently identified inside each panelboard.
- D. Warning Labels for Indoor Cabinets, Boxes, and Enclosures for Power and Lighting: Comply with 29 CFR 1910.145 and apply self-adhesive warning. Identify system voltage with black letters on an orange background. Apply to exterior of door, cover, or other access.
 - 1. Equipment Requiring Workspace Clearance According to NFPA 70: Unless otherwise indicated, apply to door or cover of equipment but not on flush panelboards and similar equipment in finished spaces.
- E. Equipment Identification Labels: On each unit of equipment, install unique designation label that is consistent with wiring diagrams, schedules, and Operation and Maintenance Manual. Apply labels to disconnect switches and protection equipment, central or master units, control panels, control stations, terminal cabinets, and racks of each system. Systems include power, lighting, control, communication, signal, monitoring, and alarm systems unless equipment is provided with its own identification.
 - 1. Labeling Instructions:
 - a. Indoor Equipment: Self-adhesive, engraved, laminated phenolic label. Unless otherwise indicated, provide a single line of text with 1/4-inch- high letters on 5/8-inch- high label; where 2 lines of text are required, use labels 1 inch high.
 - 2. Equipment to Be Labeled:
 - a. Panelboards, electrical cabinets, and enclosures.
 - b. Disconnect switches.

3. Label shall include equipment name, voltage and where fed from. Where equipment is located in finished spaces, accessible to the public, in addition to adhesive, secure labels with screws, one on each end.

3.2 INSTALLATION

- A. Verify identity of each item before installing identification products.
- B. Location: Install identification materials and devices at locations for most convenient viewing without interference with operation and maintenance of equipment.
- C. Apply identification devices to surfaces that require finish after completing finish work.
- D. Self-Adhesive Identification Products: Clean surfaces before application, using materials and methods recommended by manufacturer of identification device.
- E. Attach nonadhesive signs and plastic labels with screws and auxiliary hardware appropriate to the location and substrate.
- F. Color-Coding for Phase and Voltage Level Identification, 600 V and Less: Use the colors listed below for ungrounded feeder, and branch-circuit conductors.
 - 1. Color shall be factory applied.
 - 2. Colors for 208/120-V Circuits:

a. Phase A: Black.

b. Phase B: Red.

c. Phase C: Blue.

d. Neutral: White

END OF SECTION 26 0553

SECTION 26 0923 - LIGHTING CONTROL DEVICES

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes the following lighting control devices:
 - 1. Indoor occupancy sensors.
- B. See Division 26 Section "Wiring Devices" for wall-box dimmers, wall-switch occupancy sensors, and manual light switches.

1.2 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Operation and maintenance data.

1.3 QUALITY ASSURANCE

A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.

PART 2 - PRODUCTS

2.1 INDOOR OCCUPANCY SENSORS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. Current.
 - 2. Leviton Mfg. Company Inc.
 - 3. Lithonia Lighting; Acuity Lighting Group, Inc.
 - 4. Watt Stopper (The).
 - 5. Sensorswitch.
 - 6. Sensorworx.
- B. General Description: Wall- or ceiling-mounting, solid-state units with a separate relay unit.
 - 1. Operation: Unless otherwise indicated, turn lights on when covered area is occupied and off when unoccupied; with a time delay for turning lights off, adjustable over a minimum range of 1 to 30 minutes.

- 2. Sensor Output: Contacts rated to operate the connected relay, complying with UL 773A. Sensor shall be powered from the relay unit.
- 3. Relay Unit: Dry contacts rated for 20-A ballast load at 120- and 277-V ac, for 13-A tungsten at 120-V ac, and for 1 hp at 120-V ac. Power supply to sensor shall be 24-V dc, 150-mA, Class 2 power source as defined by NFPA 70.
- 4. Mounting:
 - a. Sensor: Suitable for mounting in any position on a standard outlet box.
 - b. Relay: Externally mounted through a 1/2-inch knockout in a standard electrical enclosure.
 - c. Time-Delay and Sensitivity Adjustments: Recessed and concealed behind hinged door.
- 5. Indicator: LED, to show when motion is being detected during testing and normal operation of the sensor.
- 6. Automatic Light-Level Sensor: Adjustable from 2 to 200 fc; keep lighting off when selected lighting level is present.
- C. Dual Technology Type: Ceiling mounting; detect occupancy by sensing a combination of heat and movement in area of coverage.
 - 1. Detector Sensitivity: Detect occurrences of 6-inch- minimum movement of any portion of a human body that presents a target of not less than 36 sq. in.
 - 2. Detection Coverage (Room): Detect occupancy anywhere in a circular area of 1000 sq. ft. when mounted on a 96-inch- high ceiling.
 - 3. Detection Coverage (Corridor): Detect occupancy within 90 feet when mounted on a 10-foot- high ceiling.

D. Emergency Bypass Relays:

1. Where an emergency power system is available and plans indicate control of emergency lighting via occupancy sensor controls, provide U.L. 924 Listed emergency bypass relay(s) to illuminate emergency lighting from emergency power system during a normal power outage.

E. Application:

- 1. Utilize sensor type to best apply to the area it controls (i.e. office, corridor, restrooms, etc.) and provide proper quantity and spacing of sensors to adequately cover the entire area it serves.
- 2. Sensors shall be located and adjusted in private office to prevent incidental activation from passerby in hallways or sensor shall utilize 'adaptive' technology to recognize usage patterns and adjust sensitivity.
- 3. Provide override switch where indicated on plans to disable operation of sensor and leave lights off.

2.2 CONDUCTORS AND CABLES

- A. Power Wiring to Supply Side of Remote-Control Power Sources: Not smaller than No. 12 AWG. Comply with requirements in Division 26 Section "Low-Voltage Electrical Power Conductors and Cables."
- B. Classes 2 and 3 Control Cable: Multiconductor cable with stranded-copper conductors not smaller than No. 18 AWG. Comply with requirements in Division 26 Section "Low-Voltage Electrical Power Conductors and Cables."
- C. Class 1 Control Cable: Multiconductor cable with stranded-copper conductors not smaller than No. 14 AWG. Comply with requirements in Division 26 Section "Low-Voltage Electrical Power Conductors and Cables."

PART 3 - EXECUTION

3.1 SENSOR INSTALLATION

- A. Install and aim sensors in locations to achieve not less than 95 percent coverage of areas indicated. Do not exceed coverage limits specified in manufacturer's written instructions.
- B. After construction period and just prior to turn-over of facility for beneficial use, reset all sensors that are "Adaptive Technology" (or "Smart Technology") to initiate their "learning mode" while in use by the Owner during move-in and beneficial use. Follow up with necessary sensor adjustments within 15 working days.
- C. When requested within 12 months of date of Substantial Completion, provide on-site assistance in adjusting sensors to suit actual occupied conditions. Provide up to two visits to Project during other than normal occupancy hours for this purpose.

3.2 WIRING INSTALLATION

- A. Wiring Method: Comply with Division 26 Section "Low-Voltage Electrical Power Conductors and Cables." Minimum conduit size shall be 1/2 inch.
- B. Wiring within Enclosures: Comply with NECA 1. Separate power-limited and nonpower-limited conductors according to conductor manufacturer's written instructions.
- C. Size conductors according to lighting control device manufacturer's written instructions, unless otherwise indicated.
- D. Splices, Taps, and Terminations: Make connections only on numbered terminal strips in junction, pull, and outlet boxes; terminal cabinets; and equipment enclosures.

3.3 IDENTIFICATION

A. Identify components and power and control wiring according to Division 26 Section "Identification for Electrical Systems."

- 1. Identify controlled circuits in lighting contactors.
- 2. Identify circuits or luminaries controlled by photoelectric and occupancy sensors at each sensor.

3.4 FIELD QUALITY CONTROL

- A. Perform the following field tests and inspections:
 - 1. After installing sensors, and after electrical circuitry has been energized, adjust and test for compliance with requirements.
 - 2. Operational Test: Verify operation of each lighting control device, and adjust time delays.
- B. Lighting control devices that fail tests and inspections are defective work.

END OF SECTION 26 0923

SECTION 26 2416 - PANELBOARDS

PART 1 - GENERAL

1.1 SUMMARY

A. Section includes lighting and appliance branch-circuit panelboards.

1.2 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: For each panelboard and related equipment.
 - 1. Include dimensioned plans, elevations, sections, and details. Show tabulations of installed devices, equipment features, and ratings.
 - 2. Detail enclosure types and details for types other than NEMA 250, Type 1.
 - 3. Detail bus configuration, current, and voltage ratings.
 - 4. Short-circuit current rating of panelboards and overcurrent protective devices.
 - 5. Include evidence of NRTL listing for series rating of installed devices.
 - 6. Detail features, characteristics, ratings, and factory settings of individual overcurrent protective devices and auxiliary components.
- C. Panelboard schedules for installation in panelboards.
- D. Operation and maintenance data.

1.3 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. Comply with NEMA PB 1.
- C. Comply with NFPA 70.

PART 2 - PRODUCTS

2.1 GENERAL REQUIREMENTS FOR PANELBOARDS

- A. Enclosures: Flush- and/or surface-mounted cabinets, as indicated on the drawings.
 - 1. Rated for environmental conditions at installed location.
 - a. Indoor Dry and Clean Locations: NEMA 250, Type 1.

- 2. Front: Secured to box with concealed trim clamps. For surface-mounted fronts, match box dimensions; for flush-mounted fronts, overlap box.
- 3. Hinged Front Cover: Entire front trim hinged to box and with standard door within hinged trim cover.
- 4. Directory Card: Inside panelboard door, mounted in transparent card holder.
- B. Incoming Mains Location: Top and/or bottom as Project condition dictates.
- C. Phase, Neutral, and Ground Buses: Hard-drawn copper, 98 percent conductivity.
- D. Conductor Connectors: Suitable for use with conductor material and sizes.
 - 1. Material: Hard-drawn copper, 98 percent conductivity.
 - 2. Main and Neutral Lugs: Mechanical type.
 - 3. Ground Lugs and Bus Configured Terminators: Mechanical type.
 - 4. Feed-Through Lugs: Mechanical type, suitable for use with conductor material. Locate at opposite end of bus from incoming lugs or main device.
 - 5. Subfeed (Double) Lugs: Mechanical type suitable for use with conductor material. Locate at same end of bus as incoming lugs or main device.
- E. Service Equipment Label: NRTL labeled for use as service equipment for panelboards with one or more main service disconnecting and overcurrent protective devices.
- F. Future Devices: Mounting brackets, bus connections, filler plates, and necessary appurtenances required for future installation of devices.
- G. Panelboard Short-Circuit Current Rating: Fully rated to interrupt symmetrical short-circuit current available at terminals.
- H. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. Cutler-Hammer.
 - 2. Siemens.
 - 3. Square D.
 - 4. ABB.

2.2 LIGHTING AND APPLIANCE BRANCH-CIRCUIT PANELBOARDS

- A. Panelboards: NEMA PB 1, lighting and appliance branch-circuit type.
- B. Mains: Circuit breaker and/or lugs only as identified on the drawings. Sized to have 225 amp bussing unless indicated otherwise on drawings.
- C. Branch Overcurrent Protective Devices: Bolt-on circuit breakers, replaceable without disturbing adjacent units. Sized to accommodate 42 poles unless indicated otherwise on drawings. Furnish number of breakers shown.
- D. Doors: Concealed hinges; secured with flush latch with tumbler lock; keyed alike.

2.3 DISCONNECTING AND OVERCURRENT PROTECTIVE DEVICES

- A. Molded-Case Circuit Breaker (MCCB): Comply with UL 489, with interrupting capacity to meet available fault currents listed on the drawings.
 - 1. Thermal-Magnetic Circuit Breakers: Inverse time-current element for low-level overloads, and instantaneous magnetic trip element for short circuits. Adjustable magnetic trip setting for circuit-breaker frame sizes 250 A and larger.
 - 2. GFCI Circuit Breakers: Single- and two-pole configurations with Class A ground-fault protection (6-mA trip).
 - 3. Ground-Fault Equipment Protection (GFEP) Circuit Breakers: Class B ground-fault protection (30-mA trip).
 - 4. Molded-Case Circuit-Breaker (MCCB) Features and Accessories:
 - a. Standard frame sizes, trip ratings, and number of poles. Where more than one pole is used, they shall employ a common trip.
 - b. Lugs: Mechanical style, suitable for number, size, trip ratings, and conductor materials
 - c. Application Listing: Appropriate for application; Type HACR for feeding heating, air conditioning and refrigeration equipment.
 - d. Ground-Fault Protection: Integrally mounted relay and trip unit with adjustable pickup and time-delay settings, push-to-test feature, and ground-fault indicator.
 - e. Handle Padlocking Device: Fixed attachment, for locking circuit-breaker handle in on or off position.
 - f. Handle Clamp: Loose attachment, for holding circuit-breaker handle in on position.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Receive, inspect, handle, store and install panelboards and accessories according to NEMA PB 1.1.
- B. Mount top of lighting and appliance panelboard trim 72 inches above finished floor; distribution panelboard trim 90 inches above finished floor, unless otherwise indicated.
- C. Mount panelboard cabinet plumb and rigid without distortion of box. Mount recessed panelboards with fronts uniformly flush with wall finish and mating with back box.
- D. Install overcurrent protective devices and controllers not already factory installed.
 - 1. Set field-adjustable, circuit-breaker trip ranges and ground fault settings as applicable.
- E. Install filler plates in unused spaces.
- F. Stub four 1-inch empty conduits from flush mounted panelboard into accessible ceiling space or space designated to be ceiling space in the future.

- G. Arrange conductors in gutters into groups and bundle and wrap with wire ties.
- H. Comply with NECA 1.

3.2 IDENTIFICATION

- A. Identify field-installed conductors, interconnecting wiring, and components; provide warning signs complying with Division 26 Section "Identification for Electrical Systems."
- B. Switchboards or panelboards containing a 4-wire, delta connected system where the midpoint of one phase winding is grounded shall be legibly and permanently field marked to indicate "high phase leg to ground" per (2017) NEC 408.3(F).
- C. Create a directory to indicate installed circuit loads and incorporating Owner's final room, area or equipment designations. Temporary conditions of occupancy shall not be utilized as circuit descriptions. Indicated spare circuits shall be specifically labeled as such. Obtain approval before installing. Use a computer or typewriter to create directory; handwritten directories are not acceptable.
- D. Panelboard Nameplates: Label each panelboard with a nameplate complying with requirements for identification specified in Division 26 Section "Identification for Electrical Systems."
- E. Device Nameplates: Label each branch circuit device in distribution panelboards with a nameplate complying with requirements for identification specified in Division 26 Section "Identification for Electrical Systems."

3.3 FIELD QUALITY CONTROL

- A. Perform tests and inspections.
- B. Panelboards will be considered defective if they do not pass tests and inspections.

END OF SECTION 26 2416

SECTION 26 2726 - WIRING DEVICES

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes the following:
 - 1. Receptacles, receptacles with integral GFCI, and associated device plates.
 - 2. Wall-box motion sensors.
 - 3. Snap switches and wall-box dimmers.
 - 4. Solid-state fan speed controls.
 - 5. Wall-switch and interior occupancy sensors.
 - 6. Communications outlets.
- B. See Division 27 Section "Communications Horizontal Cabling" for workstation outlets.

1.2 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: List of legends and description of materials and process used for premarking wall plates.

1.3 QUALITY ASSURANCE

A. Comply with NFPA 70.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Manufacturers' Names: Shortened versions (shown in parentheses) of the following manufacturers' names are used in other Part 2 articles:
 - 1. Cooper Wiring Devices; a division of Cooper Industries, Inc. (Cooper).
 - 2. Hubbell Incorporated; Wiring Device-Kellems (Hubbell).
 - 3. Leviton Mfg. Company Inc. (Leviton).
 - 4. Pass & Seymour/Legrand; Wiring Devices & Accessories (Legrand).

2.2 STRAIGHT BLADE RECEPTACLES

A. Convenience Receptacles, 125 V, 20 A: Comply with NEMA WD 1, NEMA WD 6 configuration 5-20R, and UL 498.

- 1. Products: Subject to compliance with requirements, provide one of the following:
 - a. Cooper; 5351 (single), 5352 (duplex).
 - b. Hubbell; 5361 (single), 5362 (duplex).
 - c. Leviton; 5351 (single), 5352 (duplex).
 - d. Pass & Seymour; 5361 (single), 5362 (duplex).

2.3 GFCI RECEPTACLES

- A. General Description: Straight blade, non-feed-through type. Comply with NEMA WD 1, NEMA WD 6, UL 498, and UL 943, Class A, and include indicator light that is lighted when device is tripped.
- B. All receptacles installed outdoors shall be weather resistant type.
- C. Duplex GFCI Convenience Receptacles, 125 V, 20 A:
 - 1. Products: Subject to compliance with requirements, provide one of the following:
 - Cooper.
 - b. Pass & Seymour/Legrand.
 - c. Leviton.
 - d. Hubbell.

2.4 TAMPER RESISTANT STRAIGHT BLADE RECEPTACLES

- A. Convenience Receptacles, 125 V, 20 A: Comply with NEMA WD 1, NEMA WD 6 configuration 5-20R, NEC 406.12 & 517.18(C) and UL 498.
- B. Where indicated on plans to provide Tamper Resistant type receptacle, device shall have non-conductive dual mechanical shutter mechanisms on 120V connection ports, compliant with NEC requirements. This is in addition to required device configuration indicated (ie: Standard Straight Blade, Hospital Grade, GFCI, etc.).

2.5 USB CHARGING TYPE RECEPTACLES

- A. Convenience Receptacles, 125V, 20A: Comply with NEMA WD 1, NEMA WD 6 configuration 5-20R, UL 498.
- B. Where indicated on plans to include USB Type Charging ports, device shall include Dual-Port USB Type A-C charging ports with minimum 5 Amps combined charging power (minimum 25 watts), in addition to required device configuration indicated (ie: Standard Straight Blade, Hospital Grade, GFCI, Tamper-resistant, etc.).

2.6 NIGHT LIGHT ACCESSORY

A. Where indicated on plans to include night light accessory ("NL"), device shall have LED night light, integral with the face of device and photo-sensor for control of night light function. This is in addition to required device configuration indicated (ie: Standard Straight Blade, Hospital Grade, GFCI, Tamper-resistant, etc.).

2.7 SNAP SWITCHES

- A. Comply with NEMA WD 1 and UL 20.
- B. Switches, 120/277 V, 20 A:
 - 1. Products: Subject to compliance with requirements, provide one of the following:
 - a. Cooper; 2221 (single pole), 2222 (two pole), 2223 (three way), 2224 (four way).
 - b. Hubbell; CS1221 (single pole), CS1222 (two pole), CS1223 (three way), CS1224 (four way).
 - c. Leviton; 1221-2 (single pole), 1222-2 (two pole), 1223-2 (three way), 1224-2 (four way).
 - d. Pass & Seymour; 20AC1 (single pole), 20AC2 (two pole), 20AC3 (three way), 20AC4 (four way).
- C. Pilot Light Switches, 20 A:
 - 1. Products: Subject to compliance with requirements, provide one of the following:
 - a. Cooper; 2221PL for 120 V and 277 V.
 - b. Hubbell; HPL1221PL for 120 V and 277 V.
 - c. Leviton; 1221-PLR for 120 V, 1221-7PLR for 277 V.
 - d. Pass & Seymour; PS20AC1-PLR for 120 V.
 - 2. Description: Single pole, with neon-lighted handle, illuminated when switch is "ON."

2.8 WALL-BOX DIMMERS

- A. Dimmer Switches: Modular, 0-10V, solid-state units with integral, quiet on-off switches. Unit listed and compatible for type of lighting controlled and rated for connected load unless larger rating is indicated for future capacity.
- B. Control: Continuously adjustable slider, with separate on-off switch; single-pole or three-way switching capability. Comply with UL 1472.

2.9 OCCUPANCY SENSORS

A. Wall-Switch Sensors:

- 1. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, the following:
- 2. Products: Subject to compliance with requirements, manufacturer shall match that submitted for ceiling mounted occupancy sensors.
- 3. Description: Passive-infrared type, 120/277 V, adjustable time delay up to 30 minutes, 180-degree field of view, with a minimum coverage area of 900 sq. ft..

2.10 WALL PLATES

- A. Single and combination types to match corresponding wiring devices.
 - 1. Plate-Securing Screws: Metal with head color to match plate finish.
 - 2. Material for Finished Spaces: Nylon.
- B. Wet-Location, Weatherproof Cover Plates: NEMA 250, complying with type 3R weather-resistant, die-cast aluminum with lockable cover.
 - 1. Outdoor receptacle covers shall be "In Use" type rated "Extra Duty".

2.11 FLOOR SERVICE FITTINGS

- A. Type: Modular, flush-type, dual-service units suitable for wiring method used.
- B. Compartments: Barrier separates power from voice and data communication cabling.
- C. Service Plate: Rectangular, die-cast aluminum with satin finish.
- D. Power Receptacle: NEMA WD 6 configuration 5-20R, black finish, unless otherwise indicated.
- E. Voice and Data Communication Outlet: As noted on plans or as indicated in applicable specification section.

2.12 FINISHES

- A. Color: Wiring device catalog numbers in Section Text do not designate device color.
 - 1. Wiring Devices: White, unless otherwise indicated or required by NFPA 70 or device listing.
 - 2. Device plates: Nylon, to match color of wiring devices.

PART 3 - EXECUTION

3.1 INSTALLATION

A. Comply with NECA 1, including the mounting heights listed in that standard, unless otherwise noted.

B. Coordination with Other Trades:

- 1. Take steps to insure that devices and their boxes are protected. Do not place wall finish materials over device boxes and do not cut holes for boxes with routers that are guided by riding against outside of the boxes.
- 2. Keep outlet boxes free of plaster, drywall joint compound, mortar, cement, concrete, dust, paint, and other material that may contaminate the raceway system, conductors, and cables
- 3. Install device boxes in brick or block walls so that the cover plate does not cross a joint unless the joint is troweled flush with the face of the wall.
- 4. Install wiring devices after all wall preparation, including painting, is complete.
- 5. All 15 or 20 amp-120V wiring devices located within 6 feet from the edge of a sink, located in Kitchens or Bathrooms or serving electric water cooler shall be GFCI protected type device.

C. Conductors:

- 1. Do not strip insulation from conductors until just before they are spliced or terminated on devices
- 2. The length of free conductors at outlets for devices shall meet provisions of NFPA 70, Article 300, without pigtails.
- 3. Existing Conductors:
 - a. Cut back and pigtail, or replace all damaged conductors.
 - b. Straighten conductors that remain and remove corrosion and foreign matter.
 - c. Pigtailing existing conductors is permitted provided the outlet box is large enough.

D. Device Installation:

- 1. Replace all devices that have been in temporary use during construction or that show signs that they were installed before building finishing operations were complete.
- 2. Connect devices to branch circuits using pigtails that are not less than 6 inches in length.
- 3. When there is a choice, use side wiring with binding-head screw terminals.
- 4. When conductors larger than No. 12 AWG are installed on 15- or 20-A circuits, splice No. 12 AWG pigtails for device connections.
- 5. Tighten unused terminal screws on the device.

E. Receptacle Orientation:

- 1. Install ground pin of vertically mounted receptacles down, and on horizontally mounted receptacles to the right.
- F. Device Plates: Do not use oversized or extra-deep plates. Repair wall finishes and remount outlet boxes when standard device plates do not fit flush or do not cover rough wall opening.

G. Dimmers:

- 1. Install dimmers within terms of their listing.
- 2. Verify that dimmers used for fan speed control are listed for that application.
- 3. Install unshared neutral conductors on line and load side of dimmers according to manufacturers' device listing conditions in the written instructions.

WIRING DEVICES 26 2726 - 5

H. Arrangement of Devices: Unless otherwise indicated, mount flush, with long dimension vertical and with grounding terminal of receptacles on top. Group adjacent switches under single, multigang wall plates.

3.2 "PLUG CONNECT/PLUG TAIL" DEVICES

- A. In lieu of terminal screw connected receptacles and switches as specified above, specialized plug-in type devices may be provided as long as it is offered by the same manufacturer and listed equivalent to the same product line specified. Permanent wiring pigtails shall be of sufficient length to enable replacement of device with standard terminal screw type device as required by Code.
- B. Where plug-in type wiring devices are provided, furnish a minimum of five (5) of each type and color device installed to the Owner as spares. Where more than one hundred (100) of any type is installed, provide a minimum of ten (10) spare devices.

3.3 IDENTIFICATION

A. Comply with Division 26 Section "Identification for Electrical Systems."

3.4 FIELD QUALITY CONTROL

- A. Tests for Convenience Receptacles:
 - 1. Line Voltage: Acceptable range is 105 to 132 V.
 - 2. Percent Voltage Drop under 15-A Load: A value of 6 percent or higher is not acceptable.
 - 3. Ground Impedance: Values of up to 2 ohms are acceptable.
 - 4. GFCI Trip: Test for tripping values specified in UL 1436 and UL 943.
 - 5. Using the test plug, verify that the device and its outlet box are securely mounted.

END OF SECTION 26 2726

WIRING DEVICES 26 2726 - 6

SECTION 26 5113 - INTERIOR LIGHTING FIXTURES

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes the following:
 - 1. Interior lighting fixtures, light engines (LED's) and drivers.
 - 2. Emergency lighting units.
 - 3. Exit signs.
 - 4. Lighting fixture supports.
- B. See Division 26 Section "Wiring Devices" for manual wall-box dimmers for LED fixtures or lamps.
- C. See Division 26 Section "Lighting Control Devices" for automatic control of lighting, including occupancy sensors, and multi-pole lighting relays and contactors.

1.2 SUBMITTALS

- A. Product Data: For each type of lighting fixture, arranged in order of fixture designation. Include data on features, accessories, finishes and photometric data.
- B. Shop Drawings: Show details of nonstandard or custom lighting fixtures. Indicate dimensions, weights, methods of field assembly, components, features, and accessories.
- C. LED Fixtures: Fixtures with LED light source are noted on lighting fixture schedule with advertised lumen output of light source for fixture/manufacturer specified and color temperature. Listed equal manufacturer shall provide fixture with equivalent lumen output as listed product. If insufficient information is provided, the Engineer may require Project Specific, point-by-point photometric calculations of sample areas utilizing the submitted fixture to prove equivalent performance.
- D. Product Certificates: For each type of driver, signed by product manufacturer.
- E. Utility Company Energy Rebate Programs
 - 1. LED lighting fixtures shall be Energy Star or DLC listed to comply with local Utility Company Rebate Programs. Does not apply to track lighting fixtures. Fixture submittals that do not have either of these listings clearly indicated in the product data shall be rejected.
- F. Field quality-control test reports.

1.3 QUALITY ASSURANCE

- A. Comply with NFPA 70.
- B. All LED fixtures and components shall be tested and comply under the standards of IESNA LM-79-08, LM-80-08, LM-82-12 and TM-21-11 for measurement and publication of projected long term lumen maintenance, color stability, photometric performance and LED source operating lifetime. Fixture submitted shall meet the listed lifetime rating of the fixture specified, as a minimum.

1.4 WARRANTY

A. Provide a written, five year replacement material warranty for defective or non-starting LED source assemblies. Warranty period shall begin on date of installation.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. In Lighting Fixture Schedule the following requirements apply to product selection:
 - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the manufacturers specified on drawing schedule.

2.2 LIGHTING FIXTURES AND COMPONENTS, GENERAL REQUIREMENTS

- A. Recessed Fixtures: Comply with UL 1598 and NEMA LE 4 for ceiling compatibility for recessed fixtures.
- B. Metal Parts: Free of burrs and sharp corners and edges.
- C. Sheet Metal Components: Steel, unless otherwise indicated. Form and support to prevent warping and sagging.
- D. Polymer Components: Plastic or polymer housing/components of fixture assemblies shall be rated for the temperature (or plenum) environment installed and shall not degrade in structural integrity, shape, color or finish for a minimum of 10 years.
- E. Doors, Frames, and Other Internal Access: Smooth operating, free of light leakage under operating conditions, and designed to permit servicing without use of tools. Designed to prevent doors, frames, lenses, diffusers, and other components from falling accidentally during servicing and when secured in operating position.
- F. Plastic Diffusers, Covers, and Globes:
 - 1. Acrylic Lighting Diffusers: 100 percent virgin acrylic plastic. High resistance to yellowing and other changes due to aging, exposure to heat, and UV radiation.

- a. Lens Thickness: At least 0.125 inch minimum unless different thickness is indicated.
- b. UV stabilized.
- 2. Glass: Tempered glass, unless otherwise indicated.
- G. Servicing Access: Fixtures specified for installation in inaccessible (gypsum/drywall) ceilings/walls, etc. shall be fully serviceable/accessible from the fixture aperture.

H. Disconnecting Means:

1. Lighting fixtures with luminaires that utilize double-ended lamps and contain driver(s) that can be serviced in place or luminaires that are supplied from multi-wire branch circuits and can be serviced in place shall have a local disconnecting means at/within the fixture complying with NEC Article 410.75.

2.3 DRIVERS

A. Drivers for LED Light Sources:

- 1. Driver shall be separate component from LED light source and shall be replaceable utilizing mounting screws, factory provided clips and electrical connector bodies.
- 2. Dimming (When noted or indicated on Fixture Schedule): 100 to 1 percent of rated lumens via separate 0-10V input (Dimmer) control. Line voltage dimming acceptable when noted on plans.
- 3. Level Control/Step-Dimming (When noted or indicated on Fixture Schedule): Minimum capability of bi-level control (100%-50%-Off) or 1/3-2/3-Full on, as noted.
- 4. Voltage input: 120-277 Volt multi-volt capability.
- B. Internal-Type Emergency Fluorescent Power Unit: Self-contained, modular, battery-inverter unit, factory mounted within lighting fixture body and compatible with driver. Comply with UL 924.
 - 1. Emergency Connection: Operate light source continuously at a minimum output of 1000 lumens. Connect unswitched circuit to battery-inverter unit and switched circuit to fixture driver.
 - 2. Test Push Button and Indicator Light: Visible and accessible without opening fixture or entering ceiling space.
 - a. Push Button: Push-to-test type, in unit housing, simulates loss of normal power and demonstrates unit operability.
 - b. Indicator Light: LED indicates normal power on. Normal glow indicates trickle charge; bright glow indicates charging at end of discharge cycle.
 - 3. Battery: Sealed, maintenance-free, nickel-cadmium type.
 - 4. Charger: Fully automatic, solid-state, constant-current type with sealed power transfer relay.
 - 5. Voltage input: 120-277 Volt multi-volt capability.

C. Where plans call for multi-level switching/lighting, provide appropriate driver in fixture as required to accommodate the switching level arrangement of fixture.

2.4 EXIT SIGNS

- A. Internally Lighted Signs: Comply with UL 924; for sign colors, visibility, luminance, and lettering size, comply with authorities having jurisdiction.
 - 1. Light source for AC Operation: LEDs, 70,000 hours minimum rated lamp life.
 - 2. Voltage input: 120-277 Volt multi-volt capability.
 - 3. Integral battery backup to illuminate fixture and lamps heads, including remote lamp heads (where applicable), for a minimum of 90 minutes upon loss of normal power.

2.5 EMERGENCY LIGHTING UNITS

- A. Description: Self-contained units complying with UL 924.
 - 1. Battery: Sealed, maintenance-free, lead-acid type.
 - 2. Charger: Fully automatic, solid-state type with sealed transfer relay.
 - 3. Operation: Relay automatically turns luminaire on when power supply circuit voltage drops to 80 percent of nominal voltage or below. Luminaire automatically disconnects from battery when voltage approaches deep-discharge level. When normal voltage is restored, relay disconnects luminaire from battery, and battery is automatically recharged and floated on charger.
 - 4. Test Push Button: Push-to-test type, in unit housing, simulates loss of normal power and demonstrates unit operability.
 - 5. LED Indicator Light: Indicates normal power on. Normal glow indicates trickle charge; bright glow indicates charging at end of discharge cycle.
 - 6. Voltage input: 120-277 Volt multi-volt capability.

2.6 LIGHTING FIXTURE SUPPORT COMPONENTS

- A. Comply with Division 26 Section "Hangers and Supports for Electrical Systems" for channeland angle-iron supports and nonmetallic channel and angle supports.
- B. Wires: ASTM A 641/A 641M, Class 3, soft temper, zinc-coated steel, 12 gauge.
- C. Rod Hangers: 3/16-inch minimum diameter, cadmium-plated, threaded steel rod.
- D. Recessed fixtures shall be supported at all 4 corners, independent of each other, from structure above with steel #12 single jack chains. Additionally, securely fasten each fixture to the ceiling framing member by mechanical means such as bolts, screws, rivets or approved clips; install a minimum of one on each four sides of fixture.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Lighting fixtures: Set level, plumb, and square with ceilings and walls.
- B. Comply with NFPA 70 for minimum fixture supports.
- C. Suspended Lighting Fixture Support:
 - 1. Single or Continuous Rows: Provide manufacturer required quantity of suspension cables at minimum intervals to support continuous row fixtures. The E.C. shall support suspended fixtures independently from the ceiling system and as specified by the fixture manufacturer.

D. Surface or Flush Lighting Fixture Support:

- 1. The E.C. shall coordinate fixture locations with the trade installing the ceiling system to assure support members are oriented and located to accommodate the lighting fixture layout.
- 2. Surface or flush fixtures in ceilings of the suspended lay-in type shall be installed so that the long dimension of the fixture is supported on the main support members of the ceiling system.
- E. Luminaires installed in exposed or concealed locations under metal corrugated sheet roof decking shall be installed and supported so there is not less than 1-1/2" measured from the lowest surface of the roof decking to the top of the luminaire.
- F. Adjust aimable lighting fixtures to provide required light intensities.
- G. Where fixtures are suspended in Mechanical/Electrical/Storage/Technology or Utility spaces with no suspended ceiling, coordinate mounting heights and locations with exposed ductwork, piping, conduit/data cabling racks, equipment, etc. to provide optimal and even light distribution to service equipment.
- H. Connect wiring according to Division 26 Section "Low-Voltage Electrical Power Conductors and Cables."

3.2 FIELD QUALITY CONTROL

A. Test for Emergency Lighting: Interrupt power supply to demonstrate proper operation. Where applicable, verify transfer from normal power to battery and retransfer to normal.

3.3 SPARE LAMPS/FIXTURES

A. For LED fixtures with LED source integral to the fixture assembly, provide one spare fixture for each type as noted on lighting fixture schedule.

B. For fixtures with separate/replaceable LED luminaire (retrofit lamp), provide 5 spare lamps of each type utilized.

END OF SECTION 26 5113

SECTION 26 7561 – VOICE AND DATA COMMUNICATIONS HORIZONTAL CABLING

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

- 1. Pathways.
- 2. UTP cabling.
- 3. Multiuser telecommunications outlet assemblies.
- 4. Cable connecting hardware, patch panels, and cross-connects.
- 5. Telecommunications outlet/connectors.
- 6. Cabling identification products.
- 7. Cabling administration system

1.2 HORIZONTAL CABLING DESCRIPTION

- A. Horizontal cable and its connecting hardware provide the means of transporting signals between the telecommunications outlet/connector and the horizontal cross-connect located in the communications equipment room. This cabling and its connecting hardware are called "permanent link," a term that is used in the testing protocols.
 - 1. TIA/EIA-568-B.1 requires that a minimum of two telecommunications outlet/connectors be installed for each work area.
 - 2. Horizontal cabling shall contain no more than one transition point or consolidation point between the horizontal cross-connect and the telecommunications outlet/connector.
 - 3. Bridged taps and splices shall not be installed in the horizontal cabling.

1.3 PERFORMANCE REQUIREMENTS

A. General Performance: Horizontal cabling system shall comply with transmission standards in TIA/EIA-568-B.1, when tested according to test procedures of this standard.

1.4 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings:
 - 1. System Labeling Schedules: Electronic copy of labeling schedules, in software and format selected by Owner.
 - 2. Cabling administration drawings and printouts.
 - 3. Wiring diagrams to show typical wiring schematics, including the following:

DARKE COUNTY WAGNER AVENUE INTERIOR RENOVATION

- a. Data Racks and Patch panels.
- b. Cross connects.
- c. Patch cords.
- 4. Cross-connects and patch panels. Detail mounting assemblies, and show elevations and physical relationship between the installed components.
- C. Qualification Data: For Installer, qualified layout technician, installation supervisor, and field inspector.
- D. Maintenance data.

1.5 QUALITY ASSURANCE

- A. Installer Qualifications: Cabling Installer must have personnel certified by BICSI on staff.
 - 1. Layout Responsibility: Preparation of Shop Drawings, Cabling Administration Drawings, and field testing program development by an RCDD.
 - 2. Installation Supervision: Installation shall be under the direct supervision of Registered Technician, who shall be present at all times when Work of this Section is performed at Project site.
- B. Surface-Burning Characteristics: As determined by testing identical products according to ASTM E 84 by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.
 - 1. Flame-Spread Index: 25 or less.
 - 2. Smoke-Developed Index: 50 or less.
- C. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- D. Telecommunications Pathways and Spaces: Comply with TIA/EIA-569-A.
- E. Grounding: Comply with ANSI-J-STD-607-A.
- 1.6 DELIVERY, STORAGE, AND HANDLING
- A. Test cables upon receipt at Project site. Test each pair of UTP cable for open and short circuits.

PART 2 - PRODUCTS

2.1 PATHWAYS

A. Cable Support: NRTL labeled for support of Category 6 cabling, designed to prevent degradation of cable performance and pinch points that could damage cable.

- 1. Support brackets with cable tie slots for fastening cable ties to brackets.
- 2. Lacing bars, spools, J-hooks, and D-rings.
- 3. Straps and other devices.
- B. Conduit and Boxes: Comply with requirements in Division 26 Section "Raceway and Boxes for Communications Systems." Flexible metal conduit shall not be used.
 - 1. Outlet boxes shall be no smaller than 4 inches square, and 2-1/2 inches deep.

2.2 UTP CABLE

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. Black Box.
- B. Description: Category 5E 100-ohm, 4-pair UTP, covered with a blue thermoplastic jacket.
 - 1. Comply with ICEA S-90-661 for mechanical properties.
 - 2. Comply with TIA/EIA-568-B.1 for performance specifications.
 - 3. Comply with TIA/EIA-568-B.2, Category 6 for data.
 - 4. Listed and labeled by an NRTL acceptable to authorities having jurisdiction as complying with UL 444 and NFPA 70 for the following types:
 - a. Communications, Plenum Rated: Type CMP, complying with NFPA 262.
 - b. Communications, Riser Rated: Type CMR, complying with UL 1666.
 - c. Multipurpose, Plenum Rated: Type MPP, complying with NFPA 262.
 - d. Multipurpose, Riser Rated: Type MPR, complying with UL 1666.

2.3 UTP CABLE HARDWARE

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. American Technology Systems Industries, Inc.
 - 2. Dynacom Corporation.
 - 3. Hubbell Premise Wiring.
 - 4. Panduit Corp.
- B. General Requirements for Cable Connecting Hardware: Comply with TIA/EIA-568-B.2, IDC type, with modules designed for punch-down caps or tools. Cables shall be terminated with connecting hardware of same category or higher.
- C. Cross-Connect: Modular array of connecting blocks arranged to terminate building cables and permit interconnection between cables.
 - 1. Number of Terminals per Field: One for each conductor in assigned cables.

- D. Patch Panel: Modular panels housing multiple-numbered jack units with IDC-type connectors at each jack for permanent termination of pair groups of installed cables, utilize 48 port panels as a standard.
 - 1. Number of Jacks per Field: One for each four-pair conductor group of indicated cables, plus spares and blank positions adequate to suit specified expansion criteria.
- E. Jacks and Jack Assemblies: Modular, color-coded, eight-position modular receptacle units with integral IDC-type terminals.
- F. Patch Cords: Factory-made, 4-pair cables in **48-inch** lengths; terminated with 8-position modular plug at each end.
 - 1. Patch cords shall have bend-relief-compliant boots and color-coded icons to ensure Category 5E performance. Patch cords shall have latch guards to protect against snagging.
 - 2. Patch cords shall have color-coded boots for circuit identification.

2.4 CONSOLIDATION POINTS

- A. Manufacturers: Subject to compliance with requirements, provide products by the following:
 - 1. Data: Ortronics, Inc.
- B. Description: Consolidation points shall comply with requirements for cable connecting hardware.
 - 1. Number of Terminals per Field: One for each conductor in assigned cables.
 - 2. Number of Connectors per Field:
 - a. One for each four-pair UTP cable indicated.
 - 3. Mounting: Recessed in Floor or Wall as indicated on floor plans.
 - 4. NRTL listed as complying with UL 50 and UL 1863.
 - 5. When installed in plenums used for environmental air, NRTL listed as complying with UL 2043.

2.5 MULTIUSER TELECOMMUNICATIONS OUTLET ASSEMBLY (MUTOA)

- A. Manufacturers: Subject to compliance with requirements, provide products by the following:
 - 1. Data: Ortronics, Inc.
- B. Description: MUTOAs shall meet the requirements for cable connecting hardware.
 - 1. Number of Terminals per Field: One for each conductor in assigned cables.
 - 2. Number of Connectors per Field:

- a. One for each four-pair UTP cable indicated.
- 3. Mounting: Recessed in Floor, Wall or Furniture.
- 4. NRTL listed as complying with UL 50 and UL 1863.
- 5. Label shall include maximum length of work area cords, based on TIA/EIA-568-B.1.

2.6 DATA OUTLET/CONNECTORS

- A. Jacks: 100-ohm, balanced, twisted-pair connector; four-pair, eight-position modular. Comply with TIA/EIA-568-B.1.
- B. Workstation Outlets: Two-port-connector assemblies mounted in single or multigang faceplate.
 - 1. Faceplate: White nylon, complying with requirements in Division 26 Section "Wiring Devices."
 - 2. For use with snap-in jacks accommodating any combination of UTP work area cords.
 - a. Flush mounting jacks, positioning the cord at a 180-degree angle.
 - 3. Legend: Snap-in, clear-label covers and machine-printed paper inserts.

2.7 GROUNDING

- A. Comply with requirements in Division 26 Section "Grounding and Bonding for Electrical Systems" for grounding conductors and connectors.
- B. Comply with ANSI-J-STD-607-A.

2.8 IDENTIFICATION PRODUCTS

- A. Comply with TIA/EIA-606-A and UL 969 for a system of labeling materials, including label stocks, laminating adhesives, and inks used by label printers.
- B. Comply with requirements in Division 26 Section "Identification for Electrical Systems."

2.9 SOURCE QUALITY CONTROL

- A. Factory test UTP cables on reels according to TIA/EIA-568-B.1.
- B. Factory test UTP cables according to TIA/EIA-568-B.2.
- C. Cable will be considered defective if it does not pass tests and inspections.

PART 3 - EXECUTION

3.1 ENTRANCE FACILITIES

A. Coordinate backbone cabling with the Owner (Provided by Owner).

3.2 WIRING METHODS

- A. Wiring Method: Install cables in raceways, basket tray and routed thru J-Hook/Bridle Ring System in accessible ceiling spaces except within consoles, cabinets, desks, and counters. Conceal raceway and cables except in unfinished spaces. The floor plans indicate areas where basket tray shall be utilized above accessible ceiling panels. All other areas shall utilize J-Hook/Bridle Ring System and conduit system from workstation outlet to corridor cable management system.
 - 1. Install plenum cable in environmental air spaces, including plenum ceilings.
 - 2. Comply with requirements for raceways and boxes specified in Division 26 Section "Raceway and Boxes for Electrical Systems."
- B. Wiring within Enclosures: Bundle, lace, and train cables to terminal points with no excess and without exceeding manufacturer's limitations on bending radii. Provide and use lacing bars and distribution spools.

3.3 INSTALLATION OF PATHWAYS

- A. J-Hook/Bridle Ring System: Comply with TIA/EIA-569-A. Drawings indicate general routing of system. Provide capacity for all new cabling to be installed plus 100% spare capacity. Provide tiered or tandem hooks as required.
- B. Comply with TIA/EIA-569-A for pull-box sizing and length of conduit and number of bends between pull points.
- C. Comply with requirements in Division 26 Section "Raceway and Boxes for Communications Systems" for installation of cable tray, conduits and wireways.
- D. Install manufactured conduit sweeps and long-radius elbows whenever possible.
- E. Pathway Installation in Communications Equipment Rooms:
 - 1. Position conduit ends adjacent to a corner on backboard where a single piece of plywood is installed, or in the corner of room where multiple sheets of plywood are installed around perimeter walls of room.
 - 2. Secure conduits to backboard when entering room from overhead.
 - 3. Install metal conduits with grounding bushings and connect with grounding conductor to grounding system.
 - 4. Provide ladder rack as detailed on floor plan, mount 12" above top of equipment racks.
 - 5. Install J-Hooks around perimeter of room near top of backboards 12" O.C.

F. Backboards: Install backboards with 96-inch dimension vertical. Butt adjacent sheets tightly, and form smooth gap-free corners and joints.

3.4 INSTALLATION OF CABLES

- A. Comply with NECA 1.
- B. General Requirements for Cabling:
 - 1. Comply with TIA/EIA-568-B.1.
 - 2. Comply with BICSI ITSIM, Ch. 6, "Cable Termination Practices."
 - 3. Install Cat 6 patch panel termination hardware unless otherwise indicated.
 - 4. MUTOA shall not be used as a cross-connect point.
 - 5. Consolidation points may be used only for making a direct connection to telecommunications outlet/connectors:
 - a. Do not use consolidation point as a cross-connect point, as a patch connection, or for direct connection to workstation equipment.
 - b. Locate consolidation points for UTP at least 49 feet from communications equipment room.
 - 6. Terminate conductors; no cable shall contain unterminated elements. Make terminations only at indicated outlets, terminals, cross-connects, and patch panels.
 - 7. Cables may not be spliced. Secure and support cables at intervals not exceeding 30 inches and not more than 6 inches from cabinets, boxes, fittings, outlets, racks, frames, and terminals.
 - 8. Install lacing bars to restrain cables, to prevent straining connections, and to prevent bending cables to smaller radii than minimums recommended by manufacturer.
 - 9. Bundle, lace, and train conductors to terminal points without exceeding manufacturer's limitations on bending radii, but not less than radii specified in BICSI ITSIM, "Cabling Termination Practices" Chapter. Install lacing bars and distribution spools.
 - 10. Do not install bruised, kinked, scored, deformed, or abraded cable. Do not splice cable between termination, tap, or junction points. Remove and discard cable if damaged during installation and replace it with new cable.
 - 11. Cold-Weather Installation: Bring cable to room temperature before dereeling. Heat lamps shall not be used for heating.
 - 12. In the communications equipment room and at workstation outlet in private offices, install a 10-foot- long service loop on each end of cable. Locate private office service loop above accessible ceiling of office.
 - 13. Pulling Cable: Comply with BICSI ITSIM, Ch. 4, "Pulling Cable." Monitor cable pull tensions

C. UTP Cable Installation:

- 1. Comply with TIA/EIA-568-B.2.
- 2. Do not untwist UTP cables more than 1/2 inch from the point of termination to maintain cable geometry.
- D. Open-Cable Installation:

- 1. Install cabling with horizontal and vertical cable guides in telecommunications spaces with terminating hardware and interconnection equipment.
- 2. Suspend UTP cable not in a wireway or pathway a minimum of 8 inches above ceilings by cable supports not more than 60 inches apart.
- 3. Cable shall not be run through structural members or in contact with pipes, ducts, or other potentially damaging items. Where cable spans a break in cable tray due to conflict with ductwork or piping, provide "J-hook" on each side of obstruction to route/suspend cable above obstruction.
- E. Group connecting hardware for cables into separate logical fields.
- F. Separation from EMI Sources:
 - 1. Comply with BICSI TDMM and TIA/EIA-569-A for separating unshielded copper voice and data communication cable from potential EMI sources, including electrical power lines and equipment.
 - 2. Separation between open communications cables or cables in nonmetallic raceways and unshielded power conductors and electrical equipment shall be as follows:
 - a. Electrical Equipment Rating Less Than 2 kVA: A minimum of 5 inches.
 - 3. Separation between communications cables in grounded metallic raceways and unshielded power lines or electrical equipment shall be as follows:
 - a. Electrical Equipment Rating Less Than 2 kVA: A minimum of 2-1/2 inches.
 - 4. Separation between communications cables in grounded metallic raceways and power lines and electrical equipment located in grounded metallic conduits or enclosures shall be as follows:
 - a. Electrical Equipment Rating Less Than 2 kVA: No requirement.
 - 5. Separation between Communications Cables and Electrical Motors and Transformers, 5 kVA or HP and Larger: A minimum of 48 inches.

3.5 FIRESTOPPING

- A. Comply with requirements in Division 07 Section "Penetration Firestopping."
- B. Comply with TIA/EIA-569-A, Annex A, "Firestopping."

3.6 GROUNDING

- A. Install grounding according to BICSI TDMM, "Grounding, Bonding, and Electrical Protection" Chapter.
- B. Locate grounding bus bar in data room to minimize the length of bonding conductors. Fasten to wall allowing at least 2-inch clearance behind the grounding bus bar. Connect grounding bus

- bar with a minimum No. 4 AWG grounding electrode conductor from grounding bus bar to suitable electrical building ground.
- C. Bond metallic equipment to the grounding bus bar, using not smaller than No. 6 AWG equipment grounding conductor.

3.7 IDENTIFICATION

- A. Identify system components, wiring, and cabling complying with TIA/EIA-606-A. Comply with requirements for identification specified in Division 26 Section "Identification for Electrical Systems."
 - 1. Color-code cross-connect fields. Apply colors to data service connections, covers, and labels.
- B. Comply with requirements in Division 09 Section "Interior Painting" for painting backboards. For fire-resistant plywood, do not paint over manufacturer's label.
- C. Cable Schedule: Post in prominent location in each equipment room and wiring closet. List incoming and outgoing cables and their designations, origins, and destinations. Protect with rigid frame and clear plastic cover. Furnish an electronic copy of final comprehensive schedules for Project.
- D. Cabling Administration Drawings: Show building floor plans with cabling administration-point labeling. Identify labeling convention and show labels for telecommunications closets, horizontal cables, work areas and workstation terminal positions, grounding buses and pathways, and equipment grounding conductors. Follow convention of TIA/EIA-606-A. Furnish electronic record of all drawings, in software and format selected by Owner.

E. Cable and Wire Identification:

- 1. Label each cable within 4 inches of each termination and tap, where it is accessible in a cabinet or junction or outlet box, and elsewhere as indicated.
- 2. Exposed Cables: Label each cable at intervals not exceeding 15 feet.
- 3. Label each terminal strip and screw terminal in each cabinet, rack, or panel.
 - a. Individually number wiring conductors connected to terminal strips, and identify each cable or wiring group being extended from a panel or cabinet to a building-mounted device shall be identified with name and number of particular device as shown.
 - b. Label each unit and field within distribution racks and frames.
- 4. Identification within Connector Fields in Equipment Rooms and Wiring Closets: Label each connector and each discrete unit of cable-terminating and connecting hardware. Where similar jacks and plugs are used for both voice and data communication cabling, use a different color for jacks and plugs of each service.
- 5. Uniquely identify and label work area cables extending from the MUTOA to the work area. These cables may not exceed the length stated on the MUTOA label.

- F. Labels shall be preprinted or computer-printed type with printing area and font color that contrasts with cable jacket color but still complies with requirements in TIA/EIA-606-A.
 - 1. Cables use flexible vinyl or polyester that flex as cables are bent.

3.8 FIELD QUALITY CONTROL

A. Tests and Inspections:

- 1. Visually inspect UTP cable jacket materials for NRTL certification markings. Inspect cabling terminations in communications equipment rooms for compliance with color-coding for pin assignments, and inspect cabling connections for compliance with TIA/EIA-568-B.1.
- 2. Visually confirm Category 6 and Category 5e marking of outlets, cover plates, outlet/connectors, and patch panels.
- 3. Visually inspect cable placement, cable termination, grounding and bonding, equipment and patch cords, and labeling of all components.
- 4. UTP Performance Tests:
 - a. Test for each outlet and MUTOA. Perform the following tests according to TIA/EIA-568-B.1 and TIA/EIA-568-B.2:
 - 1) Wire map.
 - 2) Length (physical vs. electrical, and length requirements).
 - 3) Insertion loss.
 - 4) Near-end crosstalk (NEXT) loss.
 - 5) Power sum near-end crosstalk (PSNEXT) loss.
 - 6) Equal-level far-end crosstalk (ELFEXT).
 - 7) Power sum equal-level far-end crosstalk (PSELFEXT).
 - 8) Return loss.
 - 9) Propagation delay.
 - 10) Delay skew.
- 5. Final Verification Tests: Perform verification tests for UTP systems after the complete communications cabling and workstation outlet/connectors are installed.
 - a. Voice Tests: These tests assume that dial tone service has been installed. Connect to the network interface device at the demarcation point. Go off-hook and listen and receive a dial tone. If a test number is available, make and receive a local, long distance, and digital subscription line telephone call.
- B. Document data for each measurement. Data for submittals shall be printed in a summary report that is formatted similar to Table 10.1 in BICSI TDMM, or transferred from the instrument to the computer, saved as text files, and printed and submitted.
- C. Prepare test and inspection reports.

DARKE COUNTY WAGNER AVENUE INTERIOR RENOVATION

END OF SECTION 26 7561