

# Addendum



**DATE:** 10/17/2024

**PROJECT:** City of Springfield, Fire Station No. 5

**PROJECT ADDRESS:** 50 N. Thompson Avenue  
Springfield, Ohio 45504

615 Woodside Drive, Englewood, Ohio 45322

T 937.836.8898 F 937.832.3696

[www.app-arch.com](http://www.app-arch.com)

## **ADDENDUM NO. 7**

*RECEIPT OF THIS ADDENDUM MUST BE NOTED ON THE FORM OF PROPOSAL*

### **TO ALL BIDDERS:**

This addendum supplements and amends the original Plans and Specifications and shall be taken into account in preparing proposals and shall become part of the Contract Documents.

### **GENERAL ITEMS:**

ITEM G1 Questions & Answers

- Q1 E0.6 in electrical drawings shows the keyed 3-Button Control. Is this correct?  
A1 Standard flush mounted 3 button control with standard electrical switch to kill the timer in lieu of the keyed control is acceptable and preferred.
- Q2 I can't find the roofing spec, but the sheet metal spec calls for 22 ga. Where do I find that the roof is required to be 24 ga typical?  
A2 Roofing and siding is included in 13 3419 Metal Building Systems spec. There we call for the roofing to be ".024". This is technically between 22 & 24 gage. 24 gage is acceptable.
- Q3 Please verify the landscape bed type is mulch.  
A3 Gravel mulch is located at the generator/mechanical yard as shown on L1.0. Planting beds are mulch as defined by Note 7 under Landscaping Requirements on L1.0.

**END OF ADDENDUM NO. 7**

**ATTACHMENTS:** None