

ADDENDUM NO. #3
December 8, 2025
Fire Station 15 Renovations
(10% MBE PARTICIPATION GOAL)

TO ALL BIDDERS:

This addendum, including all articles and corrections listed below, shall be taken into account in preparing the Bid.

ITEM NO. 1 Questions and Answers

1. **Question:** The apparatus bay lighting shown on E2.1 does not match the lighting shown on E3.1. Quantities and direction of rows are different.

Answer: Lighting shown on E2.1 are correct. E3.1 shows the radiant heaters, not lights.

2. **Question:** What is the intent of the outside remote box showing both the inside and outside switch for the new generator?

Answer: The exterior box is a portable generator connection/switch, furnished and installed by the E.C. The interior Switch is a service entrance A.T.S., furnished by Owner, installed by the E.C. (see Single-Line diagram).

3. **Question:** On the finish plan A1.14 shows a coded note EQ-09 at the windows in the dorm rooms. I'm assuming this is for roller shades but the Finish schedule A0.02 doesn't have a EQ-09.

Answer: A1.14 is the Equipment Plan. EQ-09 is called out in the CFCI Schedule as "Blackout roller shade."

ITEM NO. 2 Bid Closing Date

1. To facilitate answering the above questions, the bid closing date is changed from December 11, 2025, to December 18, 2025.